



SLOVENSKI STANDARD

SIST EN 61643-311:2013

01-oktober-2013

Nadomešča:

SIST EN 61643-311:2005

Sestavni deli za nizkonapetostne naprave za zaščito pred prenapetostnimi udari - 311. del: Zahtevane lastnosti, preskusni tokokrogi in metode preskušanja plinskih odvodnikov (IEC 61643-311:2013)

Components for low-voltage surge protective devices - Part 311: Performance requirements and test circuits and methods for gas discharge tubes (GDT)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Composants pour parafoudres basse tension - Partie 311: Circuits et méthodes d'essai pour tubes à décharge de gaz

<https://standards.iteh.ai/catalog/standards/sist/70db3e0e-66bd-4bce-a8a2-77afaed17d5b/sist-en-61643-311-2013>

Ta slovenski standard je istoveten z: EN 61643-311:2013

ICS:

| | | |
|-----------|---|--|
| 29.120.50 | Varovalke in druga medtokovna zaščita | Fuses and other overcurrent protection devices |
| 29.240.10 | Transformatorske postaje. Prenapetostni odvodniki | Substations. Surge arresters |

SIST EN 61643-311:2013

en,fr

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 61643-311:2013](#)

<https://standards.iteh.ai/catalog/standards/sist/70db3e0e-66bd-4bce-a8a2-77afaed17d5b/sist-en-61643-311-2013>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 61643-311

August 2013

ICS 31.100; 33.040.99

Supersedes EN 61643-311:2001 (partially)

English version

**Components for low-voltage surge protective devices -
Part 311: Performance requirements and test circuits for gas discharge
tubes (GDT)
(IEC 61643-311:2013)**

Composants pour parafoudres basse
tension -
Partie 311: Exigences de performance et
circuits d'essai pour tubes à décharge de
gaz (TDG)
(CEI 61643-311:2013)

Bauelemente für
Überspannungsschutzgeräte für
Niederspannung -
Teil 311: Leistungsanforderungen sowie
Prüfschaltungen und -verfahren für
Gasentladungsableiter (ÜsAG)
(IEC 61643-311:2013)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 61643-311:2013](https://standards.iteh.ai/catalog/standards/sist/70db3e0e-66bd-4bce-a8a2-11d1-4078b7004764/EN-61643-311-2013)

<https://standards.iteh.ai/catalog/standards/sist/70db3e0e-66bd-4bce-a8a2-11d1-4078b7004764/EN-61643-311-2013>
This European Standard was approved by CENELEC on 2013-05-16. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 37B/113/FDIS, future edition 2 of IEC 61643-311, prepared by SC 37B, "Specific components for surge arresters and surge protective devices", of IEC TC 37, "Surge arresters" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61643-311:2013.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-02-16
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2016-05-16

This document partially supersedes EN 61643-311:2001.

EN 61643-311:2013 includes the following significant technical changes with respect to EN 61643-311:2001:

- addition of performance values.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice
<https://standards.iteh.ai/catalog/standards/sist/70db3e0e-66bd-4bce-a8a2-77afed17d5b/sist-en-61643-311-2013>

The text of the International Standard IEC 61643-311:2013 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

| | | |
|--------------------------------|------|---|
| IEC 60364-5-51:2005 | NOTE | Harmonised as HD 60364-5-51:2009 (modified). |
| IEC 61180-1:1992 | NOTE | Harmonised as EN 61180-1:1994 (not modified). |
| IEC 61643-312 | NOTE | Harmonised as EN 61643-312. |
| IEC 61643-11:2011 | NOTE | Harmonised as EN 61643-11:2012 (modified). |
| IEC 61643-21:2000 + A1:2008 | NOTE | Harmonised as EN 61643-21:2001 (not modified) + A1:2009 (modified) |

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

| <u>Publication</u> | <u>Year</u> | <u>Title</u> | <u>EN/HD</u> | <u>Year</u> |
|-----------------------------------|--------------|---|---------------|-------------|
| IEC 60068-2-1 | 2007 | Environmental testing - Part 2-1: Tests - Test A: Cold | EN 60068-2-1 | 2007 |
| IEC 60068-2-20 | 2008 | Environmental testing - Part 2-20: Tests - Test T: Test methods for solderability and resistance to soldering heat of devices with leads | EN 60068-2-20 | 2008 |
| IEC 60068-2-21 + corr. January | 2006 2012 | Environmental testing - Part 2-21: Tests - Test U: Robustness of terminations and integral mounting devices | EN 60068-2-21 | 2006 |
| IEC 61000-4-5 + corr. October | 2005 2009 | Electromagnetic compatibility (EMC) - Part 4-5: Testing and measurement techniques - Surge immunity test | EN 61000-4-5 | 2006 |
| ITU-T Recommendation K.20 | 2011 | Resistibility of telecommunication equipment - installed in a telecommunications centre to overvoltages and overcurrents | - | - |

<https://standards.iteh.ai/catalog/standards/sist/70db3e0e-66bd-4bce-a8a2-77afaed17d5b/sist-en-61643-311-2013>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 61643-311:2013](#)

<https://standards.iteh.ai/catalog/standards/sist/70db3e0e-66bd-4bce-a8a2-77afaed17d5b/sist-en-61643-311-2013>



IEC 61643-311

Edition 2.0 2013-04

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Components for low-voltage surge protective devices –
Part 311: Performance requirements and test circuits for gas discharge tubes
(GDT)**

**Composants pour parafoudres basse tension –
Partie 311: Exigences de performance et circuits d'essai pour tubes à décharge
de gaz (TDG)**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

U

ICS 31.100; 33.040.99

ISBN 978-2-83220-678-2

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

| | |
|--|----|
| FOREWORD..... | 4 |
| 1 Scope..... | 6 |
| 2 Normative references | 6 |
| 3 Terms, definitions and symbols | 7 |
| 3.1 Terms and definitions | 7 |
| 3.2 Symbols | 10 |
| 4 Service conditions | 10 |
| 4.1 Low temperature | 10 |
| 4.2 Air pressure and altitude | 10 |
| 4.3 Ambient temperature | 10 |
| 4.4 Relative humidity..... | 11 |
| 5 Mechanical requirements and materials..... | 11 |
| 5.1 Robustness of terminations | 11 |
| 5.2 Solderability | 11 |
| 5.3 Radiation..... | 11 |
| 5.4 Marking | 11 |
| 6 General | 11 |
| 6.1 Failure rates | 11 |
| 6.2 Standard atmospheric conditions | 11 |
| 7 Electrical requirements | 12 |
| 7.1 General | 12 |
| 7.2 Initial values | 12 |
| 7.2.1 Sparkover voltages | 12 |
| 7.2.2 Insulation resistance | 13 |
| 7.2.3 Capacitance | 13 |
| 7.2.4 Transverse voltage | 13 |
| 7.2.5 DC holdover | 13 |
| 7.3 Requirements after application of load..... | 13 |
| 7.3.1 General | 13 |
| 7.3.2 Sparkover voltages | 14 |
| 7.3.3 Insulation resistance | 14 |
| 7.3.4 AC follow current | 14 |
| 7.3.5 Fail-short (Failsafe) | 15 |
| 8 Test and measurement procedures and circuits | 15 |
| 8.1 DC sparkover voltage | 15 |
| 8.2 Impulse sparkover voltage | 16 |
| 8.3 Insulation resistance | 16 |
| 8.4 Capacitance | 16 |
| 8.5 Glow-to-arc transition current, glow voltage, arc voltage..... | 16 |
| 8.6 Transverse voltage..... | 18 |
| 8.7 DC holdover voltage | 19 |
| 8.7.1 General | 19 |
| 8.7.2 DC holdover voltage values | 21 |
| 8.8 Requirements for current-carrying capacity | 22 |
| 8.8.1 General | 22 |

| | | |
|-----------|---|----|
| 8.8.2 | Nominal alternating discharge current..... | 22 |
| 8.8.3 | Nominal impulse discharge current, waveshape 8/20 | 23 |
| 8.8.4 | Life test with impulse currents, waveshape 10/1 000 | 24 |
| 8.8.5 | AC follow current | 24 |
| 8.9 | Fail-short (failsafe) | 25 |
| | Bibliography..... | 27 |
| | | |
| Figure 1 | – Voltage and current characteristics of a GDT | 8 |
| Figure 2 | – Symbol for a two-electrode GDT | 10 |
| Figure 3 | – Symbol for a three-electrode GDT | 10 |
| Figure 4 | – Circuit for d.c. sparkover voltage test at 100 V/s | 15 |
| Figure 5 | – Circuit for impulse sparkover voltage at 1 000 V/ μ s | 16 |
| Figure 6 | – Test circuit for glow-to-arc transition current, glow voltage and arc voltage | 17 |
| Figure 7 | – Voltage-current characteristic of a typical GDT, suitable for measuring for example the glow-to-arc transition current, glow voltage, and arc voltage | 18 |
| Figure 8 | – Test circuit for transverse voltage | 19 |
| Figure 9 | – Test circuit for dc holdover voltage, two-electrode GDTs..... | 20 |
| Figure 10 | – Test circuit for dc holdover voltage, three-electrode GDTs | 20 |
| Figure 11 | – Circuit for nominal alternating discharge current, two-electrode GDTs..... | 23 |
| Figure 12 | – Circuit for nominal alternating discharge current, three-electrode GDTs | 23 |
| Figure 13 | – Circuit for nominal impulse discharge current, two-electrode GDTs | 23 |
| Figure 14 | – Circuit for nominal impulse discharge current, three-electrode GDTs..... | 23 |
| Figure 15 | – Circuit for life test with impulse current, two-electrode GDTs..... | 24 |
| Figure 16 | – Circuit for life test with impulse current, three-electrode GDTs | 24 |
| Figure 17 | – Test circuit for alternating follow current..... | 25 |
| Figure 18 | – Test circuit for fail-short (failsafe), two-electrode GDTs | 26 |
| Figure 19 | – Test circuit for fail-short (failsafe), three-electrode GDTs | 26 |
| | | |
| Table 1 | – DC and impulse sparkover voltage requirements, initial..... | 12 |
| Table 2 | – Values of sparkover voltages after the tests of Table 5..... | 14 |
| Table 3 | – Values for different d.c. holdover voltage tests for two-electrode GDTs | 21 |
| Table 4 | – Values for different d.c. holdover voltage tests for three-electrode GDTs..... | 21 |
| Table 5 | – Different classes of current-carrying capacity | 22 |

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMPONENTS FOR LOW-VOLTAGE
SURGE PROTECTIVE DEVICES –****Part 311: Performance requirements and
test circuits for gas discharge tubes (GDT)**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61643-311 has been prepared by subcommittee 37B: Specific components for surge arresters and surge protective devices, of IEC technical committee 37: Surge arresters.

This second edition of IEC 61643-311 cancels and replaces the first edition published in 2001. It constitutes a technical revision.

Specific changes with respect to the previous edition are:

- Addition of performance values.

The text of this standard is based on the following documents:

| FDIS | Report on voting |
|--------------|------------------|
| 37B/113/FDIS | 37B/118/RVD |

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of IEC 61643 series, under the general title *Components for low-voltage surge protective devices* can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 61643-311:2013](https://standards.iteh.ai/catalog/standards/sist/70db3e0e-66bd-4bce-a8a2-77afaed17d5b/sist-en-61643-311-2013)

<https://standards.iteh.ai/catalog/standards/sist/70db3e0e-66bd-4bce-a8a2-77afaed17d5b/sist-en-61643-311-2013>

COMPONENTS FOR LOW-VOLTAGE SURGE PROTECTIVE DEVICES –

Part 311: Performance requirements and test circuits for gas discharge tubes (GDT)

1 Scope

This part of IEC 61643 is applicable to gas discharge tubes (GDT) used for overvoltage protection in telecommunications, signalling and low-voltage power distribution networks with nominal system voltages up to 1 000 V (r.m.s.) a.c. and 1 500 V d.c.. They are defined as a gap, or several gaps with two or three metal electrodes hermetically sealed so that gas mixture and pressure are under control. They are designed to protect apparatus or personnel, or both, from high transient voltages. This standard contains a series of test criteria, test methods and test circuits for determining the electrical characteristics of GDTs having two or three electrodes. This standard does not specify requirements applicable to complete surge protective devices, nor does it specify total requirements for GDTs employed within electronic devices, where precise coordination between GDT performance and surge protective device withstand capability is highly critical.

This part of IEC 61643

- does not deal with mountings and their effect on GDT characteristics. Characteristics given apply solely to GDTs mounted in the ways described for the tests;
- does not deal with mechanical dimensions;
- does not deal with quality assurance requirements;
- may not be sufficient for GDTs used on high-frequency (>30 MHz);
- does not deal with electrostatic voltages;
- does not deal with hybrid overvoltage protection components or composite GDT devices.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-1:2007, *Environmental testing – Part 2: Tests. Tests A: Cold*

IEC 60068-2-20:2008, *Environmental testing – Part 2: Tests. Test T: Test methods for solderability and resistance to soldering heat of devices with leads*

IEC 60068-2-21:2006, *Environmental testing – Part 2-21: Tests – Test U: Robustness of terminations and integral mounting devices*

IEC 61000-4-5:2005, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 5: Surge immunity test*

ITU-T Recommendation K.20:2011, *Resistibility of telecommunication equipment installed in a telecommunications centre to overvoltages and overcurrents*