

SLOVENSKI STANDARD SIST-TS CLC/TS 50131-7:2011

01-maj-2011

Nadomešča:

SIST-TS CLC/TS 50131-7:2009

Alarmni sistemi - Sistemi za javljanje vloma - 7. del: Navodila za uporabo

Alarm systems - Intrusion and hold-up systems - Part 7: Application guidelines

Alarmanlagen - Einbruch- und Überfallmeldeanlagen - Teil 7: Anwendungsregeln

iTeh STANDARD PREVIEW

Systèmes d'alarme - Systèmes d'alarme contre l'intrusion et les hold-up - Partie 7: Guide d'application (standards.iteh.ai) d'application

SIST-TS CLC/TS 50131-7:2011

Ta slovenski standard/jenistoveten zbg/stanGLC/TS:50131-7:2010)a33-

32493a27e490/sist-ts-clc-ts-50131-7-2011

ICS:

13.310 Varstvo pred kriminalom Protection against crime 13.320 Alarmni in opozorilni sistemi Alarm and warning systems

SIST-TS CLC/TS 50131-7:2011 en

SIST-TS CLC/TS 50131-7:2011

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST-TS CLC/TS 50131-7:2011 https://standards.iteh.ai/catalog/standards/sist/7c2d3805-ae0a-4b50-9a33-32493a27e490/sist-ts-clc-ts-50131-7-2011

TECHNICAL SPECIFICATION SPÉCIFICATION TECHNIQUE TECHNISCHE SPEZIFIKATION

CLC/TS 50131-7

July 2010

ICS 13.310

Supersedes CLC/TS 50131-7:2008

English version

Alarm systems -Intrusion and hold-up systems -Part 7: Application guidelines

Systèmes d'alarme -Systèmes d'alarme contre l'intrusion et les hold-up -Partie 7: Guide d'application Alarmanlagen -Einbruch- und Überfallmeldeanlagen -Teil 7: Anwendungsregeln

iTeh STANDARD PREVIEW (standards.iteh.ai)

This Technical Specification was approved by CENELEC on 2010-06-25.

CENELEC members/are required to announce the existence of this TS-in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

This Technical Specification was prepared by the Technical Committee CENELEC TC 79, Alarm systems. It was circulated for vote in accordance with the Internal Regulations, Part 2, Subclause 11.3.3.3 and was approved by CENELEC as CLC/TS 50131-7 on 2010-06-25

This document supersedes CLC/TS 50131-7:2008.

Compared to the previous edition the changes are the following:

- 3.1.46: note deleted;
- 10.2: "the test signals replaced with "these signals" in the last paragraph;
- 10.4: "hold-up triggering devices" replaced with "hold-up devices" in the 2nd paragraph;
- Annex B, B.6: "Psychological problems of persons after robbery" deleted;
- Annex D, D.13: "avoid" replaced with "minimize".

The following date was fixed:

latest date by which the existence of the CLC/TS has to be announced at national level

(doa) 2011-01-01

The EN/TS 50131 series consists of the following parts, under the general title *Alarm systems* – *Intrusion and hold-up systems*:

Part 1	System requirements
Part 2-2	Intrusion detectors Passive infrared detectors
Part 2-3	https://standards.iteh.ai/catalog/standards/sist/7c2d3805-ae0a-4b50-9a33- Requirements for microwave detectors 32493a27e490/sist-is-cic-is-50131-7-2011
Part 2-4	Requirements for combined passive infrared and microwave detectors
Part 2-5	Requirements for combined passive infrared and ultrasonic detectors
Part 2-6	Opening contacts (magnetic)
Part 2-7-1	Intrusion detectors – Glass break detectors (acoustics)
Part 2-7-2	Intrusion detectors – Glass break detectors (passive)
Part 2-7-3	Intrusion detectors – Glass break detectors (active)
Part 2-8 1)	Intrusion detectors – Vibration detectors
Part 2-9 1)	Intrusion detectors – Active infrared detectors
Part 3	Control and indicating equipment
Part 4	Warning devices
Part 5-1 1)	Requirements for wired interconnection for I&HAS equipments located in supervised premises
Part 5-3	Requirements for interconnections equipment using radio frequency techniques
Part 6	Power supplies
Part 7	Application guidelines
Part 8	Security fog device/systems
Part 9 1)	Alarm verification – Methods and principles

¹⁾ At draft stage.

Contents

Inti	Introduction5				
1	Scop	e	7		
2	Norm	native references	7		
3	Terms, definitions and abbreviations				
	3.1	Terms and definitions			
	3.2	Abbreviations	12		
4	Secu	rity grade of I&HAS	12		
	4.1	Security grading	12		
5	Envir	onmental classification			
	5.1	Environmental Class I – Indoor	13		
	5.2	Environmental Class II – Indoor – General			
	5.3	Environmental Class III – Outdoor – Sheltered or indoor extreme conditions	13		
	5.4	Environmental Class IV – Outdoor – General	13		
6	Gene	ral	14		
	6.1	Other components	14		
	6.2	Electrical safety	14		
	6.3	Unwanted alarms	14		
	6.4	Unwanted alarms Responsibility Ch STANDARD PREVIEW	14		
	6.5	Qualifications (standards.iteh.ai) Competence	14		
	6.6	Competence (Standards.itch.ar)	14		
	6.7	Tools <u>SIST-TS:CLC/TS:50131-7:2011</u>	14		
	6.8	Confidentialitystandards.itch.ai/catalog/standards/sist/7c2d3805-ac0a-4b50-9a33	14		
	6.9	Consultation 32493a27e490/sist-ts-clc-ts-50131-7-2011			
	6.10	Compatibility			
7	Syste	em design			
	7.1	Location survey – Risk	15		
	7.2	Location survey – Other influences			
	7.3	System design proposal			
8		llation planning	21		
	O		21		
9	Syste	em installation	22		
	9.1	Installation process			
10	Inspe	ection, functional testing and commissioning	22		
	10.1	Inspection	22		
	10.2	Functional testing	22		
	10.3	Commissioning	22		
		Handover			
		Test period			
		Acceptance			
		As-fitted document			
		Certificate of conformance			
11		mentation and records			
		Documentation			
		Records			
12	Oper	ation of I&HAS	25		

13 Maintenance and repair of I&HAS	25
13.1 General	25
13.2 Inspection and servicing	25
13.3 Repair	26
Annex A (normative) Special national conditions	
Annex B (informative) System design – Location survey – Contents	28
Annex C (informative) Systems design – Location survey – Building	29
Annex D (informative) Location survey – Influences affecting I&HAS originating within the supervised premises	31
Annex E (informative) Location survey – Influences affecting I&HAS originating outside the supervised premises	34
Annex F (informative) Levels of supervision	36
Annex G (normative) Information to be included in the system design proposal	37
Annex H (informative) Technical survey	39
Annex I (informative) System record (log book)	51
Annex J (informative) Maintenance	52
Annex K (informative) Flow chart	53
Bibliography	
iTeh STANDARD PREVIEW	
Table (standards.iteh.ai)	
Table F.1 – Levels of supervision	36
SIST-TS CLC/TS 50131-7:2011 Figure https://standards.iteh.ai/catalog/standards/sist/7c2d3805-ae0a-4b50-9a33-	
224022272400/airt to also to 50121 7 2011	
Figure K 1 – Flow chart 3249382 /6490/SSI-IS-CIC-IS-30131-7-2011	53

Introduction

These application guidelines are intended to provide advice relating to the design, installation, operation and maintenance of Intruder and Hold-up Alarm Systems (I&HAS). The purpose of this document is to ensure, as far as is practical, that I&HAS provide the required performance with a minimum of unwanted alarms.

These application guidelines are set out in the logical order in which an I&HAS would normally be designed and installed. Each procedure is set out separately in the guideline but it is accepted that, in practice, some of the procedures may be carried out simultaneously. Annex K describes in the form of a flowchart the main processes and documentation included in this application guideline.

Those responsible for the design, installation planning, system installation, commissioning, operation and maintenance of I&HAS should be conversant with other European Standards relating to I&HAS, particularly those relating to system performance, control and indicating equipment, detectors, warning devices, power supplies and alarm transmission systems.

These application guidelines are set out in seven main clauses; a brief explanation of each section is shown below.

i) Clause 7 – System design

This clause is intended to assist those responsible for designing I&HAS to design I&HAS suitable for the premises to be supervised in relation to the perceived risk(s). The design of I&HAS will depend on many factors all of which will influence more or less the design of I&HAS. Consideration of these factors will result in a system design proposal for an I&HAS with the appropriate extent, security grade and environmental class.

SIST-TS CLC/TS 50131-7:2011

ii) Clause 8 – Installation planninghai/catalog/standards/sist/7c2d3805-ae0a-4b50-9a33-32493a27e490/sist-ts-clc-ts-50131-7-2011

This clause is intended to help those responsible for installing I&HAS by highlighting issues which should be considered prior to commencing the installation of the I&HAS.

iii) Clause 9 – System installation

In this clause, guidance is given with regard to issues arising during the installation of I&HAS. This clause is intended to ensure I&HAS is correctly installed as specified at the design stage.

iv) Clause 10 - Inspection, functional testing and commissioning

In this clause, guidance is given on issues arising after I&HAS has been installed. The clause is intended to ensure I&HAS has been installed as specified and also provides the level of performance intended at the design stage. Guidance is also provided with regard to the proper commissioning and handing over of the system to the user and to the documents, records and operating instructions which should be provided.

v) Clause 11 - Documentation and records

This clause describes the documentation which should be provided to the client on completion of I&HAS. The documents are intended to provide a history of modifications to I&HAS, based on the as-fitted document, prepared when I&HAS installation was completed.

The records are intended to chronicle any corrective action carried out following unwanted alarm conditions and details of any repairs or modifications to I&HAS. The record should also include details of temporary fault conditions.

CLC/TS 50131-7:2010

-6-

vi) Clause 12 - Operation of I&HAS

This clause describes the responsibility of the client or user of I&HAS to properly maintain I&HAS and to ensure it is operated correctly.

vii) Clause 13 - Maintenance and repair of I&HAS

This clause describes how I&HAS should be maintained and repaired to ensure I&HAS continues to provide the level of performance intended at the design stage.

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST-TS CLC/TS 50131-7:2011 https://standards.iteh.ai/catalog/standards/sist/7c2d3805-ae0a-4b50-9a33-32493a27e490/sist-ts-clc-ts-50131-7-2011

1 Scope

These application guidelines include guidance on the design, planning, operation, installation, commissioning and maintenance of I&HAS installed in buildings. Requirements for I&HAS are specified in EN 50131-1:2006.

The recommendations of this Technical Specification (TS) also apply to IAS and HAS when these systems are installed independently.

When an I&HAS does not include functions relating to the detection of intruders, the requirements relating to intrusion detection do not apply.

When an I&HAS does not include functions relating to hold-up, the requirements relating to hold-up do not apply.

NOTE Unless otherwise stated the abbreviation I&HAS is intended to also mean IAS and HAS.

These application guidelines are intended to assist those responsible for establishing an I&HAS to ascertain the appropriate design of I&HAS both in terms of the extent of the supervision required and in determining the grade of system performance necessary to provide the degree of supervision considered appropriate.

These application guidelines are also intended to assist those responsible for selecting equipment appropriate to both the level of performance required and the environmental conditions in which the equipment will be required to operate.

(standards.iteh.ai)

These application guidelines are relevant to all classes and grades of I&HAS of any size and complexity. These application guidelines should be read in conjunction with EN 50131-1:2006.

NOTE It has been assumed in the drafting of these application guidelines that the execution of its provisions will be entrusted to appropriately qualified and experienced persons. However the guidance is also appropriate to other persons who may be required to purchase or use an I&HAS.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50131-1:2006, Alarm systems – Intrusion and hold-up systems – Part 1: System requirements

EN 61082-1:2006, Preparation of documents used in electrotechnology – Part 1: Rules (IEC 61082-1:2006)

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1.1

alarm

warning of the presence of a hazard to life, property or the environment

3.1.2

alarm receiving centre

continuously manned centre to which information concerning the status of one or more I&HAS is reported

alarm company

organization which provides services for I&HAS

3.1.4

alarm condition

condition of an I&HAS, or part thereof, which results from the response of the system to the presence of a hazard

3.1.5

alarm system

electrical installation which responds to the manual or automatic detection of the presence of a hazard

3.1.6

alarm transmission system

equipment and network used to transfer information concerned with the state of one or more I&HAS to one or more alarm receiving centre

NOTE Alarm transmission systems exclude local direct connections, i.e. interconnections between parts of an I&HAS which do not require an interface to transform I&HAS information into a form suitable for transmission.

3.1.7

ancillary control equipment

equipment used for supplementary control purposes

3.1.8

as-fitted document iTeh STANDARD PREVIEW

document in which details of I&HAS as actually installed are recorded

3.1.9

control and indicating equipment SIST-TS CLC/TS 50131-7:2011

equipment for receiving;/processing).controlling;indicating?and@initiating;5the@nward transmission of information 32493a27e490/sist-ts-clc-ts-50131-7-2011

3.1.10

commissioning

putting an I&HAS into operational mode

3.1.11

client

individual or corporate body responsible for acquiring the I&HAS

3.1.12

detector

device designed to generate an intruder alarm signal or message in response to the sensing of an abnormal condition indicating the presence of a hazard

3.1.13

documentation

paperwork (or other media) prepared during the design, installation, commissioning and handover of I&HAS recording details of the I&HAS

3.1.14

entry/exit route

route by which authorized entry or exit to the supervised area or part thereof may be achieved

3.1.15

equipment schedule

list of equipment to be installed or actually installed

fault condition

condition of an alarm system which prevents an I&HAS or parts thereof from functioning normally

3.1.17

entry/exit point

point at which the user enters or leaves the supervised premises

EXAMPLE Entrance door to supervised premises

3.1.18

hold-up alarm system

alarm system providing the means for a user to deliberately generate a hold-up alarm condition

3.1.19

hold-up device

device which when triggered causes a hold-up alarm signal or message to be generated

3.1.20

hold-up alarm condition

condition of an alarm system, or part thereof, which results from the response of an I&HAS to the triggering of a hold-up device

3.1.21

inhibit

status of a part of an I&HAS in which an alarm condition cannot be notified, such status remaining until I&HAS or part thereof is unset (standards.iteh.ai)

3.1.22

installation company

company responsible for installing the I&HAS https://standards.iteh.av.catalog/standards/sist/7c2d3805-ae0a-4b50-9a33-

32493a27e490/sist-ts-clc-ts-50131-7-2011

3.1.23

installation plan

document describing the methodology to be followed during the installation of the I&HAS

3.1.24

installer

individual or individuals responsible for carrying out the installation process

3.1.25

intruder alarm system

alarm system to detect and indicate the presence, entry or attempted entry of an intruder into supervised premises

3.1.26

interconnection

means by which messages and/or signals are transmitted between I&HAS components

3.1.27

isolation

status of a part of an alarm system in which an alarm condition cannot be notified, such status remaining until deliberately cancelled

3.1.28

non-specific wired interconnection

interconnection conveying information pertaining to two or more applications

3.1.29

normal condition

state of an I&HAS system where no conditions exist which would prevent the setting of the I&HAS

notification

passing of an alarm, tamper or fault condition to warning devices and/or alarm transmission systems

3.1.31

operational mode

state of an alarm system when it is complete, commissioned and ready for use

3.1.32

part set

status of an I&HAS in which an intruder alarm condition can be notified but part of I&HAS is unset

3.1.33

power supply

that part of an alarm system which provides power for I&HAS or any part thereof

3.1.34

response authority

designated authority with responsibility for attending the supervised premises following an alarm and taking the appropriate action

3.1.35

set

status of an I&HAS or part thereof in which an alarm condition can be notified

3.1.36 iTeh STANDARD PREVIEW

specific wired interconnection

interconnection conveying information pertaining to one application

3.1.37

specifier

SIST-TS CLC/TS 50131-7:2011

individual or corporate body responsible for stipulating the requirements I&HAS will be required to meet

3.1.38

subsystem

that part of an I&HAS located in a clearly defined part of the supervised premises capable of independent operation

3.1.39

supervised premises

part of a building and/or area in which an intrusion, attempted intrusion, or the triggering of a hold-up device may be detected by an I&HAS

3.1.40

supervised premises transceiver

equipment at the supervised premises, including the interface to the alarm system and the interface to the alarm transmission network

3.1.41

system components

individual items of equipment which constitute an I&HAS when configured together

3.1.42

system record

history of maintenance, faults, repair or modifications to the IAS

EXAMPLE A log book

tamper

deliberate interference with an I&HAS or part thereof

3.1.44

tamper alarm

alarm generated by tamper detection

3.1.45

tamper condition

condition of an I&HAS in which tampering has been detected

3.1.46

tamper protection

methods or means used to protect an I&HAS or part thereof against deliberate interference.

3.1.47

technical survey

inspection of the premises to be supervised, carried out after the proposal has been accepted, to verify the selection, location and siting of system components and to consider the selection of components in relation to the environmental conditions to which the system components will be exposed

3.1.48

unset

status of an I&HAS or part thereof in which an alarm condition cannot be notified

3.1.49

(standards.iteh.ai)

user

person authorized to operate an I&HASST-TS CLC/TS 50131-7:2011

3.1.50 nttps://standards.ite

https://standards.iteh.ai/catalog/standards/sist/7c2d3805-ae0a-4b50-9a33-ae0a-4b50-9a0-4b0-9a0-

32493a27e490/sist-ts-clc-ts-50131-7-2011

unknown alarm

alarm for which the cause cannot be positively identified

3.1.51

unwanted alarm

alarm conditions not generated by an intrusion or attempted intrusion into the supervised premises

3.1.52

warning device

device that gives an audible alarm in response to a notification

NOTE A warning device may also provide alert indications providing such indications are easily distinguishable from an alarm.

3.1.53

wire-free interconnection

interconnection conveying information between I&HAS components without physical media

3.1.54

zone

assessed area of a supervised premises where an intrusion, attempted intrusion, or the triggering of a hold-up device may be detected by an I&HAS

3.2 Abbreviations

For the purposes of this document, the following abbreviations apply.

Ancillary Control Equipment ACE

APS Alternative Power Source

ARC Alarm Receiving Centre

ATS Alarm Transmission System

CIE Control and Indicating Equipment

HAS Hold-up Alarm System(s)

Intrusion and Hold-up Alarm System(s) **I&HAS**

IAS Intruder Alarm System(s)

PIR Passive Infra-Red

PS Power Supply

SPT Supervised Premises Transceiver

WD

Warning Device Teh STANDARD PREVIEW

4 Security grade of I&HAS(standards.iteh.ai)

The security grade of I&HAS will depend upon the performance required as determined during the risk assessment and location/survey.ls.iteh.ai/catalog/standards/sist/7c2d3805-ae0a-4b50-9a33-

32493a27e490/sist-ts-clc-ts-50131-7-2011

An I&HAS may include I&HAS components of differing grades when divided into clearly defined sub-systems. When I&HAS is divided into sub-systems, each sub-system may be of a different grade. The grade of a sub-system shall be that of the lowest graded component within it.

Components shared by more than one sub-system should have a grade equal to that of the highest sub-system grade, e.g. control and indicating equipment, alarm transmission system, warning devices and power supplies.

4.1 Security grading

EN 50131-1:2006 describes four security grades which should be considered when selecting equipment. These are as follows.

4.1.1 Grade 1 - Low risk

An intruder or robber is expected to have little knowledge of I&HAS and be restricted to a limited range of easily available tools.

4.1.2 Grade 2 - Low to medium risk

An intruder or robber is expected to have a limited knowledge of I&HAS and the use of a general range of tools and portable instruments (e.g. a multi-meter).

4.1.3 Grade 3 - Medium to high risk

An intruder or robber is expected to be conversant with I&HAS and have a comprehensive range of tools and portable electronic equipment.

4.1.4 Grade 4 - High risk

To be used when security takes precedence over all other factors. An intruder or robber is expected to have the ability or resource to plan an intrusion or robbery in detail and have a full range of equipment, including means of substitution of components in an I&HAS.

NOTE In all grades the term "intruder" is intended to embrace other types of threat (e.g. robbery or the threat of physical violence, which might influence the design of an I&HAS).

5 Environmental classification

The environmental class of each system component should be determined by the environmental conditions in which the component is expected to operate.

NOTE 1 Classes I, II, III and IV are progressively more severe and therefore Class IV components may, for example, be used in Class III I&HAS.

NOTE 2 Annex A includes special national conditions for specified countries.

EN 50131-1:2006 defines 4 environmental classes as shown below.

5.1 Environmental Class I - Indoor

Environmental influences normally experienced indoors when the temperature is well maintained (e.g. in a residential or commercial property) ANDARD PREVIEW

NOTE Temperatures may be expected to vary between +5 °C and +40 °C all

5.2 Environmental Class II - Indoor - General

SIST-TS CLC/TS 50131-7:2011

https://standards.iteh.ai/catalog/standards/sist/7c2d3805-ae0a-4b50-9a33-

Environmental influences normally experienced indoors when the temperature is not well maintained (e.g. in corridors, halls or staircases and where condensation can occur on windows and in unheated storage areas or warehouses where heating is intermittent).

NOTE Temperatures may be expected to vary between -10 °C and +40 °C.

5.3 Environmental Class III - Outdoor - Sheltered or indoor extreme conditions

Environmental influences normally experienced out of doors when I&HAS components are not fully exposed to the weather or indoors where environmental conditions are extreme.

NOTE Temperatures may be expected to vary between -25 °C and +50 °C.

5.4 Environmental Class IV – Outdoor – General

Environmental influences normally experienced out of doors when I&HAS components are fully exposed to the weather.

NOTE Temperatures may be expected to vary between -25 °C and +60 °C.