

SLOVENSKI STANDARD

SIST EN 62271-200:2012

01-marec-2012

Nadomešča:

SIST EN 62271-200:2004

Visokonapetostne stikalne in krmilne naprave - 200. del: Stikalne in krmilne naprave v kovinskih ohišjih za naznačene izmenične napetosti nad 1 kV in do vključno 52 kV (IEC 62271-200:2011)

High-voltage switchgear and controlgear - Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV (IEC 62271-200:2011)

iTeh STANDARD PREVIEW

(standards.itech.ai)

Hochspannungs-Schaltgeräte und -Schaltanlagen - Teil 200: Metallgekapselte Wechselstrom-Schaltanlagen für Bemessungsspannungen über 1 kV bis einschließlich 52 kV (IEC 62271-200:2011)

<https://standards.itech.ai/catalog/standards/sist/01cd79c2-7df7-417a-9582-c9b76be0f848/sist-en-62271-200-2012>

Appareillage à haute tension - Partie 200: Appareillage sous enveloppe métallique pour courant alternatif de tensions assignées supérieures à 1 kV et inférieures ou égales à 52 kV (CEI 62271-200:2011)

Ta slovenski standard je istoveten z: EN 62271-200:2012

ICS:

29.130.10	Visokonapetostne stikalne in krmilne naprave	High voltage switchgear and controlgear
-----------	--	---

SIST EN 62271-200:2012

en

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 62271-200:2012

<https://standards.iteh.ai/catalog/standards/sist/01cd79c2-7df7-417a-9582-c9b76be0f848/sist-en-62271-200-2012>

**High-voltage switchgear and controlgear -
Part 200: AC metal-enclosed switchgear and controlgear for rated
voltages above 1 kV and up to and including 52 kV
(IEC 62271-200:2011)**

Appareillage à haute tension -
Partie 200: Appareillage sous enveloppe
métallique pour courant alternatif de
tensions assignées supérieures à 1 kV et
inférieures ou égales à 52 kV
(CEI 62271-200:2011)

Hochspannungs-Schaltgeräte und -
Schaltanlagen -
Teil 200: Metallgekapselte Wechselstrom-
Schaltanlagen für
Bemessungsspannungen über 1 kV bis
einschließlich 52 kV
(IEC 62271-200:2011)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 62271-200:2012

<https://standards.iteh.ai/catalog/standards/sist/01cd79c2-7df7-417a-9582-c9d706c0449/sist-en-62271-200-2012>

This European Standard was approved by CENELEC on 2011-11-28. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 17C/523/FDIS, future edition 2 of IEC 62271-200, prepared by SC 17C, "High-voltage switchgear and controlgear assemblies", of IEC/TC 17, "Switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62271-200:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-08-28
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2014-11-28

This document supersedes EN 62271-200:2004.

EN 62271-200:2012 has been further updated and improved to the experience gained with EN 62271-200:2004. As maintenance result, EN 62271-200:2012 introduces the following significant changes:

- definitions, classifications and testing procedures are specified more precisely;
- categories LSC2A and LSC2B have been clarified and LSC2 has been assigned a separate definition;
- specific ratings related to fault level to earth (4.5 to 4.7) are introduced;
- solid insulated high-voltage parts are no longer considered as compartments on their own;
- an optional rating "cable test voltage" and the associated requirements and type tests are introduced;
- for testing the internal arc classification, when assigned by the manufacturer, more specific guidance is provided regarding the test arrangement, room simulation and arc initiation;
- a single phase to earth ignition is also recognised for internal arc testing;
- the Annexes A and B are renumbered Annexes AA and BB.

The level of severity of internal arc testing is maintained without changes.

This European Standard should be read in conjunction with EN 62271-1:2008, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in EN 62271-1. Amendments to these clauses and subclauses are given under the same numbering, whilst additional subclauses, are numbered from 101.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62271-200:2011 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60059:1999	NOTE Harmonized as EN 60059:1999 (not modified).
IEC 60243-1:1998	NOTE Harmonized as EN 60243-1:1998 (not modified).
IEC 60909-0:2001	NOTE Harmonized as EN 60909-0:2001 (not modified).
IEC 62271-203:2003	NOTE Harmonized as EN 62271-203:2004 (not modified).
IEC/TR 62271-303:2008	NOTE Harmonized as CLC/TR 62271-303:2009 (not modified).

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 62271-200:2012](https://standards.iteh.ai/catalog/standards/sist/01cd79c2-7df7-417a-9582-c9b76be0f848/sist-en-62271-200-2012)
<https://standards.iteh.ai/catalog/standards/sist/01cd79c2-7df7-417a-9582-c9b76be0f848/sist-en-62271-200-2012>

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-151	-	International Electrotechnical Vocabulary (IEV) - Part 151: Electrical and magnetic devices	-	-
IEC 60050-441	1984	International Electrotechnical Vocabulary (IEV) - Chapter 441: Switchgear, controlgear and fuses	-	-
IEC 60060-1	-	High-voltage test techniques - Part 1: General definitions and test requirements	EN 60060-1	-
IEC 60270	-	High-voltage test techniques - Partial discharge measurements	EN 60270	-
IEC 60470	1999	High-voltage alternating current contactors and contactor-based motor starters	EN 60470 ¹⁾ + corr. June	2000 2000
IEC 60529	1989	Degrees of protection provided by enclosures (IP Code)	EN 60529 + corr. May	1991 1993
IEC 62262	-	Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)	EN 62262	-
IEC 62271-1	2007	High-voltage switchgear and controlgear - Part 1: Common specifications	EN 62271-1	2008
IEC 62271-100	-	High-voltage switchgear and controlgear - Part 100: Alternating current circuit-breakers	EN 62271-100	-
IEC 62271-102 + corr. April + corr. February + corr. May	2001 2002 2005 2003	High-voltage switchgear and controlgear - Part 102: Alternating current disconnectors and earthing switches	EN 62271-102 + corr. July + corr. March	2002 2008 2005
IEC 62271-103	-	High-voltage switchgear and controlgear - Part 103: Switches for rated voltages above 1 kV up to and including 52 kV	EN 62271-103	-
IEC 62271-105	-	High-voltage switchgear and controlgear - Part 105: Alternating current switch-fuse combinations	EN 62271-105	-
IEC 62271-201	2006	High-voltage switchgear and controlgear - Part 201: AC insulation-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	EN 62271-201 + corr. November	2006 2006

¹⁾ EN 60470:2000 is superseded by EN 62271-106:2011, which is based on IEC 62271-106:2011.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC/TS 62271-304	-	High-voltage switchgear and controlgear - Part 304: Design classes for indoor enclosed switchgear and controlgear for rated voltages above 1 kV up to and including 52 kV to be used in severe climatic conditions	CLC/TS 62271-304	-
ISO/IEC Guide 51	1999	Safety aspects - Guidelines for their inclusion in standards		-

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 62271-200:2012

<https://standards.iteh.ai/catalog/standards/sist/01cd79c2-7df7-417a-9582-c9b76be0f848/sist-en-62271-200-2012>

Annex ZB (informative)

A-deviations

A-deviation: National deviation due to regulations, the alteration of which is for the time being outside the competence of the CENELEC member.

This European Standard does not fall under any Directive.

In the relevant CEN/CENELEC countries these A-deviations are valid instead of the provisions of the European Standard until they have been removed.

<u>Clause</u>	<u>Deviation</u>
1	<p>Italy (Italian pressure vessel code for electrical switchgear DM 1 December 1980 and DM 10 September 1981 published in Gazzetta Ufficiale n° 285 dated 16.10.1981)</p> <p>For metal-enclosed switchgear and controlgear containing gas-filled compartments, the design pressure is limited to a maximum of 0,5 bar (gauge) and the volume is limited to a maximum of 2 m³. Gas filled compartments having a design pressure exceeding 0,5 bar (gauge) or a volume exceeding 2 m³ shall be designed according to the Italian pressure vessel code for electrical switchgear.</p>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 62271-200:2012](https://standards.iteh.ai/catalog/standards/sist/01cd79c2-7df7-417a-9582-c9b76be0f848/sist-en-62271-200-2012)
<https://standards.iteh.ai/catalog/standards/sist/01cd79c2-7df7-417a-9582-c9b76be0f848/sist-en-62271-200-2012>



IEC 62271-200

Edition 2.0 2011-10

INTERNATIONAL STANDARD

NORME INTERNATIONALE



High-voltage switchgear and controlgear –
Part 200: AC metal-enclosed switchgear and controlgear for rated voltages
above 1 kV and up to and including 52 kV

Appareillage à haute tension –
Partie 200: Appareillage sous enveloppe métallique pour courant alternatif
de tensions assignées supérieures à 1 kV et inférieures ou égales à 52 kV

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XC

ICS 29.130.10

ISBN 978-2-88912-743-6

CONTENTS

FOREWORD.....	5
1 General	7
1.1 Scope.....	7
1.2 Normative references	8
2 Normal and special service conditions	8
3 Terms and definitions	9
4 Ratings.....	15
4.1 Rated voltage (U_r)	15
4.2 Rated insulation level	16
4.3 Rated frequency (f_r).....	16
4.4 Rated normal current and temperature rise	16
4.5 Rated short-time withstand currents (I_k).....	16
4.6 Rated peak withstand current (I_p)	16
4.7 Rated durations of short circuit (t_k)	17
4.8 Rated supply voltage of closing and opening devices and of auxiliary and control circuits (U_a).....	17
4.9 Rated supply frequency of closing and opening devices and of auxiliary circuits.....	17
4.10 Rated pressure of compressed gas supply for controlled pressure systems	17
4.11 Rated filling levels for insulation and/or operation	17
4.101 Ratings of the internal arc classification (IAC).....	17
4.102 Rated cable test voltages.....	19
5 Design and construction	19
5.1 Requirements for liquids in switchgear and controlgear	19
5.2 Requirements for gases in switchgear and controlgear	19
5.3 Earthing of switchgear and controlgear	20
5.4 Auxiliary and control equipment	21
5.5 Dependent power operation	21
5.6 Stored energy operation	21
5.7 Independent manual or power operation (independent unlatched operation)	21
5.8 Operation of releases	21
5.9 Low- and high-pressure interlocking and monitoring devices.....	21
5.10 Nameplates	21
5.11 Interlocking devices	23
5.12 Position indication	23
5.13 Degrees of protection by enclosures	24
5.14 Creepage distances for outdoor insulators	24
5.15 Gas and vacuum tightness.....	24
5.16 Liquid tightness	24
5.17 Fire hazard (flammability)	24
5.18 Electromagnetic compatibility (EMC)	24
5.19 X-ray emission.....	24
5.20 Corrosion.....	24
5.101 Internal arc fault	25
5.102 Enclosure	25
5.103 High-voltage compartments	27

5.104	Removable parts	30
5.105	Provisions for dielectric tests on cables	30
6	Type tests	31
6.1	General	31
6.2	Dielectric tests	32
6.3	Radio interference voltage (r.i.v.) test	35
6.4	Measurement of the resistance of circuits	35
6.5	Temperature-rise tests	36
6.6	Short-time withstand current and peak withstand current tests	37
6.7	Verification of the protection	38
6.8	Tightness tests	39
6.9	Electromagnetic compatibility tests (EMC)	39
6.10	Additional tests on auxiliary and control circuits	39
6.11	X-radiation test procedures for vacuum interrupters	40
6.101	Verification of making and breaking capacities	40
6.102	Mechanical operation tests	41
6.103	Pressure withstand test for gas-filled compartments	42
6.104	Tests to verify the protection of persons against dangerous electrical effects	43
6.105	Weatherproofing test	44
6.106	Internal arc test	44
7	Routine tests	47
7.1	Dielectric test on the main circuit	48
7.2	Tests on auxiliary and control circuits	48
7.3	Measurement of the resistance of the main circuit	48
7.4	Tightness test	48
7.5	Design and visual checks	48
7.101	Partial discharge measurement	48
7.102	Mechanical operation tests	49
7.103	Pressure tests of gas-filled compartments	49
7.104	Tests of auxiliary electrical, pneumatic and hydraulic devices	49
7.105	Tests after erection on site	49
7.106	Measurement of fluid condition after filling on site	50
8	Guide to the selection of switchgear and controlgear	50
8.101	General	50
8.102	Selection of rated values	50
8.103	Selection of design and construction	50
8.104	Internal arc fault	55
8.105	Summary of technical requirements, ratings and optional tests	59
8.106	Ratings of earthing circuits	61
8.107	Ratings for cable testing	61
9	Information to be given with enquiries, tenders and orders	61
9.1	Information with enquiries and orders	61
9.2	Information with tenders	62
10	Transport, storage, installation, operation and maintenance	63
10.1	Conditions during transport, storage and installation	63
10.2	Installation	63
10.3	Operation	63

10.4 Maintenance.....	63
11 Safety.....	63
11.101 Procedures.....	64
11.102 Internal arc aspects.....	64
12 Influence of the product on the environment	64
Annex AA (normative) Internal arc fault – Method to verify the internal arc classification (IAC).....	65
Annex BB (normative) Partial discharge measurement.....	80
Annex CC (informative) Regional deviations	86
Bibliography.....	87
Figure 101 – LSC1.....	54
Figure 102 – LSC2.....	54
Figure 103 – LSC2.....	54
Figure 104 – LSC2A	54
Figure 105 – LSC2B	54
Figure 106 – LSC2B	54
Figure AA.1 – Mounting frame for vertical indicators	73
Figure AA.2 – Horizontal indicator.....	73
Figure AA.3 – Position of the indicators	74
Figure AA.4 – Room simulation and indicator positioning for accessibility A, classified rear side, functional unit of any height	75
Figure AA.5 – Room simulation and indicator positioning for accessibility B, classified rear side, functional unit greater than or equal to 1 900 mm high	76
Figure AA.6 – Room simulation and indicator positioning for accessibility B, classified rear side, functional unit less than 1 900 mm high.....	77
Figure AA.7 – Test arrangement for overhead connected pole-mounted switchgear and controlgear.....	78
Figure AA.8 – Ceiling height stated from the floor or false floor level where the switchgear is actually placed	79
Figure BB.1 – Partial discharge test circuit (three-phase arrangement).....	84
Figure BB.2 – Partial-discharge test circuit (system without earthed neutral)	85
Table 101 – Nameplate information	21
Table 102 – Locations, causes and examples of measures to decrease the probability of internal arc faults	56
Table 103 – Single phase-to-earth arc fault current depending on the network neutral earthing	58
Table 104 – Summary of technical requirements, ratings and optional tests for metal-enclosed switchgear	59
Table AA.1 – Parameters for internal fault test according to compartment construction.....	72
Table BB.1 – Test circuits and procedures.....	83

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 200: AC metal-enclosed switchgear and controlgear
for rated voltages above 1 kV and up to and including 52 kV**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-200 has been prepared by subcommittee 17C: High-voltage switchgear and controlgear assemblies, of IEC technical committee 17: Switchgear and controlgear.

This second edition cancels and replaces the first edition, published in 2003. It is a technical revision.

This second edition of IEC 62271-200 has been further updated and improved to the experience gained with the first edition of IEC 62271-200. As maintenance result, this second edition of IEC 62271-200 introduces the following significant changes:

- definitions, classifications and testing procedures are specified more precisely;
- categories LSC2A and LSC2B have been clarified and LSC2 has been assigned a separate definition;
- specific ratings related to fault level to earth (4.5 to 4.7) are introduced;

- solid insulated high-voltage parts are no longer considered as compartments on their own;
- an optional rating "cable test voltage" and the associated requirements and type tests are introduced;
- for testing the internal arc classification, when assigned by the manufacturer, more specific guidance is provided regarding the test arrangement, room simulation and arc initiation;
- a single phase to earth ignition is also recognised for internal arc testing;
- the Annexes A and B are renumbered Annexes AA and BB.

The level of severity of internal arc testing is maintained without changes.

The text of this standard is based on the following documents:

FDIS	Report on voting
17C/523/FDIS	17C/534/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This International Standard should be read in conjunction with IEC 62271-1:2007, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1. Amendments to these clauses and subclauses are given under the same numbering, whilst additional subclauses, are numbered from 101.

A list of all parts of the IEC 62271 series can be found under the general title *High-voltage switchgear and controlgear*, on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

1 General

1.1 Scope

This part of IEC 62271 specifies requirements for prefabricated metal-enclosed switchgear and controlgear for alternating current of rated voltages above 1 kV and up to and including 52 kV for indoor and outdoor installation, and for service frequencies up to and including 60 Hz. Enclosures may include fixed and removable components and may be filled with fluid (liquid or gas) to provide insulation.

NOTE 1 For the use of this document high-voltage (IEC 60050-601:1985, 601-01-27) is the rated voltage above 1 000 V. However, medium voltage (IEC 60050-601:1985, 601-01-28) is commonly used for distribution systems with voltages above 1 kV and generally applied up to and including 52 kV; refer to [1] of Bibliography

NOTE 2 Although primarily dedicated to three-phase systems, this standard can also be applied to single-phase or two-phase systems.

This standard defines several categories of metal enclosed switchgear and controlgear which differ due to

- the consequences on network service continuity in case of maintenance on the switchgear and controlgear;
- the need and convenience of maintenance of the equipment.

NOTE 3 Safety of an installation results from the design, implementation and coordination of products, installations and operations.

For metal-enclosed switchgear and controlgear containing gas-filled compartments, the design pressure is limited to a maximum of 300 kPa (relative pressure).

NOTE 4 Gas-filled compartments having a design pressure exceeding 300 kPa (relative pressure) should be designed and tested in accordance with IEC 62271-203; refer to [6] of Bibliography.

Metal-enclosed switchgear and controlgear for special use, for example, in flammable atmospheres, in mines or on board ships, may be subject to additional requirements.

Components contained in metal-enclosed switchgear and controlgear are to be designed and tested in accordance with their various relevant standards. This standard supplements the standards for the individual components regarding their installation in switchgear and controlgear assemblies.

This standard does not preclude that other equipment may be included in the same enclosure. In such a case, any possible influence of that equipment on the switchgear and controlgear is to be taken into account.

NOTE 5 Switchgear and controlgear assemblies having an insulation enclosure are covered by IEC 62271-201.

NOTE 6 Metal-enclosed switchgear and controlgear for rated voltages above 52 kV insulated by ambient air may be covered by this standard taking into account the insulation levels of IEC 62271-1.