

SLOVENSKI STANDARD

SIST EN 61784-3-14:2010

01-oktober-2010

Industrijska komunikacijska omrežja - Profili - 3-14. del: Funkcijska varnost procesnih vodil - Dodatne specifikacije za CPF 14 (IEC 61784-3-14:2010)

Industrial communication networks - Profiles - Part 3-14: Functional safety fieldbuses - Additional specifications for CPF 14 (IEC 61784-3-14:2010)

Industrielle Kommunikationsnetze - Profile - Teil 3-14: Funktional sichere Übertragung bei Feldbussen - Zusätzliche Festlegungen für die Kommunikationsprofilfamilie 14 (IEC 61784-3-14:2010)

High STANDARD PREVIEW

(standards.iteh.ai)

Réseaux de communication industriels - Partie 3-14: Bus de terrain à sécurité fonctionnelle - Spécifications complémentaires pour le CPF 14 (CEI 61784-3-14:2010)

SIST EN 61784-3-14:2010
<https://standards.iteh.ai/catalog/standards/sist-en-61784-3-14-2010>

Ta slovenski standard je istoveten z: EN 61784-3-14:2010

ICS:

25.040.40	Merjenje in krmiljenje industrijskih postopkov	Industrial process measurement and control
35.100.05	Večslojne uporabniške rešitve	Multilayer applications

SIST EN 61784-3-14:2010

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 61784-3-14:2010](#)
<https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-f6cce7dcc9d9/sist-en-61784-3-14-2010>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 61784-3-14

August 2010

ICS 25.404.40; 35.100.05

English version

**Industrial communication networks -
Profiles -
Part 3-14: Functional safety fieldbuses -
Additional specifications for CPF 14
(IEC 61784-3-14:2010)**

Réseaux de communication industriels -
Partie 3-14: Bus de terrain à sécurité
fonctionnelle -
Spécifications complémentaires
pour le CPF 14
(CEI 61784-3-14:2010)

Industrielle Kommunikationsnetze -
Profile -
Teil 3-14: Funktional sichere Übertragung
bei Feldbussen -
Zusätzliche Festlegungen
für die Kommunikationsprofilfamilie 14
(IEC 61784-3-14:2010)

**ITEH STANDARD PREVIEW
(standards.iteh.ai)**

[SIST EN 61784-3-14:2010](https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-)

<https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1->

This European Standard was approved by CENELEC on 2010-07-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 65C/591A/FDIS, future edition 1 of IEC 61784-3-14, prepared by SC 65C, Industrial networks, of IEC TC 65, Industrial-process measurement, control and automation, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61784-3-14 on 2010-07-01.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2011-04-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2013-07-01

Annex ZA has been added by CENELEC.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 61784-3-14:2010](https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-f6cce7dcc9d9/sist-en-61784-3-14-2010)
<https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-f6cce7dcc9d9/sist-en-61784-3-14-2010>

Endorsement notice

The text of the International Standard IEC 61784-3-14:2010 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60204-1	NOTE Harmonized as EN 60204-1.
IEC 61131-2	NOTE Harmonized as EN 61131-2.
IEC 61158-2	NOTE Harmonized as EN 61158-2.
IEC 61326-3-1	NOTE Harmonized as EN 61326-3-1.
IEC 61326-3-2	NOTE Harmonized as EN 61326-3-2.
IEC 61496 series	NOTE Harmonized in EN 61496 series (partially modified).
IEC 61508-1:2010	NOTE Harmonized as EN 61508-1:2010 (not modified).
IEC 61508-4:2010	NOTE Harmonized as EN 61508-4:2010 (not modified).
IEC 61508-5:2010	NOTE Harmonized as EN 61508-5:2010 (not modified).
IEC 61508-6:2010	NOTE Harmonized as EN 61508-6:2010 (not modified).
IEC 61784-1	NOTE Harmonized as EN 61784-1.
IEC 61784-5 series	NOTE Harmonized in EN 61784-5 series (not modified).
IEC 61800-5-2	NOTE Harmonized as EN 61800-5-2.
IEC 61918	NOTE Harmonized as EN 61918.
IEC 62061	NOTE Harmonized as EN 62061-3-14:2010
ISO 10218-1	NOTE Harmonized as EN ISO 10218-1. https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-fbcce7dcc9d9/sist-en-61784-3-14-2010
ISO 12100-1	NOTE Harmonized as EN ISO 12100-1.
ISO 13849-1	NOTE Harmonized as EN ISO 13849-1.
ISO 13849-2	NOTE Harmonized as EN ISO 13849-2.

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158	Series	Industrial communication networks - Fieldbus specifications	EN 61158	Series
IEC 61158-3-14	-	Industrial communication networks - Fieldbus specifications - Part 3-14: Data-link layer service definition - Type 14 elements	EN 61158-3-14	-
IEC 61158-4-14	-	Industrial communication networks - Fieldbus specifications - Part 4-14: Data-link layer protocol specification - Type 14 elements	EN 61158-4-14	-
IEC 61158-5-14	-	Industrial communication networks - Fieldbus specifications - Part 5-14: Application layer service definition - Type 14 elements	EN 61158-5-14	-
IEC 61158-6-14	-	Industrial communication networks - Fieldbus specifications - Part 6-14: Application layer protocol specification - Type 14 elements	EN 61158-6-14	-
IEC 61508	Series	Functional safety of electrical/electronic/programmable electronic safety-related systems	EN 61508	Series
IEC 61511	Series	Functional safety - Safety instrumented systems for the process industry sector	EN 61511	Series
IEC 61588	-	Precision clock synchronization protocol for networked measurement and control systems	-	-
IEC 61784-2	-	Industrial communication networks - Profiles - EN 61784-2 Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC 8802-3	EN 61784-2	-
IEC 61784-3	2010	Industrial communication networks - Profiles - EN 61784-3 Part 3: Functional safety fieldbuses - General rules and profile definitions	EN 61784-3	2010
ISO/IEC 8802-3	-	Information technology - Telecommunications - and information exchange between systems - Local and metropolitan area networks - Specific requirements - Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications	-	-



INTERNATIONAL STANDARD



Industrial communication networks – Profiles –
Part 3-14: Functional safety fieldbuses – Additional specifications for CPF 14
([standards.iteh.ai](https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-f6cce7dcc9d9/sist-en-61784-3-14-2010))

[SIST EN 61784-3-14:2010](https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-f6cce7dcc9d9/sist-en-61784-3-14-2010)
<https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-f6cce7dcc9d9/sist-en-61784-3-14-2010>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE **XB**

ICS 25.040.40; 35.100.05

ISBN 978-2-88910-983-8

CONTENTS

FOREWORD	6
0 Introduction	8
0.1 General	8
0.2 Patent declaration	10
1 Scope	11
2 Normative references	11
3 Terms, definitions, symbols, abbreviated terms and conventions	12
3.1 Terms and definitions	12
3.1.1 Common terms and definitions	12
3.1.2 CPF 14: Additional terms and definitions	16
3.2 Symbols and abbreviated terms	16
3.2.1 Common symbols and abbreviated terms	16
3.2.2 CPF 14: Additional symbols and abbreviated terms	17
3.3 Conventions	17
4 Overview of FSCP 14/1 (EPASafety®)	18
4.1 EPASafety®	18
4.2 Principle of EPA safety communications	18
4.3 Safety function processing	19
5 General	19
5.1 External documents providing specifications for the profile	19
5.2 Safety functional requirements	20
5.3 Safety measures	20
5.4 Safety communication layer structure	21
5.4.1 Combination of standard communication and safety communication systems	21
5.4.2 CP 14/1 safety communication structure	22
5.5 Relationships with FAL (and DLL, PhL)	23
5.5.1 Overview	23
5.5.2 Data types	23
6 Safety communication layer services	24
6.1 Overview	24
6.2 FSCP 14/1 object extensions	24
6.2.1 General	24
6.2.2 Functional safety communication management object	25
6.2.3 Functional Safety Link Object	26
6.2.4 Functional safety communication alert object	29
6.3 Extended services	30
6.3.1 General	30
6.3.2 SafetyCommunicationOpen	31
6.3.3 SafetyCommunicationClose	32
7 Safety communication layer protocol	34
7.1 Safety PDU format	34
7.1.1 General	34
7.1.2 APDU header structure	34
7.1.3 Functional safety PDU	34
7.2 Safety communication operation	36

7.2.1	Sequence number	36
7.2.2	RelationKey.....	36
7.2.3	Feedback message	37
7.2.4	CRC-cross-check	37
7.2.5	Scheduling number.....	38
7.2.6	Time stamp	39
7.2.7	Time expectation	39
7.2.8	Time synchronization monitoring	39
7.2.9	Communication scheduling precision monitoring.....	39
7.3	Safety communication behaviour	39
7.3.1	Protocol state description of periodic data transmission.....	39
7.3.2	Protocol state description of non-periodic data transmission.....	41
7.3.3	Protocol state description of alert report for communication fault	46
7.3.4	Function description	49
7.4	Code	51
7.4.1	Object code	51
7.4.2	Service code	53
8	Safety communication layer management.....	59
8.1	Time synchronization diagnostics	59
8.1.1	Time synchronization process.....	59
8.1.2	Time synchronization management.....	60
8.2	CSME diagnostics	60
8.2.1	General	60
8.2.2	CSME diagnostics management.....	60
8.3	Communication fault management.....	61
8.3.1	Configuration management.....	61
8.3.2	Communication fault report process.....	61
9	System requirements.....	64
9.1	Indicators and switches	64
9.2	Installation guidelines.....	64
9.3	Safety function response time	64
9.3.1	General	64
9.3.2	Calculation of the network reaction time	65
9.4	Duration of demands	66
9.5	Constraints for calculation of system characteristics.....	66
9.6	Maintenance.....	67
9.7	Safety manual	67
10	Assessment.....	67
Annex A (informative)	Additional information for functional safety communication profiles of CPF 14	68
A.1	Hash function calculation.....	68
A.2	69
Annex B (informative)	Information for assessment of the functional safety communication profiles of CPF 14	70
Bibliography.....		71
Table 1 – Relationships between errors and safety measures		21
Table 2 – Data types used within FSCP 14/1		24

Table 3 – FSCP 14/1 object extensions	24
Table 4 – Functional safety service extension	31
Table 5 – SafetyCommunicationOpen Service Parameters	31
Table 6 – SafetyCommunicationClose Service Parameters	33
Table 7 – Encoding of APDU Header	34
Table 8 – Structure of Functional Safety PDU (FSPDU) Header	35
Table 9 – CRC calculation polynomials	37
Table 10 – Functional safety communication state description	40
Table 11 – States and transitions of periodic data transmission	40
Table 12 – Functional safety communication states description	42
Table 13 – States and transitions of non-periodic data transmission	42
Table 14 – Communication alert state description	47
Table 15 – Communication alert states and transitions	47
Table 16 – LinkObjectType function description	49
Table 17 – CRCCheck function description	49
Table 18 – CrossCheck function description	50
Table 19 – TimeDelayCheck function description	50
Table 20 – PeriodUncomfrimedSNCheck function description	50
Table 21 – Non-periodicSNCheck function description	50
Table 22 – Functional safety communication management object encoding	51
Table 23 – Functional safety link object encoding	51
Table 24 – Functional safety communication alert object encoding	53
Table 25 – Encoding of SafetyCommunicationOpen request parameters	56
Table 26 – SafetyCommunicationOpen positive response parameters	56
Table 27 – SafetyCommunicationOpen negative response parameters	57
Table 28 – SafeCommunicationClose request parameters	57
Table 29 – SafeCommunicationClose positive response parameters	57
Table 30 – SafeCommunicationClose negative response parameters	57
Table 31 – Error class and code	58
Table 32 – Communication process of confirmed service between two devices	61
Table 33 – Settings for time expectation margin	65
Table 34 – Constraints for system characteristics at $\varepsilon = 10^{-2}$	67
 Figure 1 – Relationships of IEC 61784-3 with other standards (machinery)	8
Figure 2 – Relationships of IEC 61784-3 with other standards (process)	9
Figure 3 – Safety communication architecture	19
Figure 4 – Safety function processing	19
Figure 5 – Standard communication and safety communication	22
Figure 6 – CP 14/1 protocol hierarchy	23
Figure 7 – Relationship between the SCL and the other layers of CP 14/1	23
Figure 8 – Functional safety communication message structure	34
Figure 9 – Structure of Functional Safety PDU (FSPDU)	35
Figure 10 – Structure of Virtual Safety Check Message (VSCM)	35

Figure 11 – FSPDU mapping	36
Figure 12 – Time-sharing communication scheduling	38
Figure 13 – Format of EndofNonPeriodicDataSending PDU	39
Figure 14 – State transfer figure of periodic data transmission.....	40
Figure 15 – Functional safety communication state transfer	41
Figure 16 – Communication alert report state transfer figure.....	46
Figure 17 – CRC check for time synchronization process.....	59
Figure 18 – The process of communication fault report	63
Figure 19 – Example application for FSCP 14/1 communication.....	64
Figure 20 – Calculation of the network reaction time	65

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 61784-3-14:2010](https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-f6cce7dcc9d9/sist-en-61784-3-14-2010)
<https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-f6cce7dcc9d9/sist-en-61784-3-14-2010>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INDUSTRIAL COMMUNICATION NETWORKS –
PROFILES –Part 3-14: Functional safety fieldbuses –
Additional specifications for CPF 14

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

International Standard IEC 61784-3-14 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial process measurement, control and automation.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/591A/FDIS	65C/603/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61784-3 series, published under the general title *Industrial communication networks – Profiles – Functional safety fieldbuses*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 61784-3-14:2010](https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-f6cce7dcc9d9/sist-en-61784-3-14-2010)
<https://standards.iteh.ai/catalog/standards/sist/daa44f77-3338-4487-85d1-f6cce7dcc9d9/sist-en-61784-3-14-2010>


0 Introduction

0.1 General

The IEC 61158 fieldbus standard together with its companion standards IEC 61784-1 and IEC 61784-2 defines a set of communication protocols that enable distributed control of automation applications. Fieldbus technology is now considered well accepted and well proven. Thus many fieldbus enhancements are emerging, addressing not yet standardized areas such as real time, safety-related and security-related applications.

This standard explains the relevant principles for functional safety communications with reference to IEC 61508 series and specifies several safety communication layers (profiles and corresponding protocols) based on the communication profiles and protocol layers of IEC 61784-1, IEC 61784-2 and the IEC 61158 series. It does not cover electrical safety and intrinsic safety aspects.


Figure 1 shows the relationships between this standard and relevant safety and fieldbus standards in a machinery environment.



NOTE Subclauses 6.7.6.4 (high complexity) and 6.7.8.1.6 (low complexity) of IEC 62061 specify the relationship between PL (Category) and SIL.

Figure 1 – Relationships of IEC 61784-3 with other standards (machinery)

Figure 2 shows the relationships between this standard and relevant safety and fieldbus standards in a process environment.



^a For specified electromagnetic environments; otherwise IEC 61326-3-1.

^b EN ratified.

Figure 2 – Relationships of IEC 61784-3 with other standards (process)

Safety communication layers which are implemented as parts of safety-related systems according to IEC 61508 series provide the necessary confidence in the transportation of messages (information) between two or more participants on a fieldbus in a safety-related system, or sufficient confidence of safe behaviour in the event of fieldbus errors or failures.

Safety communication layers specified in this standard do this in such a way that a fieldbus can be used for applications requiring functional safety up to the Safety Integrity Level (SIL) specified by its corresponding functional safety communication profile.

The resulting SIL claim of a system depends on the implementation of the selected functional safety communication profile within this system – implementation of a functional safety communication profile in a standard device is not sufficient to qualify it as a safety device.