

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Industrial communication networks – Fieldbus specifications –
Part 5-26: Application layer service definition – Type 26 elements

Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-26: Définition des services de la couche application – Éléments
de type 26



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC online collection - oc.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 5-26: Application layer service definition – Type 26 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-26: Définition des services de la couche application – Éléments
de type 26**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-9172-6

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
1.1 Overview	8
1.2 Specifications	9
1.3 Conformance	9
2 Normative references	9
3 Terms, definitions, symbols, abbreviations and conventions	10
3.1 Terms and definitions from other ISO/IEC standards.....	11
3.1.1 Terms and definitions from ISO/IEC 7498-1	11
3.1.2 Terms and definitions from ISO/IEC 8822	11
3.1.3 Terms and definitions from ISO/IEC 9545	11
3.1.4 Terms and definitions from ISO/IEC 8824-1	11
3.2 Fieldbus application layer Type 26-specific definitions	12
3.3 Abbreviations and symbols	18
3.4 Conventions.....	20
3.4.1 Overview	20
3.4.2 General conventions.....	20
3.4.3 Conventions for class definitions	20
3.4.4 Conventions for service definitions	21
4 Concepts	22
5 Data type ASE.....	23
5.1 Overview.....	23
5.2 Formal definition of data type objects.....	23
5.2.1 Data type class definitions	23
5.2.2 Attributes	24
5.3 FAL defined data types	25
5.3.1 Fixed length types	25
5.3.2 String types	29
5.4 Data type ASE service specification.....	30
6 Communication model specification	30
6.1 General.....	30
6.2 Protocol stack for Type 26 fieldbus	30
6.3 Overview of Type 26 communication model	31
6.4 Cyclic data communication service with Common-memory	32
6.4.1 Overview	32
6.4.2 Common-memory: allocation to each node.....	32
6.4.3 Data sharing among nodes with the CM.....	33
6.4.4 CM data type	35
6.5 ASEs	35
6.5.1 Overview of Type 26 ASEs	35
6.5.2 Type 26 specific conventions for FAL service common parameters	36
6.5.3 Cyclic-data ASE.....	37
6.5.4 Message data ASE	42
6.5.5 Communication load measurement ASE	69
6.5.6 Network management ASE	74

6.5.7	General purpose command server ASE	87
6.5.8	AR ASE	90
6.5.9	FAL ASE summary	101
Bibliography.....		104
Figure 1	– Protocol stack for Type 26 fieldbus	31
Figure 2	– Unconfirmed Push-Publisher/Subscriber type interaction	32
Figure 3	– Unconfirmed/Confirmed Client/Server type interaction	32
Figure 4	– Common memory allocation	33
Figure 5	– Data sharing with the CM	34
Figure 6	– Node #01 for reception only	34
Figure 7	– Node #01 without the CM	35
Figure 8	– The structure of ASEs for Type 26 FAL	36
Figure 9	– Virtual-address-space for Byte block	45
Figure 10	– Virtual-address-space for Word block	48
Figure 11	– AR ASE internal architecture	91
Figure 12	– Structure of IP address	99
Table 1	– Write service parameters.....	39
Table 2	– Send-CM service parameters	40
Table 3	– Read service parameters.....	40
Table 4	– Update memory service parameters.....	41
Table 5	– Get- buffer service parameters.....	42
Table 6	– Byte block read service parameters.....	46
Table 7	– Byte block write service parameters	47
Table 8	– Word block read service parameters	48
Table 9	– Word block write service parameters	49
Table 10	– Network parameter read service parameters	50
Table 11	– Network parameter write service parameters	51
Table 12	– Stop command service parameters.....	52
Table 13	– Operation command service parameters.....	53
Table 14	– profile read service parameters	53
Table 15	– Transparent message service parameters	56
Table 16	– Log data read service parameters	57
Table 17	– Log data items.....	57
Table 18	– Log data clear service parameters.....	61
Table 19	– Message return service parameters.....	62
Table 20	– Vendor specific message service parameters	63
Table 21	– Set remote node configuration parameter service parameters	64
Table 22	– Data elements and Node configuration parameters.....	64
Table 23	– Service parameters of Read remote participating node management information parameter service.....	65
Table 24	– Participating node management information parameters.....	66
Table 25	– Read remote node management information parameter service parameters	67

Table 26 – Node management information parameters	67
Table 27 – Read remote node setting information parameter service parameters.....	68
Table 28 –Node setting information parameters	69
Table 29 – Start TK-holding-time measurement service parameters.....	71
Table 30 – Terminate TK-holding-time measurement service parameters.....	71
Table 31 – Token-holding-time measurement result	72
Table 32 – Start GP_Comm sender log service parameters	73
Table 33 – Terminate GP_Comm sender log service parameters	73
Table 34 – GP_Comm sender log measurement result.....	74
Table 35 – Service parameters for Set configuration parameter	77
Table 36 – Configuration parameters	78
Table 37 – Read node management information parameter service parameters	78
Table 38 – Node management information parameters	79
Table 39 – Service parameters for Read participating node mgt. information parameter	80
Table 40 – Participating node management information parameters.....	80
Table 41 – Service parameters for Read network management information parameter.....	81
Table 42 – Network management information parameters	81
Table 43 – Service parameters for Read message sequence number management information.....	82
Table 44 – Read message sequence number management information parameters	82
Table 45 –Read node status service parameters.....	83
Table 46 – Read node status parameters.....	83
Table 47 – Upper layer operating condition matrix	84
Table 48 –Reset node service parameters	84
Table 49 – Set network address service parameters	85
Table 50 – Register service parameters.....	85
Table 51 – Event service parameters	86
Table 52 – Activate/Deactivate measurement service parameters	86
Table 53 – Get log data service parameters.....	87
Table 54 – Send command service parameters.....	90
Table 55 – CT send service parameters.....	93
Table 56 – MT send service parameters	95
Table 57 – CS send service parameters.....	96
Table 58 – Notify state change service parameters	97
Table 59 – Control measurement service parameters.....	97
Table 60 – DLSAP assignments.....	99
Table 61 – DLS Primitives and parameters	100
Table 62 – Lower layer T-profile and the required standards.....	101
Table 63 – Summary of FAL ASEs	101

ITeh STANDARD PREVIEW

(standards.iteh.ai)

IEC 61158-5-26:2019

[https://standards.iteh.ai/catalog/standards/sist/7448e7ed-0d43-4247-a282-](https://standards.iteh.ai/catalog/standards/sist/7448e7ed-0d43-4247-a282-15f2e1aad3e3/iec-61158-5-26-2019)

[15f2e1aad3e3/iec-61158-5-26-2019](https://standards.iteh.ai/catalog/standards/sist/7448e7ed-0d43-4247-a282-15f2e1aad3e3/iec-61158-5-26-2019)

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INDUSTRIAL COMMUNICATION NETWORKS –
 FIELDBUS SPECIFICATIONS –

**Part 5-26: Application layer service definition –
 Type 26 elements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61158-5-26 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement and control.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/947/FDIS	65C/950/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[IEC 61158-5-26:2019](#)

<https://standards.iteh.ai/catalog/standards/sist/7448e7ed-0d43-4247-a282-15f2e1aad3e3/iec-61158-5-26-2019>

INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This document defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this document is a conceptual architectural service, independent of administrative and implementation divisions.

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[IEC 61158-5-26:2019](https://standards.iteh.ai/catalog/standards/sist/7448e7ed-0d43-4247-a282-15f2e1aad3e3/iec-61158-5-26-2019)

<https://standards.iteh.ai/catalog/standards/sist/7448e7ed-0d43-4247-a282-15f2e1aad3e3/iec-61158-5-26-2019>

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-26: Application layer service definition – Type 26 elements

1 Scope

1.1 Overview

The Fieldbus Application Layer (FAL) provides user programs with a means to access the Fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 26 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This International Standard defines in an abstract way the externally visible service provided by the different Types of fieldbus Application Layer in terms of

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service;
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this document is to define the services provided to

- a) the FAL user at the boundary between the user and the Application Layer of the Fieldbus Reference Model, and
- b) Systems Management at the boundary between the Application Layer and Systems Management of the Fieldbus Reference Model.

This document specifies the structure and services of the IEC Fieldbus Application Layer, in conformance with the OSI Basic Reference Model (see ISO/IEC 7498-1) and the OSI Application Layer Structure (see ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can

send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this document to provide access to the FAL to control certain aspects of its operation.

1.2 Specifications

The principal objective of this document is to specify the characteristics of conceptual application layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of application layer protocols for time-critical communications.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of services standardized as the various Types of IEC 61158, and the corresponding protocols standardized in subparts of IEC 61158-6.

This specification may be used as the basis for formal Application Programming-Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This document does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to this application layer service definition standard. Instead, conformance is achieved through implementation of conforming application layer protocols that fulfill any given Type of application layer services as defined in this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as IEC 61784-1 and IEC 61784-2, are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61131-3, *Programmable controllers – Part 3: Programming languages*

IEC 61158-1:2019, *Industrial communication networks – Fieldbus specifications – Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series*

IEC 61158-6-26:2019, *Industrial communication networks – Fieldbus specifications – Part 6-26: Application layer protocol specification – Type 26 elements*

IEC 61784-2:2019, *Industrial communication networks – Profiles – Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC/IEEE 8802-3*

ISO/IEC 646, *Information technology – ISO 7-bit coded character set for information interchange*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model – Part 1: The Basic Model*

ISO/IEC/IEEE 8802-3, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Standard for Ethernet*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824-1, *Information Technology – Abstract Syntax notation One (ASN-1): Specification of basic notation*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 10646, *Information technology – Universal Coded Character Set (UCS)*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC 60559, *Information technology – Microprocessor Systems – Floating-Point arithmetic*

IETF RFC 768, *User Datagram Protocol*, available at <http://www.ietf.org> [viewed 2018-09-20]

IETF RFC 791, *Internet Protocol*, available at <http://www.ietf.org> [viewed 2018-09-20]

IETF RFC 792, *Internet Control Message Protocol*, available at <http://www.ietf.org> [viewed 2018-09-20]

IETF RFC 793, *Transmission Control Protocol*, available at <http://www.ietf.org> [viewed 2018-09-20]

IETF RFC 796, *Address mappings*, available at <http://www.ietf.org> [viewed 2018-09-20]

IETF RFC 826, *An Ethernet Address Resolution Protocol*, available at <http://www.ietf.org> [viewed 2018-09-20]

IETF RFC 894, *A Standard for the Transmission of IP Datagrams over Ethernet Networks*, available at <http://www.ietf.org> [viewed 2018-09-20]

IETF RFC 919, *Broadcasting Internet Datagrams*, available at <http://www.ietf.org> [viewed 2018-09-20]

IETF RFC 922, *Broadcasting Internet Datagrams in the presence of subnets*, available at <http://www.ietf.org> [viewed 2018-09-20]

IETF RFC 950, *Internet Standard Subnetting Procedure*, available at <http://www.ietf.org> [viewed 2018-09-20]

3 Terms, definitions, symbols, abbreviations and conventions

For the purposes of this document, the following terms, definitions, symbols, abbreviations and conventions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 Terms and definitions from other ISO/IEC standards

3.1.1 Terms and definitions from ISO/IEC 7498-1

For the purposes of this document, the following terms and definitions given in ISO/IEC 7498-1 apply.

- a) application entity
- b) application process
- c) application protocol data unit
- d) application service element
- e) application entity invocation
- f) application process invocation
- g) application transaction
- h) real open system
- i) transfer syntax

3.1.2 Terms and definitions from ISO/IEC 8822

For the purposes of this document, the following terms and definitions given in ISO/IEC 8822 apply.

- a) abstract syntax <https://standards.iteh.ai/catalog/standards/sist/7448e7ed-0d43-4247-a282-15f2e1aad3e3/iec-61158-5-26-2019>
- b) presentation context

3.1.3 Terms and definitions from ISO/IEC 9545

For the purposes of this document, the following terms and definitions given in ISO/IEC 9545 apply.

- a) application-association
- b) application-context
- c) application context name
- d) application-entity-invocation
- e) application-entity-type
- f) application-process-invocation
- g) application-process-type
- h) application-service-element
- i) application control service element

3.1.4 Terms and definitions from ISO/IEC 8824-1

For the purposes of this document, the following terms and definitions given in ISO/IEC 8824-1 apply.

- a) object identifier
- b) type
- c) value

- d) simple type
- e) structured type
- f) tag
- g) Boolean type
- h) true
- i) false
- j) integer type
- k) bitstring type
- l) octetstring type

3.2 Fieldbus application layer Type 26-specific definitions

For the purposes of this document, the following terms and definitions apply.

3.2.1

application

function or data structure for which data is consumed or produced

3.2.2

application objects

multiple object classes that manage and provide a run time exchange of messages across the network and within the network device

3.2.3

application process object

component of an application process that is identifiable and accessible through an FAL application relationship

Note 1 to entry: Application process object definitions are composed of a set of values for the attributes of their class (see the definition for Application Process Object Class Definition). Application process objects can be accessed remotely using the services of the FAL Object Management ASE. FAL Object Management services can be used to load or update object definitions, to read object definitions, and to dynamically create and delete application objects and their corresponding definitions.

3.2.4

application process object class

class of application process objects defined in terms of the set of their network-accessible attributes and services

3.2.5

application relationship

cooperative association between two or more application-entity-invocations for the purpose of exchange of information and coordination of their joint operation

Note 1 to entry: This relationship is activated either by the exchange of application-protocol-data-units or as a result of preconfiguration activities.

3.2.6

application relationship ASE

ASE used for establishing and terminating application relationship

3.2.7

application relationship endpoint

context and behavior of an application relationship as seen and maintained by one of the application processes involved in the application relationship

Note 1 to entry: Each application process involved in the application relationship maintains its own application relationship endpoint.

3.2.8**attribute**

description of an externally visible characteristic or feature of an object

Note 1 to entry: The attributes of an object contain information about variable portions of an object. Typically, they provide status information or govern the operation of an object. Attributes may also affect the behavior of an object. Attributes are divided into class attributes and instance attributes.

3.2.9**behavior**

indication of how an object responds to particular events

3.2.10**channel**

single physical or logical link of an input or output application object of a server to the process

3.2.11**class**

set of objects, all of which represent the same kind of system component

Note 1 to entry: A class is a generalization of an object; a template for defining variables and methods. All objects in a class are identical in form and behavior, but usually contain different data in their attributes.

3.2.12**class attributes**

attribute that is shared by all objects within the same class

3.2.13**client**

<object view> object which uses the services of another (server) object to perform a task

3.2.14**client**

<communication view> initiator of a message to which a server reacts

3.2.15**common-memory**

virtual memory accessible with logically unique address used for the cyclic-data transmission

Note 1 to entry: It is composed of the memory-area-1 and -2 of the memory size 512 words and 8 192 words respectively and is shared with the Type 26 nodes in a Type 26 fieldbus network.

3.2.16**connection**

logical binding between application objects that are within the same or different devices

Note 1 to entry: Connections can be either point-to-point or multipoint.

3.2.17**consumer**

node or sink that is receiving data from a producer

3.2.18**control commands**

action invocations transferred from client to server to clear outputs, freeze inputs and/or synchronize outputs

3.2.19**cyclic**

repetitive in a regular manner