

---

**Industrijska komunikacijska omrežja - Avtomatizacijska omrežja z veliko razpoložljivostjo - 7. del: Protokol za redundanco na obročni osnovi (IEC 62439-7:2011)**

Industrial communication networks - High availability automation networks - Part 7: Ring-based Redundancy Protocol (RRP) (IEC 62439-7:2011)

Industrielle Kommunikationsnetze - Hochverfügbare Automatisierungsnetze - Teil 7: Protokoll für ringbasierte Redundanz (RRP) (IEC 62439-7:2011)

Réseaux de communication industriels - Réseau de haute disponibilité pour l'automation - Partie 7: Protocole de redondance pour réseau en anneau (RRP) (CEI 62439-7:2011)

**Ta slovenski standard je istoveten z: EN 62439-7:2012**

**ICS:**

25.040.01	Sistemi za avtomatizacijo v industriji na splošno	Industrial automation systems in general
35.110	Omreževanje	Networking

**SIST EN 62439-7:2012****en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 62439-7:2012

<https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-da075c33332a/sist-en-62439-7-2012>

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN 62439-7**

March 2012

ICS 25.040; 35.040

English version

**Industrial communication networks -  
High availability automation networks -  
Part 7: Ring-based Redundancy Protocol (RRP)  
(IEC 62439-7:2011)**

Réseaux de communication industriels -  
Réseau de haute disponibilité pour  
l'automatisation -  
Partie 7: Protocole de redondance pour  
réseau en anneau (RRP)  
(CEI 62439-7:2011)

Industrielle Kommunikationsnetze -  
Hochverfügbare Automatisierungsnetze -  
Teil 7: Protokoll für ringbasierte  
Redundanz (RRP)  
(IEC 62439-7:2011)

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

This European Standard was approved by CENELEC on 2012-01-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Management Centre: Avenue Marnix 17, B - 1000 Brussels**

## Foreword

The text of document 65C/668/FDIS, future edition 1 of IEC 62439-7, prepared by SC 65C, "Industrial networks", of IEC TC 65, "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62439-7:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-10-20
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2015-01-20

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

## Endorsement notice

The text of the International Standard IEC 62439-7:2011 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC 61158 series NOTE Harmonized in EN 61158 series.12

<https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-da075c33332a/sist-en-62439-7-2012>

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-191	-	International Electrotechnical Vocabulary (IEV) - Chapter 191: Dependability and quality of service	-	-
IEC 62439-1	2010	Industrial communication networks - High availability automation networks - Part 1: General concepts and calculation methods	EN 62439-1	2010
ISO/IEC 8802-3	2000	Information technology - Telecommunications - and information exchange between systems - Local and metropolitan area networks - Specific requirements - Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications		-

<https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-da075c33332a/sist-en-62439-7-2012>

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 62439-7:2012

<https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-da075c33332a/sist-en-62439-7-2012>



IEC 62439-7

Edition 1.0 2011-12

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Industrial communication networks – High availability automation networks –  
Part 7: Ring-based Redundancy Protocol (RRP)**

**Réseaux de communication industriels – Réseaux de haute disponibilité pour  
l'automation –** <https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-nc57c83309c4/iec-62439-7-2012>  
**Partie 7: Protocole de redondance pour réseau en anneau (RRP)**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE **XC**  
CODE PRIX

ICS 25.040; 35.040

ISBN 978-2-88912-838-9

## CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references.....	9
3 Terms, definitions, abbreviations, acronyms, and conventions.....	9
3.1 Terms and definitions.....	9
3.2 Abbreviations and acronyms.....	10
3.3 Conventions.....	10
4 RRP overview.....	11
4.1 General.....	11
4.2 Frame forwarding and receiving control.....	11
4.2.1 General.....	11
4.2.2 Normal Device (ND) and Gateway Device (GWD).....	11
4.2.3 Behaviours of the General Device (GD).....	12
4.2.4 Behaviours of the Line Network Manager (LNM).....	13
4.2.5 Behaviours of the Ring Network Managers (RNMs).....	13
4.3 Link status monitoring.....	14
4.4 Error detection.....	14
4.5 Plug and play.....	14
4.6 Network management information base (NMIB) management.....	14
4.7 Network recovery.....	15
4.8 Automatic network configuration.....	15
4.9 RRP basic operating principle.....	15
5 RRP redundancy behaviours.....	17
5.1 Network topology.....	17
5.2 Network recovery in ring network.....	18
5.2.1 General.....	18
5.2.2 Link fault between neighbouring devices.....	20
5.2.3 Link fault of remote device.....	21
5.2.4 Device fault on a RNM.....	22
5.3 Automatic Ring Network Manager (RNM) election procedure.....	23
5.3.1 General.....	23
5.3.2 Primary RNM (RNMP).....	23
5.3.3 Secondary RNM (RNMS).....	24
5.4 Path management.....	24
5.4.1 General.....	24
5.4.2 Path in a line topology network.....	24
5.4.3 Path in a ring topology network.....	25
5.5 Device address collision.....	26
6 RRP class specification.....	27
6.1 General.....	27
6.2 Template.....	27
6.3 Attributes.....	29
7 RRP services specification.....	34
7.1 Set device information.....	34
7.2 Get device information.....	36



7.3	Get network information .....	38
7.4	Get path table information .....	40
8	RRP protocol specification.....	42
8.1	General .....	42
8.2	Ethernet header .....	43
8.2.1	Preamble.....	43
8.2.2	Start frame delimiter .....	43
8.2.3	Destination MAC address .....	43
8.2.4	Source MAC address.....	43
8.2.5	Length/Type .....	43
8.3	Encoding of RRP_FrameHDR.....	43
8.3.1	Version and length .....	43
8.3.2	DST_addr.....	44
8.3.3	SRC_addr.....	45
8.3.4	Frame Control (FC) .....	45
8.4	Encoding of data and pad.....	47
8.4.1	General .....	47
8.4.2	Encoding of FamilyReq.....	47
8.4.3	Encoding of FamilyRes.....	48
8.4.4	Encoding of MediaLinked.....	48
8.4.5	Encoding of AdvThis.....	49
8.4.6	Encoding of LineStart.....	49
8.4.7	Encoding of RingStart.....	50
8.4.8	Encoding of AckRNMS.....	51
8.4.9	Encoding of CheckRNMS.....	52
8.5	Frame Check Sequence (FCS).....	52
9	RRP protocol machine.....	52
9.1	Protocol state machine description.....	52
9.2	Local parameters and variables for protocol state.....	54
9.2.1	General .....	54
9.2.2	Variables to support local device information management.....	54
9.2.3	Variables to support network information management.....	55
9.2.4	Variables to support device path information management.....	55
9.2.5	Variables of Received RRP Frame.....	55
9.2.6	Local variables for protocol state.....	56
9.2.7	Constants for protocol state.....	56
9.3	State transitions .....	57
9.4	Function descriptions .....	70
10	RRP Management Information Base (MIB) .....	75
	Bibliography.....	81
	Figure 1 – Forwarding and receiving Ethernet frames .....	11
	Figure 2 – Structures of ND and GWD .....	12
	Figure 3 – LNM forwarding control .....	13
	Figure 4 – RNM forwarding control.....	13
	Figure 5 – Link status information .....	14
	Figure 6 – A device operation in initialization phase.....	15

Figure 7 – Devices operation in line network establishing phase .....	16
Figure 8 – Extension of line network operation.....	16
Figure 9 – Ring network establishment operation.....	17
Figure 10 – Ring to line network change operation.....	17
Figure 11 – Ring topology.....	18
Figure 12 – Link fault between neighbouring devices .....	21
Figure 13 – Link fault of remote device .....	22
Figure 14 – Device fault on a RNM .....	22
Figure 15 – Path management in a line topology network.....	24
Figure 16 – Path management in a ring topology network .....	25
Figure 17 – RRP device address collision in a ring network .....	26
Figure 18 – Common MAC frame format for RRP DLPDU .....	43
Figure 19 – RRP protocol state machine .....	53
Table 1 – RRP network recovery parameter .....	19
Table 2 – Parameters for calculation.....	19
Table 3 – Path table of Device1 in a line topology network.....	24
Table 4 – Path table of Device4 in a line topology network.....	25
Table 5 – Path table of Device1 in a ring topology network.....	25
Table 6 – Path table of Device3 in a ring topology network.....	26
Table 7 – Device address collision information.....	27
Table 8 – Parameters of set device information service.....	34
Table 9 – Parameters of get device information service.....	36
Table 10 – Parameters of get network information service .....	38
Table 11 – Parameters of get path table information service .....	40
Table 12 – RRP Length/Type field .....	43
Table 13 – Version.....	44
Table 14 – DST_addr.....	44
Table 15 – SRC_addr .....	45
Table 16 – Network control message type.....	45
Table 17 – Type of service.....	45
Table 18 – Priority .....	46
Table 19 – Validation of extension code.....	46
Table 20 – Encoding of FamilyReq frame.....	47
Table 21 – Encoding of FamilyRes frame.....	48
Table 22 – Encoding of MediaLinked frame.....	48
Table 23 – Encoding of AdvThis frame.....	49
Table 24 – Encoding of LineStart frame .....	49
Table 25 – Encoding of RingStart frame.....	50
Table 26 – Encoding of AckRNMS frame .....	51
Table 27 – Encoding of CheckRNMS frame .....	52
Table 28 – Variables to support device information management.....	54
Table 29 – Variables to support managing network information.....	55

Table 30 – Variables to support device path information management .....	55
Table 31 – Variables of Received RRP Frame .....	55
Table 32 – Local variables for protocol state .....	56
Table 33 – Constants for protocol state .....	56
Table 34 – RRP State transitions .....	57
Table 35 – RRP Function descriptions .....	70

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 62439-7:2012](https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-da075c33332a/sist-en-62439-7-2012)

[https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-  
da075c33332a/sist-en-62439-7-2012](https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-da075c33332a/sist-en-62439-7-2012)

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –  
HIGH AVAILABILITY AUTOMATION NETWORKS –****Part 7: Ring-based Redundancy Protocol (RRP)**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62439-7 has been prepared by subcommittee 65C: Industrial Networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/668/FDIS	65C/673/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This International Standard is to be read in conjunction with IEC 62439-1:2010, *Industrial communication networks – High availability automation networks – Part 1: General concepts and calculation methods*.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts of the IEC 62439 series, under the general title *Industrial communication networks – High availability automation networks*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## **iTeh STANDARD PREVIEW** **(standards.iteh.ai)**

[SIST EN 62439-7:2012](https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-da075c33332a/sist-en-62439-7-2012)

<https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-da075c33332a/sist-en-62439-7-2012>

## INTRODUCTION

The IEC 62439 series specifies relevant principles for high availability networks that meet the requirements for industrial automation networks.

In the fault-free state of the network, the protocols of the IEC 62439 series provide ISO/IEC 8802-3:2000 (IEEE 802.3) with compatible, reliable data communications, and preserve determinism in real-time data communications. In cases of fault, removal, and insertion of a component, they provide deterministic recovery times.

These protocols retain fully the Ethernet communication capabilities typically used in the office world, to ensure that software that relies on these protocols will remain applicable.

The market is in need of several network solutions, each with different performance characteristics and functional capabilities, meeting diverse application requirements. These solutions support different redundancy topologies and mechanisms, which are introduced in IEC 62439-1 and specified in the companion International Standards. IEC 62439-1 also distinguishes between these different solutions, providing guidance for the user.

The IEC 62439 series follows the general structure and terms of IEC 61158 series.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of patents concerning IEC 61158-4-21 given in Clause 4 and Clause 5.

Patent Number KR 0789444 "COMMUNICATION PACKET PROCESSING APPARATUS AND METHOD FOR RING TOPOLOGY ETHERNET NETWORK CAPABLE OF PREVENTING PERMANENT PACKET LOOPING," owned by LS INDUSTRIAL SYSTEMS CO., LTD., Anyang, Korea

Patent Number KR 0732510 "NETWORK SYSTEM" owned by LS INDUSTRIAL SYSTEMS CO., LTD., Anyang, Korea  
<https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-da075c33332a/sist-en-62439-7-2012>

Patent Number KR 0870670 "Method For Determining a Ring Manager Node", owned by LS INDUSTRIAL SYSTEMS CO., LTD., Anyang, Korea

IEC takes no position concerning the evidence, validity and scope of these patent rights.

The holder of these patent rights has assured the IEC that he/she is willing to negotiate licences either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of these patent rights is registered with IEC. Information may be obtained from:

LSIS Co Ltd  
LS Tower  
1026-6, Hogye-Dong  
Dongan-Gu  
Anyang, Gyeonggi-Do, 431-848  
South Korea  
Phone +82 2 2034 4917  
Fax +82 2 2034 4648

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO ([www.iso.org/patents](http://www.iso.org/patents)) and IEC (<http://patents.iec.ch>) maintain on-line data bases of patents relevant to their standards. Users are encouraged to consult the data bases for the most up to date information concerning patents.

# INDUSTRIAL COMMUNICATION NETWORKS – HIGH AVAILABILITY AUTOMATION NETWORKS –

## Part 7: Ring-based Redundancy Protocol (RRP)

### 1 Scope

The IEC 62439 series of standards is applicable to high-availability automation networks based on the ISO/IEC 8802-3:2000 (Ethernet) technology.

This part of the IEC 62439 series specifies a redundancy protocol that is based on a ring topology, in which the redundancy protocol is executed at the end nodes, as opposed to being built into the switches. Each node detects link failure and link establishment using media-sensing technologies, and shares the link information with the other nodes, to guarantee fast connectivity recovery times. The nodes have equal RRP network management functions.

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-191, *International Electrotechnical Vocabulary – Chapter 191 : Dependability and quality of service* <https://standards.iteh.ai/catalog/standards/sist/fb3f3b2b-c7fb-4161-a370-da075c33332a/sist-en-62439-7-2012>

IEC 62439-1:2010, *Industrial communication networks – High availability automation networks – Part 1: General concepts and calculation methods*

ISO/IEC 8802-3:2000, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications*

### 3 Terms, definitions, abbreviations, acronyms, and conventions

#### 3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-191 as well as in IEC 62439-1, and the following apply.

##### 3.1.1

##### **R-port**

port in a communication device that is part of a line or ring structure

##### 3.1.2

##### **device address**

2 octet address that designates the device associated with a single device on a specific local link