

INTERNATIONAL STANDARD

NORME INTERNATIONALE

iTeh STANDARD PREVIEW

**Explosive atmospheres –
Part 15: Equipment protection by type of protection "n"**
(standards.iteh.ai)

**Atmosphères explosives –
Partie 15: Protection du matériel par mode de protection «n»**
IEC 60079-15:2017
<https://standards.iteh.ai/catalog/standards/sist/a96293d8-1416-46c3-8134-471c5420488/iec-60079-15-2017>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2017 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms, containing 20 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



INTERNATIONAL STANDARD

NORME INTERNATIONALE

Explosive atmospheres –
Part 15: Equipment protection by type of protection "n"
(standards.iteh.ai)

Atmosphères explosives –
Partie 15: Protection du matériel par mode de protection «n»
IEC 60079-15:2017
47ffc54204b8/iec-60079-15-2017

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.260.20

ISBN 978-2-8322-5047-1

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

| | |
|--|----|
| FOREWORD | 4 |
| 1 Scope | 9 |
| 2 Normative references | 15 |
| 3 Terms and definitions | 16 |
| 4 General | 17 |
| 4.1 Equipment grouping and temperature classification | 17 |
| 4.2 Potential ignition sources | 17 |
| 4.3 Equipment requirements | 17 |
| 5 Maximum surface temperatures | 17 |
| 6 Requirements for electrical equipment | 18 |
| 6.1 General | 18 |
| 6.2 Electric strength insulation from earth or frame | 18 |
| 7 Requirements for non-incendive components | 18 |
| 7.1 Type testing | 18 |
| 7.2 Circuit limitations | 18 |
| 8 Requirements for hermetically sealed devices | 18 |
| 9 Requirements for sealed devices | 19 |
| 9.1 Non-metallic materials | 19 |
| 9.2 Opening | 19 |
| 9.3 Internal spaces | 19 |
| 9.4 Handling | 19 |
| 9.5 Gasket and seals | 19 |
| 9.6 Type tests | 19 |
| 10 Requirements for restricted-breathing enclosures | 19 |
| 10.1 General | 19 |
| 10.2 Constructional requirements | 20 |
| 10.2.1 Type of equipment | 20 |
| 10.2.2 Cells and batteries | 20 |
| 10.2.3 Cable glands and conduit entries | 20 |
| 10.2.4 Operating rods, spindles and shafts | 21 |
| 10.2.5 Windows | 21 |
| 10.2.6 Gasket and seal requirements | 21 |
| 10.2.7 Non-resilient seals | 21 |
| 10.2.8 Test port | 22 |
| 10.2.9 Internal fans | 23 |
| 10.3 Temperature limitation | 23 |
| 10.4 Additional requirements for restricted-breathing luminaires | 23 |
| 10.4.1 Mounting arrangement | 23 |
| 10.4.2 Reflectors | 23 |
| 10.4.3 Surface temperatures of restricted-breathing luminaires | 23 |
| 11 Type Tests | 24 |
| 11.1 Tests for non incendive components | 24 |
| 11.1.1 Preparation of non-incendive component samples | 24 |
| 11.1.2 Test conditions for non-incendive components | 24 |
| 11.2 Tests for sealed devices | 25 |

IEC STANDARD PREVIEW

(standards.iteh.ai)

IEC 60079-15:2017

[https://standards.iteh.ai/catalog/standards/sist/a96293d8-1416-46c3-8134-](https://standards.iteh.ai/catalog/standards/sist/a96293d8-1416-46c3-8134-47ffc54204b8/iec-60079-15-2017)

[47ffc54204b8/iec-60079-15-2017](https://standards.iteh.ai/catalog/standards/sist/a96293d8-1416-46c3-8134-47ffc54204b8/iec-60079-15-2017)

| | | |
|--------|---|----|
| 11.2.1 | Conditioning | 25 |
| 11.2.2 | Voltage test | 25 |
| 11.2.3 | Leakage tests on sealed devices | 25 |
| 11.3 | Type test requirements for restricted-breathing enclosures | 26 |
| 11.3.1 | General | 26 |
| 11.3.2 | Equipment where the volume of the enclosure will be unchanged due to pressure | 26 |
| 11.3.3 | Alternative type test for equipment where the volume of the enclosure changes due to pressure | 26 |
| 12 | Routine verifications and tests | 27 |
| 12.1 | Electric strength test | 27 |
| 12.2 | Routine test requirements for restricted-breathing enclosures | 27 |
| 12.2.1 | General | 27 |
| 12.2.2 | Test procedure | 27 |
| 12.3 | Routine temperature rise test | 28 |
| 12.4 | Temperature calculation | 28 |
| 13 | Marking | 29 |
| 13.1 | General | 29 |
| 13.2 | Examples of marking | 29 |
| 13.3 | Warning markings | 29 |
| 14 | Documentation | 29 |
| 15 | Instructions | 30 |
| | Bibliography | 31 |
| | Table 1 – Relationship of IEC 60079-15 to IEC 60079-0 | 9 |
| | Table 2 – Text of warning markings | 29 |

iTech STANDARD PREVIEW
(standards.iteh.ai)

[IEC 60079-15:2017](#)

Table 1 – Relationship of IEC 60079-15 to IEC 60079-0 [http://standards.iteh.ai/catalog/standards/sist/c90293d8-1416-46c3-8134-47ffc54204b8/iec-60079-15-2017](#)

Table 2 – Text of warning markings [http://standards.iteh.ai/catalog/standards/sist/c90293d8-1416-46c3-8134-47ffc54204b8/iec-60079-15-2017](#)

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –

Part 15: Equipment protection by type of protection "n"

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-15 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This fifth edition cancels and replaces the fourth edition, published in 2010, and constitutes a technical revision.

This edition includes the following significant changes with respect to the previous edition:

The text of this International Standard is based on the following documents:

| | |
|--------------|------------------|
| FDIS | Report on voting |
| 31/1339/FDIS | 31/1355/RVD |

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This International Standard is to be read in conjunction with IEC 60079-0.

A list of all parts of the IEC 60079 series, under the general title: *Explosives atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[IEC 60079-15:2017](#)

<https://standards.iteh.ai/catalog/standards/sist/a96293d8-1416-46c3-8134-47ffc54204b8/iec-60079-15-2017>

| Changes | Clause | Type | | |
|---|--------|-----------------------------|-----------|-------------------------|
| | | Minor and editorial changes | Extension | Major technical changes |
| Requirements for enclosed break devices have been removed | - | | | C1 |
| Requirements for type of protection "nA" has been removed | - | | | C2 |
| Scope has been updated to allow equipment with internal working voltages over 15 kV such as starters for HID luminaires | 1 | | X | |
| Definition for cable sealing box removed | 3 | X | | |
| Definitions for creepage distance and clearance removed as they are now in 60079-0 | 3 | X | | |
| Definition of non-sparking device "nA" removed, as the concept has been transferred to 60079-7 | 3 | | | C2 |
| Definition of duty cycle removed | 3 | X | | |
| Definition of enclosed break device moved as the concept has been transferred to 60079-1 | 3 | | | C1 |
| Definition of hermetically sealed device revised | 3 | A1 | | |
| Definition for normally sparking device added | 3.2 | X | | |
| Small component temperature clause removed, part of moving type of protection "nA" to 60079-7 | 5 | | | C2 |
| Minimum degree of protection requirements; clearance, creepage and separation requirements; determination of working voltage; conformal coating; CTI requirement; Insulation between conductive parts and measurement of creepage and clearance requirements have been removed. | 6 | | | C2 |
| Connection facilities and terminal compartment requirements have been removed | - | | | C2 |
| Supplementary requirements for non-sparking electrical rotating machines have been removed | - | | | C2 |
| Supplementary requirements for non-sparking fuses and fuse assemblies have been removed | - | | | C2 |
| Supplementary requirements for non-sparking plugs and sockets have been removed | - | | | C2 |
| Supplementary requirements for non-sparking luminaires have been removed | - | | | C2 |
| Supplementary requirements for equipment incorporating non-sparking cells and batteries have been removed | - | | | C2 |
| Supplementary requirements for non-sparking low power equipment have been removed | - | | | C2 |
| Supplementary requirements for non-sparking current transformers have been removed | - | | | C2 |
| Requirements for other non-sparking electrical equipment have been removed | - | | | C2 |
| General supplementary requirements for equipment producing arcs, sparks or hot surfaces have been removed | - | | | C2 |
| Requirements for enclosed break devices have been removed | - | | | C1 |
| Voltage and current limitations added for non-incendive components. | 7.2 | | | C6 |

| Changes | Clause | Type | | |
|--|----------|-----------------------------|-----------|-------------------------|
| | | Minor and editorial changes | Extension | Major technical changes |
| The requirements for sealed devices have been extended to require more documentation, | 9.1 | | X | |
| The +20K requirement for luminaire materials has been removed | 9.5 | | | C2 |
| Notes 1-3 have been removed, as this information is covered elsewhere | 10.1 | X | | |
| Entry device requirements added | 10.1 | | X | |
| Industrial standard compliance and battery requirements added | 10.2.1.2 | | X | |
| The exemption for manually operated sparking devices moved to here, creepage and clearance requirements in industrial standards added for switching devices, and cell and battery requirements added | 10.2.1.2 | | X | |
| Requirements for cable glands and conduit entries have been clarified | 10.2.3 | X | | |
| Requirements for gasketed windows expanded to allow a removable window mounted in a frame. | 10.2.5.2 | | X | |
| Requirement to include documentation on the thermal stability of gaskets or seals added | 10.2.6 | | | C4 |
| Requirements reworded for clarity | 10.2.7 | X | | |
| Requirements for "nR" enclosures fitted with fans added. | 10.2.9 | | | C5 |
| Type test requirements for enclosed break "nC" and "nA" equipment removed | - | | | C1, C2 |
| The dielectric test after the leakage test for sealed devices has been eliminated unless the results of the leakage test are uncertain. | 11.2.2 | | X | |
| Tests for sealed devices, screw lampholders, starters, lamps, ignitors, and ignitor pulses for luminaires have been removed | - | | | C2 |
| All testing for batteries has been removed. | - | | | C2 |
| All testing for electrical machines removed | - | | | C2 |
| Routine test requirements re-written for sealed components, non-incendive components and restricted breathing equipment to take out the testing for enclosed break and nA equipment | 12 | | | C1, C2 |
| Preparation of non-incendive component samples | 11.1.1 | | | C3 |
| Marking requirements modified to remove labelling requirements for enclosed break components, nA equipment, and batteries. | - | | | C1, C2 |
| Documentation requirements modified to remove to remove labelling requirements for enclosed break components, nA equipment, and batteries. | 14 | | | C1, C2 |
| The instruction section has been expanded to include new requirements | 15 | | X | |
| Annex A has been removed. | - | | | C2 |

NOTE The technical changes referred to include the significance of technical changes in the revised IEC Standard, but they do not form an exhaustive list of all modifications from the previous version.

Explanation of the types of changes:

A) Definitions

1) **Minor and editorial changes:**

- Clarification
- Decrease of technical requirements
- Minor technical change
- Editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

2) **Extension:** Addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

3) **Major technical changes:**

- addition of technical requirements
- increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in Clause B below.

NOTE These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of changes

- A1 – It was determined that this was already covered by the sealed device definition
- C1 – Enclosed break devices “nC” are now designated as “dc” and the requirements are located in IEC 60079-1:2014.
- C2 – Type of protection “nA” is now designated as type of protection “ec” and the requirements for “ec” equipment are located in IEC 60079-7:2015.
- C3 – Test time for the preparation of non-incendive component samples has been specified.
- C4 – Additional documentation requirements for seals and gaskets.
- C5 – As the pressure inside an enclosure fitted with fans can be affected by the operation of the fan, it is now specified that the restricted breathing test is conducted with fans operating and stationary.
- C6 – The limitations from IEC 60079-15 Ed 3 were added.

EXPLOSIVE ATMOSPHERES –

Part 15: Equipment protection by type of protection "n"

1 Scope

This part of IEC 60079 specifies requirements for the construction, testing and marking for Group II electrical equipment with type of protection "n" which includes; sealed devices "nC", hermetically sealed devices "nC", non-incendive components "nC" and restricted breathing enclosures "nR" intended for use in explosive gas atmospheres. This part of IEC 60079 applies to electrical equipment where the rated input voltage does not exceed 15 kV r.m.s. AC or DC including where the internal working voltages of the Ex product exceeds 15 kV, for example starters for HID luminaires.

This part of IEC 60079 supplements and modifies the general requirements of IEC 60079-0, except as indicated in Table 1. Where a requirement of this part of IEC 60079 conflicts with a requirement of IEC 60079-0, the requirement of this part of IEC 60079 takes precedence.

Table 1 – Relationship of IEC 60079-15 to IEC 60079-0

| Clause of IEC 60079-0 | | IEC 60079-0 clause application to IEC 60079-15 | | |
|------------------------------------|--|---|----------------------------|------------------------------|
| Ed. 6.0 (2011) (informative) | Ed. 7.01 (future edition) (informative) | Clause / Subclause title (normative) | Protected sparking "nC" | Restricted breathing "nR" |
| 3 | 3 | Definitions | Applies | Applies |
| 4 | 4 | Equipment grouping | | |
| 4.1 | 4.1 | Group I | Excluded | Excluded |
| 4.2 | 4.2 | Group II | Applies | Applies |
| 4.3 | 4.3 | Group III | Excluded | Excluded |
| 4.4 | 4.4 | Equipment for a particular explosive atmosphere | Applies | Applies |
| 5 | 5 | Temperatures | | |
| 5.1 | 5.1 | Environmental influences | Applies | Applies |
| 5.2 | 5.2 | Service temperature | Applies | Applies |
| 5.3 | 5.3 | Maximum surface temperature | | |
| 5.3.1 | 5.3.1 | Determination of maximum surface temperature | Applies | Applies |
| 5.3.2 | 5.3.2 | Limitation of maximum surface temperature | | |
| 5.3.2.1 | 5.3.2.1 | Group I equipment | Excluded | Excluded |
| 5.3.2.2 | 5.3.2.2 | Group II equipment | Applies | Applies |
| 5.3.2.3 | 5.3.2.3 | Group III equipment | Excluded | Excluded |

¹ Under preparation. Stage at the time of publication: IEC/FDIS 60079-0:2017.

| Clause of IEC 60079-0 | | | IEC 60079-0 clause application to IEC 60079-15 | |
|------------------------------------|--|--|--|------------------------------|
| Ed. 6.0 (2011) (informative) | Ed. 7.01 (future edition) (informative) | Clause / Subclause title (normative) | Protected sparking "nC" | Restricted breathing "nR" |
| 5.3.3 | 5.3.3 | Small component temperature for Group I and Group II equipment | Applies | Excluded |
| - | 5.3.4 | Component temperature of smooth surfaces for Group I or Group II equipment (Applies for smaller than 10 000 mm ² only) | Applies | Excluded |
| 6 | 6 | Requirements for all electrical apparatus | | |
| 6.1 | 6.1 | General | Applies | Applies |
| 6.2 | 6.2 | Mechanical strength | Applies | Applies |
| 6.3 | 6.3 | Opening times | Excluded | Applies |
| 6.4 | 6.4 | Circulating currents | Applies | Applies |
| 6.5 | 6.5 | Gasket retention | Applies | Applies |
| 6.6 | 6.6 | Electromagnetic and ultrasonic radiating equipment | Applies | Applies |
| 7 | 7 | Non-metallic enclosures and non-metallic parts of enclosures | | |
| 7.1 | 7.1 | General | | |
| 7.1.1 | 7.1.1 | Applicability | Applies | Applies |
| 7.1.2 | 7.1.2 | Specification of materials | Applies | Applies |
| 7.2 | 7.2 | Thermal endurance | | |
| 7.2.1 | 7.2.1 | Tests for thermal resistance | Applies | Applies |
| 7.2.2 | - | Material selection | Modified | Modified |
| - | 7.2.2 | Material selection | Applies | Applies |
| 7.2.3 | 7.2.3 | Alternative qualification for elastomeric sealing O-rings | Applies | Applies |
| 7.3 | 7.3 | Resistance to ultraviolet light | Applies | Applies |
| 7.4 | 7.4 | Electrostatic charges on external non-metallic materials | | |
| 7.4.1 | 7.4.1 | Applicability | Applies | Applies |
| 7.4.2 | 7.4.2 | Avoidance of build-up of electrostatic charge on Group I or Group II electrical equipment | Applies | Applies |
| 7.4.3 | 7.4.3 | Avoidance of build-up of electrostatic charge on equipment for Group III | Excluded | Excluded |

| Clause of IEC 60079-0 | | | IEC 60079-0 clause application to IEC 60079-15 | |
|------------------------------------|--|---|--|------------------------------|
| Ed. 6.0 (2011) (informative) | Ed. 7.01 (future edition) (informative) | Clause / Subclause title (normative) | Protected sparking "nC" | Restricted breathing "nR" |
| 7.5 | 7.5 | External conductive parts | Applies | Applies |
| 8 | 8 | Metallic enclosures and metallic parts of enclosures | | |
| 8.1 | 8.1 | Material composition | Applies | Applies |
| 8.2 | 8.2 | Group I | Excluded | Excluded |
| 8.3 | 8.3 | Group II | Applies | Applies |
| 8.4 | 8.4 | Group III | Excluded | Excluded |
| NR | 8.5 | Copper alloys | Applies | Applies |
| 9 | 9 | Fasteners | | |
| 9.1 | 9.1 | General | Applies | Applies |
| 9.2 | 9.2 | Special fasteners | Excluded | Excluded |
| 9.3 | 9.3 | Holes for special fasteners | Excluded | Excluded |
| 9.3.3 | - | Hexagon socket set screws | Excluded | Excluded |
| - | 9.4 | Hexagon socket set screws | Excluded | Excluded |
| 10 | 10 | Interlocking devices | Excluded | Excluded |
| 11 | 11 | Bushings | Applies | Applies |
| 12 | - | Materials used for cementing | Modified | Modified |
| - | 12 | Reserved for future use. | Excluded | Excluded |
| 13 | 13 | Ex components | Applies | Applies |
| 14 | 14 | Connection facilities | Applies | Applies |
| 15 | 15 | Connection facilities for earthing and bonding conductors | Applies | Applies |
| 16 | 16 | Entries into enclosures | Applies | Applies |
| 17 | 17 | Supplementary requirements for electric machines | Excluded | Excluded |
| 18 | 18 | Supplementary requirements for switchgear | Excluded | |
| 18.1 | 18.1 | Flammable dielectric | Excluded | Applies |
| 18.2 | 18.2 | Disconnectors | Excluded | Applies |
| 18.3 | 18.3 | Group I – Provisions for locking | Excluded | Excluded |
| 18.4 | 18.4 | Doors and covers | Excluded | Applies |
| 19 | - | Supplementary requirements for fuses | Excluded | Excluded |
| - | 19 | Reserved for future use. | Excluded | Excluded |
| 20 | 20 | Supplementary requirements for plugs and sockets | | |

| Clause of IEC 60079-0 | | | IEC 60079-0 clause application to IEC 60079-15 | |
|------------------------------------|--|--|--|------------------------------|
| Ed. 6.0 (2011) (informative) | Ed. 7.01 (future edition) (informative) | Clause / Subclause title (normative) | Protected sparking "nC" | Restricted breathing "nR" |
| 20.1 | 20.1 | General | Applies | Applies |
| 20.2 | 20.2 | Explosive gas atmospheres | Excluded | Excluded |
| 20.3 | 20.3 | Explosive dust atmospheres | Excluded | Excluded |
| 20.4 | 20.4 | Energized plugs | Applies | Applies |
| 21 | 21 | Supplementary requirements for luminaires | | |
| 21.1 | 21.1 | General | Applies | Applies |
| 21.2 | 21.2 | Covers for luminaires of EPL Mb, EPL Gb or EPL Db | Excluded | Excluded |
| 21.3 | 21.3 | Covers for luminaires of EPL Gc or EPL Dc | Applies | Applies |
| 21.4 | 21.4 | Sodium lamps | Applies | Applies |
| 22 | 22 | Supplementary requirements for caplights and handlights | | |
| 22.1 | 22.1 | Group I caplights | Excluded | Excluded |
| 22.2 | 22.2 | Group II and Group III caplights and handlights | Excluded | Applies |
| 23 | 23 | Equipment incorporating cells and batteries | Applies | Applies |
| 23.12 | 23.12 | Replacement battery pack | Applies | Applies |
| 24 | 24 | Documentation | Modified | Modified |
| 25 | 25 | Compliance of prototype or sample with documents | Applies | Applies |
| 26 | 26 | Type tests | Applies | Applies |
| 26.4 | 26.4 | Tests of enclosures | | |
| 26.4.1 | 26.4.1 | Order of tests | | |
| 26.4.1.1 | 26.4.1.1 | Metallic enclosures, metallic parts of enclosures and glass or ceramic parts of enclosures | Applies | Applies |
| 26.4.1.2 | 26.4.1.2 | Non-metallic enclosures or non-metallic parts of enclosures | | |
| 26.4.1.2.1 | 26.4.1.2.1 | General | Applies | Applies |
| 26.4.1.2.2 | 26.4.1.2.2 | Group I electrical equipment | Excluded | Excluded |
| 26.4.1.2.3 | - | Group II and Group III electrical equipment | Modified | Modified |
| - | 26.4.1.2.3 | Group II and Group III electrical equipment | Applies | Applies |
| 26.4.2 | 26.4.2 | Resistance to impact | Applies | Applies |

| Clause of IEC 60079-0 | | | IEC 60079-0 clause application to IEC 60079-15 | |
|------------------------------------|--|--|--|------------------------------|
| Ed. 6.0 (2011) (informative) | Ed. 7.01 (future edition) (informative) | Clause / Subclause title (normative) | Protected sparking "nC" | Restricted breathing "nR" |
| 26.4.3 | 26.4.3 | Drop test | Applies | Applies |
| 26.4.4 | 26.4.4 | Acceptance criteria | Applies | Applies |
| 26.4.5 | 26.4.5 | Degree of protection by enclosure | Applies | Applies |
| 26.5 | 26.5 | Thermal tests | | |
| 26.5.1 | 26.5.1 | Temperature measurement | Applies | Applies |
| 26.5.1.1 | 26.5.1.1 | General | Applies | Applies |
| 26.5.1.2 | 26.5.1.2 | Service Temperature | Applies | Applies |
| 26.5.2 | 26.5.2 | Thermal shock test | Applies | Applies |
| 26.5.3 | 26.5.3 | Small component ignition test (Group I and Group II) | Applies | Excluded |
| 26.6 | 26.6 | Torque test for bushings | Applies | Applies |
| 26.7 | 26.7 | Non-metallic enclosures or non-metallic parts of enclosures | | |
| 26.7.1 | 26.7.1 | General | Applies | Applies |
| 26.7.2 | - | Test temperatures | Modified | Modified |
| - | 26.7.2 | Test temperatures | Applies | Applies |
| 26.8 | - | Thermal endurance to heat | Modified | Modified |
| - | 26.8 | Thermal endurance to heat | Applies | Applies |
| 26.9 | 26.9 | Thermal endurance to cold | Applies | Applies |
| 26.10 | 26.10 | Resistance to light | | |
| 26.10.1 | 26.10.1 | General | Applies | Applies |
| 26.10.2 | 26.10.2 | Light exposure | Applies | Applies |
| 26.10.3 | 26.10.3 | Acceptance criteria | Applies | Applies |
| 26.11 | 26.11 | Resistance to chemical agents for Group I electrical equipment | Excluded | Excluded |
| 26.12 | 26.12 | Earth continuity | Applies | Applies |
| 26.13 | 26.13 | Surface resistance test of parts of enclosures of non-metallic materials | Applies | Applies |
| 26.14 | 26.14 | Measurement of capacitance | | |
| 26.14.1 | 26.14.1 | General | Applies | Applies |
| 26.14.2 | 26.14.2 | Test procedure | Applies | Applies |
| 26.15 | 26.15 | Verification of ratings of ventilating fans | Excluded | Excluded |
| 26.16 | 26.16 | Alternative qualification of elastomeric sealing O-rings | Applies | Applies |