

---

**Programski vmesnik za sistem za upravljanje energije (EMS-API) - 456. del: Profili stanja sproščenega elektroenergetskega sistema**

Energy management system application program interface (EMS-API) - Part 456: Solved power system state profiles

**iTeh STANDARD PREVIEW**

Interface de programmation d'application pour systèmes de gestion d'énergie (EMS-API)  
- Partie 456: Profils d'état de réseaux électriques résolus

[SIST EN 61970-456:2013](https://standards.iteh.ai/catalog/standards/sist/c420855f-fe97-4d08-a62d-495da004c78c/sist-en-61970-456-2013)

**Ta slovenski standard je istoveten z: EN 61970-456:2013**

**ICS:**

29.240.30	Krmilna oprema za elektroenergetske sisteme	Control equipment for electric power systems
35.200	Vmesniška in povezovalna oprema	Interface and interconnection equipment

**SIST EN 61970-456:2013****en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 61970-456:2013

<https://standards.iteh.ai/catalog/standards/sist/c420855f-fe97-4d08-a62d-493da604c78c/sist-en-61970-456-2013>

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN 61970-456**

August 2013

ICS 33.200

English version

**Energy management system application program interface (EMS-API) -  
Part 456: Solved power system state profiles  
(IEC 61970-456:2013)**

Interface de programmation d'application  
pour système de gestion d'énergie  
(EMS-API) -  
Partie 456: Profils d'état de réseaux  
électriques résolus  
(CEI 61970-456:2013)

Schnittstelle für Anwendungsprogramme  
für Netzführungssysteme (EMS-API) -  
Teil 456: Globale Stabilitätsbeurteilung  
(IEC 61970-456:2013)

**iTeh STANDARD PREVIEW  
(standards.iteh.ai)**

This European Standard was approved by CENELEC on 2013-06-11. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Management Centre: Avenue Marnix 17, B - 1000 Brussels**

## Foreword

The text of document 57/1327/FDIS, future edition 1 of IEC 61970-456, prepared by IEC TC 57 "Power systems management and associated information exchange" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61970-456:2013.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-03-11
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2016-06-11

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

**iTeh STANDARD PREVIEW**  
**Endorsement notice**  
**(standards.iteh.ai)**

The text of the International Standard IEC 61970-456:2013 was approved by CENELEC as a European Standard without any modification.

[SIST EN 61970-456:2013](#)

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61970-1	NOTE	Harmonised as EN 61970-1.
IEC/TS 61970-2	NOTE	Harmonised as CLC/TS 61970-2.
IEC 61970-301	NOTE	Harmonised as EN 61970-301.
IEC 61970-501	NOTE	Harmonised as EN 61970-501.

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61970-452	-	Energy Management System Application Program Interface (EMS-API) - Part 452: CIM static transmission network model profiles	EN 61970-452	-
IEC 61970-453	-	Energy Management System Application Program Interface (EMS-API) - Part 453: Diagram Layout Profile	EN 61970-453	-
IEC 61970-552	-	Energy Management System Application Program Interface (EMS-API) - Part 552: CIM XML Model Exchange Format	EN 61970-552	-

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 61970-456:2013](https://standards.iteh.ai/catalog/standards/sist/c420855f-fe97-4d08-a62d-493da604c78c/sist-en-61970-456-2013)

<https://standards.iteh.ai/catalog/standards/sist/c420855f-fe97-4d08-a62d-493da604c78c/sist-en-61970-456-2013>

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 61970-456:2013

<https://standards.iteh.ai/catalog/standards/sist/c420855f-fe97-4d08-a62d-493da604c78c/sist-en-61970-456-2013>



IEC 61970-456

Edition 1.0 2013-05

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE



**Energy management system application program interface (EMS-API) –  
Part 456: Solved power system state profiles**

**Interface de programmation d'application pour système de gestion d'énergie  
(EMS-API) –  
Partie 456: Profils d'état de réseaux électriques résolus**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE  
CODE PRIX

W

ICS 33.200

ISBN 978-2-83220-756-7

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references .....	7
3 Profile information .....	8
4 Overview .....	8
5 Use cases .....	9
5.1 General.....	9
5.2 EMS state estimation.....	9
5.3 ENTSO-E Process: Day-ahead congestion forecast.....	10
5.4 System planning studies process.....	11
5.5 Harmonization of planning and operations models.....	12
6 Architecture.....	12
6.1 General.....	12
6.2 Profile architecture .....	12
6.3 Profiles and datasets for EMS network analysis .....	15
6.4 Profiles and datasets in a planning power flow .....	16
6.5 Model authority sets and instance level data modularization.....	17
6.5.1 General.....	17
6.5.2 EMS instance modularization.....	17
6.5.3 Planning instance modularization.....	18
6.6 Principles of instance modularization.....	19
7 Applying the standard to business problems.....	21
7.1 EMS network analysis integration with external consumers .....	21
7.2 Planning network analysis integration with external consumers .....	23
8 Data model with CIMXML examples.....	24
8.1 Measurement interfaces 2 and 3.....	24
8.2 Topology interface 4.....	24
8.3 State variables interfaces 5a and 5b state estimation .....	26
9 Topology profile.....	30
9.1 General.....	30
9.2 Concrete classes.....	30
9.2.1 Terminal.....	30
9.2.2 TopologicalNode.....	31
9.3 Abstract classes – IdentifiedObject.....	31
10 StateVariables profile .....	32
10.1 General.....	32
10.2 Concrete classes.....	32
10.2.1 TopologicalIsland .....	32
10.2.2 SvInjection .....	32
10.2.3 SvPowerFlow.....	33
10.2.4 SvShortCircuit .....	33
10.2.5 SvShuntCompensatorSections.....	33
10.2.6 SvTapStep.....	34
10.2.7 SvVoltage.....	34



10.3 Abstract classes .....	34
10.3.1 StateVariable.....	34
10.3.2 ActivePower .....	34
10.3.3 AngleRadians .....	35
10.3.4 ApparentPower.....	35
10.3.5 ReactivePower .....	35
10.3.6 Voltage.....	35
Bibliography.....	36
Figure 1 – TSO sends a case to be merged with the overall model .....	11
Figure 2 – Profile relationships .....	13
Figure 3 – Instance example of the CIM connectivity model .....	14
Figure 4 – EMS datasets by CIM profiles .....	15
Figure 5 – Planning power flow datasets by CIM profile .....	16
Figure 6 – State estimation case sequence.....	17
Figure 7 – Instance modularization applied in an EMS .....	18
Figure 8 – Instance modularization applied to planning power flow models .....	19
Figure 9 – Model merge process.....	20
Figure 10 – EMS datasets to an external client .....	21
Figure 11 – EMS boundary dataset example .....	22
Figure 12 – Bus-branch Integration architecture.....	23
Figure 13 – Bus-branch modeling of bus coupler and line transfer .....	23
Figure 14 – CIM topology model.....	24
Figure 15 – Topology solution interface.....	25
Figure 16 – CIM state variable solution model.....	27
Figure 17 – State solution interface example .....	29
Table 1 – Profiles defined in this document.....	8

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**ENERGY MANAGEMENT SYSTEM APPLICATION  
PROGRAM INTERFACE (EMS-API) –**
**Part 456: Solved power system state profiles**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61970-456 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/1327/FDIS	57/1342/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61970 series, under the general title: *Energy management system application program interface (EMS-API)*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## **iTeh STANDARD PREVIEW** **(standards.iteh.ai)**

[SIST EN 61970-456:2013](#)

<https://standards.iteh.ai/catalog/standards/sist/c420855f-fe97-4d08-a62d-493da604c78c/sist-en-61970-456-2013>

## INTRODUCTION

This standard is one of several parts of the IEC 61970 series that defines common information model (CIM) datasets exchanged between application programs in energy management systems (EMS).

The IEC 61970-3xx series of documents specify the common information model (CIM). The CIM is an abstract model that represents the objects in an electric utility enterprise typically needed to model the operational aspects of a utility.

This standard is one of the IEC 61970-4xx series of component interface standards that specify the semantic structure of data exchanged between components (or applications) and/or made publicly available data by a component. This standard describes the payload that would be carried if applications are communicating via a messaging system, but the standard does not include the method of exchange, and therefore is applicable to a variety of exchange implementations. This standard assumes and recommends that the exchanged data is formatted in XML based on the resource description framework (RDF) schema as specified in 61970-552 CIM XML model exchange standard.

IEC 61970-456 specifies the profiles (or subsets) of the CIM required to describe a steady-state solution of a power system case, such as is produced by power flow or state estimation applications. It describes the solution with reference to a power system model that conforms to IEC 61970-452 in this series of related standards. (Thus solution data does not repeat the power system model information.) IEC 61970-456 is made up of several component profiles that describe: topology derived from switch positions, measurement input (in the case of state estimation), and the solution itself.

(standards.iteh.ai)

SIST EN 61970-456:2013

<https://standards.iteh.ai/catalog/standards/sist/c420855f-fe97-4d08-a62d-493da604c78c/sist-en-61970-456-2013>

## ENERGY MANAGEMENT SYSTEM APPLICATION PROGRAM INTERFACE (EMS-API) –

### Part 456: Solved power system state profiles

#### 1 Scope

This part of IEC 61970 belongs to the IEC 61970-450 to IEC 61970-499 series that, taken as a whole, defines at an abstract level the content and exchange mechanisms used for data transmitted between control centers and/or control center components.

The purpose of this part of IEC 61970 is to rigorously define the subset of classes, class attributes, and roles from the CIM necessary to describe the result of state estimation, power flow and other similar applications that produce a steady-state solution of a power network, under a set of use cases which are included informatively in this standard.

This standard is intended for two distinct audiences, data producers and data recipients, and may be read from those two perspectives. From the standpoint of model export software used by a data producer, the standard describes how a producer may describe an instance of a network case in order to make it available to some other program. From the standpoint of a consumer, the standard describes what that importing software must be able to interpret in order to consume solution cases.

There are many different use cases for which use of this standard is expected and they differ in the way that the standard will be applied in each case. Implementers should consider what use cases they wish to cover in order to know the extent of different options they must cover. As an example, this standard will be used in some cases to exchange starting conditions rather than solved conditions, so if this is an important use case, it means that a consumer application needs to be able to handle an unsolved state as well as one which has met some solution criteria.

#### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61970-452, *Energy Management System Application Program Interface (EMS-API) – Part 452: CIM Static Transmission Network Model Profiles*<sup>1</sup>

IEC 61970-453, *Energy Management System Application Program Interface (EMS-API) – Part 453: Diagram Layout Profile*

IEC 61970-552, *Energy Management System Application Program Interface (EMS-API) – Part 552: CIM XML Model Exchange Format*<sup>2</sup>

<sup>1</sup> To be published.

<sup>2</sup> To be published.