
<][fchYfa UbY'nbU]bcghj'ghUj V!'FU i bUb'Y]b'dfYXghUj]hYj ' _]a Uhg _] 'dcXUh_cj '!
"XY. 'JgchU'hYa dYfUi fb] 'fUn]_ 'fKbYj bYg'hc d]b'Y'f'f'GC '%' - &+! .&\$\$+L

Hygrothermal performance of buildings — Calculation and presentation of climatic data
— Part 6: Accumulated temperature differences (degree days) (ISO 15927-6:2007)

Wärme und feuchteschutztechnisches Verhalten von Gebäuden — Berechnung und
Darstellung von Klimadaten — Teil 6: Akkumulierte Temperaturdifferenzen (Gradtage)
(ISO 15927 6:2007)

iteh STANDARD PREVIEW

(standards.iteh.ai)

Performance hygrothermique des bâtiments — Calcul et présentation des données
climatiques — Partie 6: Différences accumulées de la température (en degrés par jour)
(ISO 15927 6:2007) <https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008>

Ta slovenski standard je istoveten z: EN ISO 15927-6:2007

ICS:

07.060	Geologija. Meteorologija. Hidrologija	Geology. Meteorology. Hydrology
91.120.10	Toplotna izolacija stavb	Thermal insulation

SIST EN ISO 15927-6:2008

en,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 15927-6:2008

<https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008>

ICS 07.060; 91.120.10

English Version

Hygrothermal performance of buildings - Calculation and
presentation of climatic data - Part 6: Accumulated temperature
differences (degree-days) (ISO 15927-6:2007)

Performance hygrothermique des bâtiments - Calcul et
présentation des données climatiques - Partie 6: Écarts de
température cumulés (degrés-jour) (ISO 15927-6:2007)

Wärme- und feuchteschutztechnisches Verhalten von
Gebäuden - Berechnung und Darstellung von Klimadaten -
Teil 6: Akkumulierte Temperaturdifferenzen (Gradtage)
(ISO 15927-6:2007)

This European Standard was approved by CEN on 30 June 2007.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

Page

Foreword.....3

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 15927-6:2008

<https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008>

Foreword

This document (EN ISO 15927-6:2007) has been prepared by Technical Committee ISO/TC 163 "Thermal performance and energy use in the built environment" in collaboration with Technical Committee CEN/TC 89 "Thermal performance of buildings and building components", the secretariat of which is held by SIS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2008, and conflicting national standards shall be withdrawn at the latest by March 2008.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

Endorsement notice

The text of ISO 15927-6:2007 has been approved by CEN as a EN ISO 15927-6:2007 without any modification.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 15927-6:2008](https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008)

<https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 15927-6:2008

<https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008>

**Hygrothermal performance of
buildings — Calculation and presentation
of climatic data —**

**Part 6:
Accumulated temperature differences
(degree days)**

iTeh STANDARD PREVIEW

(standards.iteh.ai)
*Performance hygrothermique des bâtiments — Calcul et présentation
des données climatiques —*

Partie 6: Différences accumulées de la température (en degrés par jour)

<https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008>



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 15927-6:2008](https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008)

<https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2007

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms, definitions, symbols and units	1
4 Direct calculation of accumulated temperature differences	3
5 Estimation of totals	6
6 Reference altitude	7
7 Accuracy and presentation of data	8
Annex A (informative) Estimation of monthly accumulated temperature differences from climatological statistics	10
Bibliography	13

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 15927-6:2008](https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008)

<https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 15927-6 was prepared by the European Committee for Standardization (CEN) Technical Committee CEN/TC 89, *Thermal performance of buildings and building components*, in collaboration with Technical Committee ISO/TC 163, *Thermal performance and energy use in the built environment*, Subcommittee SC 2, *Calculation methods*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

ISO 15927 consists of the following parts, under the general title *Hygrothermal performance of buildings — Calculation and presentation of climatic data*: [SIST EN ISO 15927-6:2008](https://standards.iteh.ai/catalog/standards/sist/3da76bd7-e17c-4e3c-a10e-4f0be76d017d/sist-en-iso-15927-6-2008)

- *Part 1: Monthly means of single meteorological elements*
- *Part 2: Hourly data for design cooling load*
- *Part 3: Calculation of a driving rain index for vertical surfaces from hourly wind and rain data*
- *Part 4: Hourly data for assessing the annual energy use for heating and cooling*
- *Part 5: Data for design heat load for space heating*
- *Part 6: Accumulated temperature differences (degree days)*

Introduction

Accumulated temperature differences are a relatively simple form of climatic data, useful as an index of climate severity as it affects energy use for space heating.

Calculation or estimation of accumulated temperature differences in this part of ISO 15927 is based on the concept of a base temperature. The base temperature reflects the point at which buildings begin to need heating to maintain the required internal temperatures. This is the external temperature below which the heating plant is assumed to come into operation. For some purposes, such as development of energy policy, the need is for a single base temperature that can be taken to represent an average value for the whole built stock and overall climate. For other purposes, it is better to determine a base temperature appropriate to an individual building and time of year.

This part of ISO 15927 meets these needs by including both exact and approximate methods of determining accumulated temperature differences to both standard and variable base temperatures. Some methods include the possibility of a threshold temperature (e.g. a daily mean air temperature lower than the base temperature, above which accumulated temperature differences are not counted). This approach is found in certain national methods of computation. It is, however, not covered in this part of ISO 15927 because it is considered to be less flexible than the methods given, in which accumulated temperature differences are assessed for a base temperature appropriate to the thermal performance of the building (taking account of other climatic conditions such as solar irradiation).

Accumulated temperature differences computed and presented in accordance with this part of ISO 15927 are suitable for various purposes including the following:

- a) providing an index of climatic severity as it affects energy use for space heating (the comparison use);
- b) monitoring the amount of energy used by a heating plant, and thus its efficiency (the energy management use);
- c) comparing the actual energy consumption for heating in a specific period with the consumption in a standardized period in order to determine the measured rating (the energy modelling use);
- d) predicting the economic consequences of different levels of energy efficiency (e.g. through thermal insulation) for the building stock as a whole or for different classes of building (the energy policy use).

Energy management [list item b)] requires new accumulated temperature difference data at regular intervals, such as meteorological station data or data representative of a climatic region, calculated to standard base temperatures, published for each month of the heating season as soon as these can be computed from verified meteorological observations.

Comparison, energy modelling and energy policy [list items a), c) and d)] require meteorological station data, data representative of a climatic region or mapped data, collected over many years (possibly giving extremes as well as mean values), to typify the severity of the climate of a locality, area or region. For list item b), accumulated temperature differences are best suited to modelling the energy performance of relatively small buildings with simple heating systems and controls, using “steady-state” thermal analysis. Modelling the performance of larger or more complex buildings can require more extensive climatological data sets, such as full or short “test reference years” which are outside the scope of this part of ISO 15927.

In principle the equations in this part of ISO 15927 can be reversed to deal with accumulated temperature differences for assessing energy use in cooling or air-conditioning buildings (“cooling degree-hours” or “cooling degree-days”). However, as the air conditioning demand depends as much on solar gain and external humidity as temperature, the results are not a reliable index of energy demand.