



SLOVENSKI STANDARD

SIST EN 50526-3:2016

01-junij-2016

Železniške naprave - Stabilne naprave električne vleke - Enosmerni prenapetostni odvodniki in omejljniki napetosti - 3. del: Navodilo za uporabo

Railway applications - Fixed installations - D.C. surge arresters and voltage limiting devices - Part 3 Application guide

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Ta slovenski standard je istoveten z: **EN 50526-3:2016**
<https://standards.iteh.ai/catalog/standards/sist/17e9a189-8b95-4bc5-9dea-d97b93181e90/sist-en-50526-3-2016>

ICS:

29.120.50	Varovalke in druga medtokovna zaščita	Fuses and other overcurrent protection devices
29.280	Električna vlečna oprema	Electric traction equipment

SIST EN 50526-3:2016

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 50526-3:2016

<https://standards.iteh.ai/catalog/standards/sist/17e9af89-8b95-4bc5-9dea-d97b93181e90/sist-en-50526-3-2016>

EUROPEAN STANDARD

EN 50526-3

NORME EUROPÉENNE

EUROPÄISCHE NORM

January 2016

ICS 29.120.50; 29.280

English Version

Railway application - Fixed installations - D.C. surge arresters and voltage limiting devices - Part 3: Application Guide

Applications ferroviaires - Installations fixes - Parafoudres et limiteurs de tension pour systèmes à courant continu - Partie 3: Guide d'application

Bahnanwendungen - Ortsfeste Anlagen - Überspannungsableiter und Spannungsbegrenzungseinrichtung für Gleichspannungsnetze - Teil 3: Anwendungsleitfaden

This European Standard was approved by CENELEC on 2015-12-07. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Content	Page
European foreword	4
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and definitions.....	7
4 General considerations	13
4.1 General.....	13
4.2 Application of surge arresters.....	14
4.2.1 General.....	14
4.2.2 Insulation level of equipment to be protected	14
4.2.3 Internal overvoltages.....	14
4.2.4 Lightning Overvoltages.....	15
4.3 Application of VLDs.....	16
4.3.1 General.....	16
4.3.2 Short term protection	16
4.3.3 Long term protection.....	17
4.3.4 Selection of VLD-F or VLD-O	17
5 Symbols for surge arresters and VLDs	17
6 Guideline for Surge Arresters	18
6.1 General.....	18
6.1.1 Electrical characteristics.....	18
6.1.2 Housing.....	19
6.1.3 Porcelain-housed surge arresters	19
6.1.4 Polymer-housed surge arresters	19
6.2 Systems and equipment to be protected by surge arresters.....	20
6.3 Nominal discharge current I_n	23
6.4 Selection of Continuous Operating Voltage	23
6.4.1 Continuous operating voltage U_c for arresters A1	23
6.4.2 Continuous operating voltage U_c for arresters A2	24
6.5 Protective level of A1 and A2 arresters.....	24
6.6 Charge transfer capability	27
6.6.1 General.....	27
6.6.2 Typical overvoltages during clearing a line fault	27
6.6.3 Arrester A1	33
6.6.4 Arrester A2	34
6.7 Procedure to select an A1 arrester	34
6.8 Procedure to select an A2 arrester	38
6.9 Connecting leads of arresters	38
6.10 Earthing requirements.....	38
7 Guideline for VLDs.....	39
7.1 Introduction	39
7.2 General.....	40
7.3 Mass transit railways and trams (U_n up to d.c. 750 V)	40
7.3.1 General.....	40
7.3.2 Trams with OCL	40
7.3.3 Metros with a conductor rail.....	42
7.3.4 Light-rail metros with OCLs.....	43
7.4 Railways (d.c. 1 500V ... d.c. 3 000 V)	43
7.4.1 General.....	43

7.4.2	Application of VLDs along the lines or at the substations and in the sectioning posts	43
7.4.3	Recommended characteristics of VLDs	45
7.5	Workshops	46
7.5.1	Application of VLD-O	46
7.5.2	Application of VLD-F	46
8	Further considerations	46
8.1	Installation recommendations	46
8.1.1	Mounting aspect	46
8.1.2	Periodicity of inspection and management of alarms	48
8.1.3	Colours of the cables	49
8.2	Interaction between arresters and VLDs	49
8.3	Interaction with other systems	49
8.3.1	Interaction with signalling systems	49
8.3.2	Interaction with earthing systems	50
8.3.3	Interaction with tunnel earthing systems	50
8.3.4	Separation of a.c. cable screens	50
	Bibliography	51

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 50526-3:2016

<https://standards.iteh.ai/catalog/standards/sist/17e9af89-8b95-4bc5-9dea-d97b93181e90/sist-en-50526-3-2016>

EN 50526-3:2016 (E)

European foreword

This document (EN 50526-3:2016) has been prepared by CLC/SC 9XC, "Electric supply and earthing systems for public transport equipment and ancillary apparatus (Fixed installations)", of CLC/TC 9X, "Electrical and electronic applications for railways".

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2016-12-07
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2018-12-07

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 50526-3:2016

<https://standards.iteh.ai/catalog/standards/sist/17e9af89-8b95-4bc5-9dea-d97b93181e90/sist-en-50526-3-2016>

Introduction

This European Standard is divided into three parts.

Part 1 deals with metal oxide arresters without gaps for d.c. railway traction systems (fixed installations) and is based on EN 60099-4.

Part 2 deals with voltage limiting devices for specific use in d.c. railway traction systems (fixed installations).

Part 3 is a Guide of application of metal-oxide arresters and of voltage limiting devices.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 50526-3:2016](https://standards.iteh.ai/catalog/standards/sist/17e9af89-8b95-4bc5-9dea-d97b93181e90/sist-en-50526-3-2016)

<https://standards.iteh.ai/catalog/standards/sist/17e9af89-8b95-4bc5-9dea-d97b93181e90/sist-en-50526-3-2016>

EN 50526-3:2016 (E)

1 Scope

This Application Guide supports the European Standards EN 50526-1 and EN 50526-2.

Guidance is offered on the following subjects:

- the selection and installation of surge arresters;
- the selection and installation of voltage limiting devices as VLD-O and VLD-F;
- the arrangement of the surge arresters and VLDs.

Because of differences in the established, proven methods, electric traction systems of nominal voltage d.c. 600 V – d.c. 750 V are treated separately from the systems at higher nominal voltages.

This Application Guide only applies to d.c. electrified traction systems

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50122-1:2011, *Railway applications - Fixed installations - Electrical safety, earthing and the return circuit - Part 1: Protective provisions against electric shock*

EN 50122-2:2010, *Railway applications - Fixed installations - Electrical safety, earthing and the return circuit - Part 2: Provisions against the effects of stray currents caused by d.c. traction systems*

EN 50123-2:2003, *Railway applications - Fixed installations - D.C. switchgear - Part 2: D.C. circuit breakers*

EN 50123-7-1:2003, *Railway applications - Fixed installations - D.C. switchgear - Part 7-1: Measurement, control and protection devices for specific use in d.c. traction systems - Application guide*

EN 50124-1:2001, *Railway applications - Insulation coordination - Part 1: Basic requirements - Clearances and creepage distances for all electrical and electronic equipment*

EN 50163: 2004, *Railway applications - Supply voltages of traction systems*

EN 50526-1:2012, *Railway applications - Fixed installations - D.C. surge arresters and voltage limiting devices - Part 1: Surge arresters*

EN 50526-2:2014, *Railway applications - Fixed installations - D.C. surge arresters and voltage limiting devices - Part 2: Voltage limiting devices*

EN 62305-2, *Protection against lightning - Part 2: Risk management.*

IEC 60050-195:1998, *International Electrotechnical Vocabulary - Chapter 195: Earthing and protection against electric shock*

IEC 60050-441:1984, *International Electrotechnical Vocabulary - Chapter 441: Switchgear, controlgear and fuses*

IEC 60050-604:1987, *International Electrotechnical Vocabulary. Chapter 604: Generation, transmission and distribution of electricity - Operation*

IEC 60050-811:1991, *International Electrotechnical Vocabulary - Chapter 811: Electric traction*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

nominal voltage

U_n

designated value for a system

[SOURCE: EN 50163:2004, 3.3]

3.2

highest permanent voltage

U_{max1}

maximum value of the voltage likely to be present indefinitely

[SOURCE: EN 50163:2004, 3.4]

3.3

highest non-permanent voltage

U_{max2}

maximum value of the voltage likely to be present for a limited period of time

[SOURCE: Adapted from EN 50163:2004, 3.5]

3.4

rated insulation voltage

U_{Nm}

d.c withstand voltage value assigned by the manufacturer to the equipment or a part of it, characterising the specified permanent (over five minutes) withstand capability of its insulation

[SOURCE: EN 50526-1:2012, 3.4]

3.5

rated impulse withstand voltage

U_{Ni}

impulse voltage value assigned by the manufacturer to the equipment or a part of it, characterising the specified withstand capability of its insulation against transient overvoltages

[SOURCE: EN 50526-1:2012, 3.5]

3.6

overvoltage

voltage having a peak value exceeding the corresponding peak value of the highest non-permanent voltage U_{max2}

[SOURCE: EN 50526-1:2012, 3.6]

3.7

transient overvoltage

short duration overvoltage of a few (up to 20 ms) milliseconds or less associated with a transient regime

Note 1 to entry: Two particular transient overvoltages are defined: switching overvoltage and lightning overvoltage.

[SOURCE: EN 50526-1:2012, 3.7]

EN 50526-3:2016 (E)

3.8

switching overvoltage

U_{so}

transient overvoltage at any point of the system due to specific switching operation or fault

[SOURCE: EN 50526-1:2012, 3.8]

3.9

lightning overvoltage

transient overvoltage at any point of the system due to a lightning discharge

[SOURCE: EN 50124-1:2001, 1.3.3.2.2]

3.10

surge arrester

device intended to limit the transient overvoltages to a specified level

[SOURCE: EN 50526-1:2012, 3.10]

3.11

metal-oxide surge arrester

arrester having non-linear metal-oxide resistors connected in series and/or in parallel without any integrated series or parallel spark gaps

[SOURCE: EN 50526-1:2012, 3.11]

3.12

continuous operating voltage of an arrester

U_c

designated permissible d.c. voltage value that may be applied continuously between the arrester terminals

[SOURCE: EN 50526-1:2012, 3.12]

3.13

rated voltage of an arrester

U_r

voltage by which the arrester is designated

Note 1 to entry: Because of the particular nature of the d.c. electrical installation dealt with, the rated voltage of a d.c. arrester coincides with the continuous operating voltage.

[SOURCE: EN 50526-1:2012, 3.13]

3.14

lightning impulse protection level

U_{pl}

the maximum residual voltage for the nominal discharge current

[SOURCE: EN 50526-1:2012, 3.15]

3.15

switching impulse protection level

U_{ps}

maximum residual voltage at the specified switching impulse current

[SOURCE: EN 50526-1:2012, 3.16]

3.16**charge transfer capability** **Q_T**

maximum charge per impulse that can be transferred during the charge transfer test and during the operating duty test

[SOURCE: EN 50526-1:2012, 3.17]

3.17**discharge current of an arrester**

impulse current which flows through the arrester

[SOURCE: EN 50526-1:2012, 3.18]

3.18**nominal discharge current of an arrester** **I_n**

peak value of lightning current impulse which is used to classify an arrester

[SOURCE: EN 50526-1:2012, 3.19]

3.19**high current impulse of an arrester**

peak value of discharge current having a 4/10 μ s impulse shape which is used to test the stability of the arrester on direct lightning strikes

[SOURCE: EN 50526-1:2012, 3.20]

3.20**steep current impulse**

current impulse with a virtual front time of 1 μ s with limits in the adjustment of equipment such that the measured values are from 0,9 μ s to 1,1 μ s and the virtual time to half-value on the tail is not longer than 20 μ s

[SOURCE: EN 50526-1:2012, 3.21]

3.21**lightning current impulse**

8/20 μ s current impulse with limits on the adjustment of equipment such that the measured values are from 7 μ s to 9 μ s for the virtual front time and from 18 μ s to 22 μ s for the time to half-value on the tail

[SOURCE: EN 50526-1:2012, 3.22]

3.22**direct lightning current impulse**

impulse defined by the charge Q and the peak value of the current impulse I_{imp}

[SOURCE: EN 50526-1:2012, 3.23]

3.23**switching current impulse of an arrester** **I_{sw}**

peak value of discharge current having a virtual front time greater than 30 μ s but less than 100 μ s and a virtual time to half value on the tail of roughly twice the virtual front time

[SOURCE: EN 50526-1:2012, 3.24]

EN 50526-3:2016 (E)

3.24

porcelain-housed arrester

arrester using porcelain as housing material, with fittings and sealing systems

[SOURCE: EN 50526-1:2012, 3.30]

3.25

polymer-housed arrester

arrester using polymeric and/or composite materials for housing

[SOURCE: EN 50526-1:2012, 3.31]

3.26

flashover

disruptive discharge over a solid surface

[SOURCE: EN 50526-1:2012, 3.44]

3.27

impulse

unidirectional wave of voltage or current which without appreciable oscillations rises rapidly to a maximum value and falls – usually less rapidly – to zero with small, if any, excursions of opposite polarity

Note 1 to entry: The parameters which define a voltage or current impulse are polarity, peak value, front time and time to half value on the tail.

ITeH STANDARD PREVIEW
(standards.iteh.ai)

[SOURCE: EN 50526-1:2012, 3.45]

3.28

voltage-limiting device

VLD

protective device whose function is to prevent existence of an impermissible high touch voltage

[SOURCE: EN 50122-1:2011, 3.1.20]

3.29

recoverable VLD

VLD that recovers after triggering

[SOURCE: EN 50526-2:2014, 3.2]

3.30

non-recoverable VLD

VLD remaining in its low resistance state permanently after triggering

[SOURCE: EN 50526-2:2014, 3.3]

3.31

welding-shut spark gap

voltage fuse

VLD which triggers by electrical discharge across a gap causing a permanent short-circuit by melting of metallic parts

[SOURCE: EN 50526-2:2014, 3.4]

3.32**rated current** I_r

maximum value of the direct current that may flow permanently through the VLD in specified environmental conditions

[SOURCE: EN 50526-2:2014, 3.5]

3.33**short time withstand current** I_w

current that a VLD can carry in closed status, during a specified short time under prescribed conditions of use and behaviour

[SOURCE: EN 50526-2:2014, 3.6]

3.34**breaking capacity**

maximum current that a recoverable VLD can interrupt at a stated voltage

[SOURCE: IEC 60050-441:1984, 17-08]

3.35**residual voltage** U_{res}

a) peak value of voltage that appears between the terminals of an arrester during the passage of discharge current

b) value of voltage that appears between the terminals of the VLD during the passage of a specified current

<https://standards.iteh.ai/catalog/standards/sist/17e9af89-8b95-4bc5-9dea-d97b93181e90/sist-en-50526-3-2016>

[SOURCE: EN 50526-1:2012, 3.27] and [SOURCE: EN 50526-2:2014, 3.17]

3.36**structure earth**

construction made of metallic parts or construction including interconnected metallic structural parts, which can be used as an earth electrode

[SOURCE: EN 50122-1:2011, 3.2.4]

3.37**open connection**

connection of conductive parts to the return circuit by a voltage-limiting device which makes a conductive connection either temporarily or permanently if the limited value of the voltage is exceeded

[SOURCE: EN 50122-1:2011, 3.2.12]

iTeh STANDARD PREVIEW
(standards.iteh.ai)

EN 50526-3:2016 (E)

3.38

return circuit

all conductors which form the intended path for the traction return current

EXAMPLE Conductors may be:

- running rails,
- return conductor rails,
- return conductors,
- return cables.

[SOURCE: EN 50122-1:2011, 3.3.1]

3.39

rail potential

U_{RE}

voltage occurring between running rails and earth

[SOURCE: EN 50122-1:2011, 3.3.7]

3.40

(traction) substation

installation to supply a contact line system and at which the voltage of a primary supply system, and in certain cases the frequency, is transformed to the voltage and the frequency of the contact line

[SOURCE: EN 50122-1:2011, 3.4.2]

3.41

(traction) switching station

installation from which electrical energy can be distributed to different feeding sections or from which different feeding sections can be switched on and off or can be interconnected

[SOURCE: EN 50122-1:2011, 3.4.3]

3.42

normal operation

operation without fault condition on the line

Note 1 to entry: In this standard normal operation includes also degraded mode (loss of one or several substations)

3.43

fault (or fault condition)

non intended condition caused by short-circuit. The time duration is terminated by the correct function of the protection devices and circuit breakers

Note 1 to entry: For the relevant fault duration the correct operation of protection devices and circuit breakers is taken into account.

[SOURCE: Adapted from EN 50122-1:2011, 3.4.5]

3.44

internal overvoltage

an overvoltage in the system resulting from switching or from a fault in the system itself

[SOURCE: IEC 60050-604:1987, 03-31]

3.45**short-circuit**

accidental or intentional conductive path between two or more conductive parts forcing the electric potential differences between these conductive parts to be equal to or close to zero

[SOURCE: IEC 60050-195:1998, 04-11]

3.46**stray current**

part of the current caused by a d.c.-traction system which follows paths other than the return circuit

[SOURCE: Adapted from EN 50122-1:2011, 3.6.3]

3.47**overhead contact line****OCL**

contact line placed above (or beside) the upper limit of the vehicle gauge and supplying vehicles with electric energy through roof-mounted current collection equipment

[SOURCE: IEC 60050-811:1991, 33-02]

3.48**conductor rail**

contact line made of a rigid metallic section or rail, mounted on insulators located near the running rails

[SOURCE: EN 50119:2009, 3.1.7]

3.49**overhead contact line zone****OCLZ**

zone whose limits are in general not exceeded by a broken overhead contact line

[SOURCE: EN 50122-1:2011, 3.5.9]

3.50**current collector zone****CCZ**

zone whose limits are in general not exceeded by an energised collector no longer in contact with the contact line or broken collector and its fragments

[SOURCE: EN 50122-1:2011, 3.5.10]

4 General considerations**4.1 General**

Surge arresters are intended to protect power equipment from the lightning overvoltages. A surge arrester can be used also in order to protect electronic equipment against high transient voltages in the circuits to which the equipment is connected. See EN 50526-1 for the product specification.

VLDs are intended to protect persons from impermissible touch voltages between conductive parts caused by train operating currents or faults. When selecting a VLD, it should be considered whether the required function is VLD-F, or VLD-O or both as described in EN 50122-1. This is a question for the system design. See EN 50526-2 for the product specification.