



SLOVENSKI STANDARD
SIST EN 60598-2-13:2007/A1:2012
01-maj-2012

Svetilke - 2-13. del: Posebne zahteve - Talne vgradne svetilke

Luminaire - Part 2-13: Particular requirements - Ground recessed luminaire

Leuchten - Teil 2-13: Besondere Anforderungen - Bodeneinbauleuchten

Luminaire - Partie 2-13: Règles particulières - Luminaire encastrés dans le sol

Ta slovenski standard je istoveten z: EN 60598-2-13:2006/A1:2012

[SIST EN 60598-2-13:2007/A1:2012](https://standards.iteh.ai/catalog/standards/sist/61456402-7b60-413e-b252-a1a2c3381dd2/sist-en-60598-2-13-2007-a1-2012)

<https://standards.iteh.ai/catalog/standards/sist/61456402-7b60-413e-b252-a1a2c3381dd2/sist-en-60598-2-13-2007-a1-2012>

ICS:

29.140.40 Svetila Luminaire

SIST EN 60598-2-13:2007/A1:2012 en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60598-2-13:2007/A1:2012

<https://standards.iteh.ai/catalog/standards/sist/61456402-7b60-413e-b252-a1a2c3381dd2/sist-en-60598-2-13-2007-a1-2012>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60598-2-13/A1

February 2012

ICS 29.140.40

English version

**Luminaire -
Part 2-13: Particular requirements -
Ground recessed luminaire
(IEC 60598-2-13:2006/A1:2011)**

Luminaire -
Partie 2-13: Règles particulières -
Luminaire encastrés dans le sol
(CEI 60598-2-13:2006/A1:2011)

Leuchten -
Teil 2-13: Besondere Anforderungen -
Bodeneinbauleuchten
(IEC 60598-2-13:2006/A1:2011)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

This amendment A1 modifies the European Standard EN 60598-2-13:2006; it was approved by CENELEC on 2012-01-11. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 34D/1009/CDV, future edition 1 of IEC 60598-2-13:2006/A1, prepared by SC 34D, "Luminaires", of IEC TC 34, "Lamps and related equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60598-2-13:2006/A1:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-10-11
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2015-01-11

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60598-2-13:2006/A1:2011 was approved by CENELEC as a European Standard without any modification.

STANDARD PREVIEW
(standards.iteh.ai)
SIST EN 60598-2-13:2007/A1:2012
<https://standards.iteh.ai/catalog/standards/sist/61456402-7b60-413e-b252-a1a2c3381dd2/sist-en-60598-2-13-2007-a1-2012>



IEC 60598-2-13

Edition 1.0 2011-12

INTERNATIONAL STANDARD

NORME INTERNATIONALE

AMENDMENT 1
AMENDEMENT 1

Luminaires – **iTeh STANDARD PREVIEW**
Part 2-13: Particular requirements – Ground recessed luminaires
(standards.iteh.ai)

Luminaires –
Partie 2-13: Règles particulières – Luminaires encastrés dans le sol
SIST EN 60598-2-13:2007/A1:2012
http://standards.iteh.ai/catalog/standards/sist/61450462-7680-413c-
b252-a1a2c3381dd2/sist-en-60598-2-13-2007-a1-2012

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

D

ICS 29.140.40

ISBN 978-2-88912-815-0

FOREWORD

This amendment has been prepared by subcommittee 34D: Luminaires, of IEC technical committee 34: Lamps and related equipment.

The text of this amendment is based on the following documents:

CDV	Report on voting
34D/1009/CDV	34D/1041/RVC

Full information on the voting for the approval of this amendment can be found in the report on voting indicated in the above table.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 60598-2-13:2007/A1:2012](https://standards.iteh.ai/catalog/standards/sist/61456402-7b60-413e-b252-a1a2c3381dd2/sist-en-60598-2-13-2007-a1-2012)

<https://standards.iteh.ai/catalog/standards/sist/61456402-7b60-413e-b252-a1a2c3381dd2/sist-en-60598-2-13-2007-a1-2012>

13.6.1 Resistance to static load

Replace the second sentence of the compliance criteria, including the three dashes, as follows:

The test load, to be maintained with a tolerance of $\pm 3\%$, shall be applied to the top side of the luminaire by a cylindrical steel punch equipped with a sheet of rubber in contact to the luminaire.

The punch shall have a diameter of 50 mm, or luminaire diameter D (see Figure 1) if smaller than 50 mm.

The thickness of the steel punch shall be 50 mm.

The rubber shall have the following characteristics:

- *hardness “shore A” (the hardness measured with the durometer type A) = 65 ± 5 ;*
- *thickness = 10 mm.*


iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 60598-2-13:2007/A1:2012

<https://standards.iteh.ai/catalog/standards/sist/61456402-7b60-413e-b252-a1a2c3381dd2/sist-en-60598-2-13-2007-a1-2012>

Figure 2 – Static load test apparatus

Replace the existing Figure 2 by the following new figure:

**Figure 2 – Static load test apparatus**