

INTERNATIONAL STANDARD

AMENDMENT 1

Automatic electrical controls –
Part 2-5: Particular requirements for automatic electrical burner control systems
(standards.iteh.ai)

[IEC 60730-2-5:2013/AMD1:2017](https://standards.iteh.ai/catalog/standards/sist/1791e676-7da2-4709-8875-f48c3774374c/iec-60730-2-5-2013-amd1-2017)

<https://standards.iteh.ai/catalog/standards/sist/1791e676-7da2-4709-8875-f48c3774374c/iec-60730-2-5-2013-amd1-2017>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2017 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch

IEC STANDARD PREVIEW
(standards.iec.ch)
IEC 60730-2:2015/AMD1:2017
48c3774374c/iec-60730-2:2015-amd1-2017

INTERNATIONAL STANDARD

AMENDMENT 1

Automatic electrical controls –
Part 2-5: Particular requirements for automatic electrical burner control systems

STANDARD PREVIEW
(standards.iteh.ai)
<https://standards.iteh.ai/catalog/standards/sist/1791e676-7da2-4709-8875-f48c3774374c/iec-60730-2-5-2013-amd1-2017>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 97.120

ISBN 978-2-8322-4747-1

Warning! Make sure that you obtained this publication from an authorized distributor.

FOREWORD

This amendment has been prepared by IEC technical committee 72: Automatic electrical controls.

The text of this amendment is based on the following documents:

| FDIS | Report on voting |
|--------------|------------------|
| 72/1084/FDIS | 72/1103/RVD |

Full information on the voting for the approval of this amendment can be found in the report on voting indicated in the above table.

The committee has decided that the contents of this amendment and the base publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW

A bilingual version of this publication may be issued at a later date.

[IEC 60730-2-5:2013/AMD1:2017](https://standards.iteh.ai/catalog/standards/sist/1791e676-7da2-4709-8875-f48c3774374c/iec-60730-2-5-2013-amd1-2017)

<https://standards.iteh.ai/catalog/standards/sist/1791e676-7da2-4709-8875-f48c3774374c/iec-60730-2-5-2013-amd1-2017>

1 Scope and normative references

Replace Subclause 1.1 by the following:

1.1 Scope

This part of IEC 60730 applies to automatic electrical **burner control systems** for the **automatic control** of burners for oil, gas, coal or other combustibles intended to be used

- for household and similar use,
- in shops, offices, hospitals, farms and commercial and industrial applications.

This International Standard is applicable

- to a complete **burner control system**,
- to a separate **programming unit**,
- to a separate electronic high-voltage **ignition source**,
- to a separate **flame detector** and
- to a separate **high-temperature operation (HTO) detector**.

NOTE 1 Throughout this document, where it can be used unambiguously, the word "system" means "burner control system" and "systems" means "burner control systems".

NOTE 2 Throughout this document, the word "equipment" means "appliance and equipment."

This standard does not apply to thermoelectric flame supervision controls; thermoelectric flame supervision controls are covered by ISO 23551-6.

This document also applies to electrical **burner control systems** intended exclusively for industrial process applications e.g. those applications covered by ISO TC 244 (ISO 13577).

1.1.1 This document applies to the inherent safety, to the declared **operating values**, **operating times** and **operating sequences** where such are associated with burner safety and to the testing of automatic electrical **burner control systems** used in, on, or in association with, burners.

NOTE Requirements for specific **operating values**, **operating times** and **operating sequences** are given in the standards for appliances and equipment.

1.1.2 This document applies to AC or DC powered systems with a rated voltage not exceeding 660 V AC or 600 V DC.

1.1.3 This document does not take into account the **response value** of an **automatic action** of a **control**, if such a **response value** is dependent upon the method of mounting the **control** in the equipment. Where a **response value** is of significant purpose for the protection of the **user**, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer applies.

1.1.4 This document applies also to systems incorporating **electronic devices**, requirements for which are contained in Annex H.

1.1.5 This document applies to systems using NTC or PTC thermistors, additional requirements for which are contained in Annex J.

1.1.6 This document includes systems responsive to flame properties and temperature for HTO.

Delete Subclauses 1.2, 1.3 and 1.4.

1.5 *Renumber this subclause as follows:*

1.2 Normative references

Delete reference to IEC 61643-11.

Add the following new references to the existing list:

IEC 60079-20-1:2010, *Explosive atmospheres – Part 20-1: Material characteristics for gas and vapour classification – Test methods and data*

ISO 23551-6:2014, *Safety and control devices for gas burners and gas-burning appliances – Part 6: Thermoelectric flame supervision controls*

Add the following instruction:

Replacement:

IEC 60127-1:2015, *Miniature fuses – Part 1: Definitions for miniature fuses and general requirements for miniature fuse-links*

2 Definitions

Replace the title of Clause 2 by the following:

2 Terms and definitions

Add, after 2.2 Definitions of types of control according to purpose, the following note:

NOTE Definition 2.2.23 is not applicable.

2.2.101 burner control system

Replace the existing definition by the following:

system which includes a **programming unit**, a **flame detector** or, if applicable, an **HTO detector** and may include an **ignition source** and/or **ignition device** and which monitors the **operation** of fuel burners

Note 1 to entry: The various functions of the system may be in one or more housings.

Add the following new terms and definitions:

2.2.108 HTO detector

device which provides the **programming unit** with a signal indicating presence or absence of **HTO**

Note 1 to entry: It includes the **HTO-sensor** and may include an amplifier and a relay for signal **transmission**. The amplifier and relay may be in its own housing or combined with the **programming unit**.

2.2.109 HTO-sensor

device which senses the temperature of a surface or a medium within the combustion chamber which is in direct contact with a flammable fuel-air mixture and provides a signal indicating presence or absence of **HTO**

2.2.110 auto-ignition temperature AIT

lowest temperature (of a hot surface or the environment) at which an ignition of a flammable fuel/air mixture occurs

[SOURCE: IEC 60079-20-1:2010,3.3, modified : "or the environment" has been added in the parenthesis, "at which under specified test conditions" has been deleted and " flammable gas or vapour in mixture with air or air/inert gas" has been replaced by " flammable fuel/air mixture"]

2.2.111 high-temperature operation HTO

operation on the basis of **auto-ignition temperature** which assures ignition and burning of fuel

Note 1 to entry: **High-temperature operation** is used e.g. in fuel cells (IEC 62282-3-100) and in industrial furnaces and associated processing equipment (ISO 13577) where ignition and burning is detected by means of sensing the temperature.

Add the following new definition 2.3.32:

2.3.32 safety shut-down

Replacement:

de-energization of the main fuel flow means as the result of the action of a limiter, a cut-out or the detection of an internal **fault** of the system

Note 1 to entry: **Safety shut-down** may include additional actions by the system.

2.3.107

Add "**flame failure response time**" below the term "**flame failure lock-out time**".

2.3.117

Add "**proved igniter system**" below the term "**proved igniter**".

2.3.121 running position

Replace the definition by the following:

position denoting that the main burner flame is established and supervised, or the burner is in **HTO** and supervised

2.3.122

Add "Void" after term number and delete the term and definition.

Add the following new terms and definitions:

2.3.132

HTO detector response time

period of time between the temperature falling below the defined temperature limit for **HTO** and the signal indicating the absence of **HTO**

2.3.133

HTO detector operating characteristics

that function of the **HTO detector** which indicates absence or presence of **HTO** as the output signal of the **HTO detector** relating to the input signal

Note 1 to entry: Normally the input signal is provided by a **HTO-sensor**.

2.3.134

HTO response time

period of time between the signal indicating absence of **HTO** and proceeding to **safety shut-down** or to switch over to flame supervision

2.3.135

HTO signal

output signal of the **HTO detector**

4 General notes on tests

4.2.1

Replace the word "inclusive" by the words "including the relevant annexes" in the third sentence between the words "Clauses 18 to 26" and "may" to read "the tests of Clauses 18 to 26 including the relevant annexes".

6 Classification

6.3 According to their purpose

Add the following subclauses:

6.3.107 – HTO detector;

6.3.108 – HTO-sensor.

6.11

In the note, replace “In the countries members of CENELEC” by “In member countries of CENELEC”.

7 Information

7.2.9

Table 1

Replace title of Table 1 on the first page by the following:

Table 1 (7.2 of edition 3) – **Required information and methods of providing information** (1 of 2)

Replace title of Table 1 on the second page by the following:

Table 1 (7.2 of edition 3) – **Required information and methods of providing information** (2 of 2)

In requirement 7, replace superscript “7)” by superscript “b” after “circuit”.

In requirement 15, replace superscript “8)” by superscript “c” after “enclosure”.

In requirement 31, replace superscript “5)” by superscript “e” after “component”.

In requirement 103, add “or Maximum flame failure response time”.

Add the following:

| | | | |
|-----|--|----------|---|
| 139 | The defined temperature limit for HTO | 11.3.114 | D |
| 140 | HTO detector response time | 11.3.114 | D |

10 Terminals and terminations

10.2.4.101 Direct plug-in connections

In the first sentence, replace “part 2-5” by “document”.

11 Constructional requirements

Delete subclauses 11.1 and 11.1.2.

Replace 11.3.5.2 by the following:

11.3.5.2 Systems of **class C control functions** shall include at least two switching elements to directly de-energize the safety relevant terminals.

NOTE 1 The **burner control system** is a **class C control function**.

NOTE 2 A single relay operating two independent contacts is considered to be only one switching element.

Designs where relays are used as switching elements, a non-replaceable fuse (see Table H.24 Note I) in series with two independent relay contacts with I_N fuse $< 0,6 * I_e$ relay, are considered to comply with the following requirements for prevention of common cause **failure**.

NOTE 3 I_N : values for the fuse (see IEC 60127-1:2015, 3.16);

I_e : rated operational current of the contact (see IEC 60947-1:2007; 4.3.2.3)

In Part 1, the term

- “safety related output terminals” is equivalent to “valve terminals”.
- “safety shut-down” shall be used as defined in this document,
- “control” shall be used as “burner control systems”.

11.3.5.2.1 Measures to protect against common cause failures

Delete this subclause.

11.3.108.6

In the first sentence, after “flame failure lock-out time”, add “or flame failure response time”.

Add the following new subclause:

11.3.114 For **controls** intended for **HTO** using **HTO-sensors**, the temperature shall be monitored. In the event the temperature falls below the defined temperature limit for **HTO**, the **control** shall proceed to **safety shut-down** or switch over to flame supervision (e.g. ionization, UV, IR etc.). This function (including sensor, detector and programming unit) shall be a **class C control function** with **type 2 action**.

The defined temperature limit for **HTO** (see Table 1, requirement 139) shall be the temperature value, which includes the auto-ignition temperature, given in IEC 60079-20-1 or otherwise specified by the product standard, and the tolerances of the signal processing circuit including the sensor.

11.4 Actions

11.4.3 Type 2 action

Replace the text of the replacement by the following:

Any **type 2 action** shall be so designed that the **manufacturing deviation** and **drift** of its **operating value**, **operating time** or **operating sequence** is within the limits declared in Table 1, requirements 46, 101 to 115 inclusive, 123 to 125 inclusive, 139 and 140.

11.101.4

Replace the existing text by the following:

An open circuit of the **flame sensor/HTO-sensor** or its connecting cables shall cause loss of the **flame signal/HTO-sensor signal**.

11.101.6

Delete the compliance statement after the first paragraph.

Add the following new subclause:

11.101.7 HTO-sensors shall only react to temperature.

NOTE For selecting the position of the **HTO-sensor** in the application, the effect of exposing it to radiant heat directly from the flame is taken into account.

Compliance with 11.101.1 to 11.101.7 inclusive is checked by inspection, test and/or measurement.

15 Manufacturing deviation and drift

15.1

Replace the existing text by the following:

Systems shall have adequate consistency of manufacture with regard to their declared **operating times, operating sequences, flame detector operating characteristics, HTO detector operating characteristics and proved igniter operating value**.

15.3

[IEC 60730-2-5:2013/AMD1:2017](https://standards.iec.ch/catalog/standards/sist/1791e676-7da2-4709-8875-f48c3774374c/iec-60730-2-5-2013-amd1-2017)

Replace the existing text by the following:

The appropriate **operating time, operating sequence, flame detector operating characteristics, HTO detector operating characteristics and proved igniter operating value** shall be recorded for the sample.

15.4

Replace the existing text by the following:

Three tests shall be conducted for each **operating time**, each operating sequence, **flame detector operating characteristics, HTO detector operating characteristics** and each **proved igniter operating value** declared.

15.5 Operating times

In the third paragraph, add the following to item c):

c) or flame failure response time;

Add the following new item t):

t) **HTO detector response time**.

15.7 Flame detector operating characteristics and proved igniter operating value

Replace the existing title and text by the following:

15.7 Flame detector operating characteristics, HTO detector operating characteristics and proved igniter operating value

The operating characteristics of **flame detectors**, **HTO detector** and **proved igniter operating value** shall be measured under the following conditions:

- a) at V_R and $(20 \pm 5) \text{ }^\circ\text{C}$;
- b) at $0,85 V_R$ and $0 \text{ }^\circ\text{C}$ or T_{\min} , whichever is lower, and
- c) at $1,1 V_R$ and $60 \text{ }^\circ\text{C}$ or T_{\max} , whichever is higher.

The measured values shall be as declared in Table 1 requirements 123, 124, 125, 132 and 139 as applicable.

The details of the measuring equipment shall be arranged between the manufacturer and the test house.

If a lamp is used for response to the visible range of light, it shall have a colour temperature of 2 856 K.

NOTE The preceding paragraph is not applicable in the USA and Canada.

17 Endurance

17.16.102.1 Test sequence and conditions

In the second paragraph, after "flame detector" add "and/or HTO detector".

After the second paragraph, add the following:

The HTO function, if applicable shall be included in the sequence.

17.16.108 Evaluation of compliance

Replace the first paragraph by the following:

*After completion of all applicable tests of 17.16.101 to 17.16.107 inclusive, the sample shall be retested according to Clause 15. The **operating times, operating sequence, flame detector operating characteristics, HTO detector operating characteristics and proved igniter operating value** shall be as declared in Table 1.*

23 Electromagnetic compatibility (EMC) requirements – emission

In the title, replace "emission" by "Emission".

26 Electromagnetic compatibility (EMC) requirements – immunity

In the title, replace "immunity" by "Immunity".

Annex H – Requirements for electronic controls

Add the following new clause: