

INTERNATIONAL STANDARD

Sound system equipment –
Part 4: Microphones

iteh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60268-4:2018](#)

<https://standards.iteh.ai/catalog/standards/iec/da163510-25f9-4250-9bc4-b8400005ed72/iec-60268-4-2018>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2018 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 21 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

[IEC 60268-4:2018](https://standards.iteh.ai/catalog/standards/iec/da163510-2519-4250-9bc4-b8400005ed72/iec-60268-4-2018)

<https://standards.iteh.ai/catalog/standards/iec/da163510-2519-4250-9bc4-b8400005ed72/iec-60268-4-2018>



IEC 60268-4

Edition 6.0 2018-09

INTERNATIONAL STANDARD

Sound system equipment –
Part 4: Microphones

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

[IEC 60268-4:2018](#)

<https://standards.itih.ai/catalog/standards/iec/dal63510-25f9-4250-9bc4-b8400005ed72/iec-60268-4-2018>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.160.50

ISBN 978-2-8322-5955-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references.....	8
3 Terms and definitions	9
4 General conditions.....	10
4.1 General.....	10
4.2 Measurement conditions.....	10
4.2.1 General	10
4.2.2 Rated conditions	11
5 Particular conditions	12
5.1 Pre-conditioning.....	12
5.2 Sound source.....	12
5.3 Measurement of sound pressure.....	12
5.4 Voltage measuring system.....	12
5.5 Acoustical environment	12
5.5.1 General	12
5.5.2 Free-field conditions.....	13
5.5.3 Diffuse field conditions.....	14
5.5.4 Microphone coupled to a sound source by means of a small cavity coupler	15
5.6 Methods of measuring frequency response	15
5.6.1 Point-by-point and continuous sweep frequency methods.....	15
5.6.2 Calibration methods	16
5.7 Overall accuracy	16
5.8 Graphical presentation of results	16
6 Type description (acoustical behaviour)	17
6.1 Principle of the transducer.....	17
6.2 Type of microphone.....	17
6.3 Type of directional response characteristics.....	17
6.4 Application	17
7 Terminals and controls.....	17
7.1 Marking.....	17
7.2 Connectors and electrical interface values	17
8 Reference point and axis	18
8.1 Reference point.....	18
8.2 Reference axis	18
9 Rated power supply	18
9.1 Characteristics to be specified	18
9.2 Method of measurement.....	18
10 Electrical impedance.....	18
10.1 Internal impedance.....	18
10.1.1 Characteristic to be specified	18
10.1.2 Methods of measurement	18
10.2 Rated impedance	19
10.3 Rated minimum permitted load impedance.....	19

11	Sensitivity.....	19
11.1	General.....	19
11.2	Sensitivities with respect to acoustical environment	20
11.2.1	Free-field sensitivity	20
11.2.2	Diffuse-field sensitivity	21
11.2.3	Close-talking and near-field sensitivity.....	21
11.2.4	Pressure sensitivity.....	22
11.3	Rated sensitivity.....	22
12	Response.....	22
12.1	Frequency response.....	22
12.1.1	Characteristic to be specified	22
12.1.2	Method of measurement.....	23
12.1.3	Graphical presentation of results	23
12.2	Effective frequency range.....	23
12.2.1	Characteristic to be specified	23
12.2.2	Method of measurement.....	23
13	Directional characteristics	23
13.1	Directional pattern.....	23
13.1.1	Characteristic to be specified	23
13.1.2	Methods of measurement	24
13.1.3	Graphical presentation of results	25
13.2	Directivity index.....	25
13.2.1	Characteristic to be specified	25
13.2.2	Method of measurement.....	25
14	Amplitude non-linearity	25
14.1	General.....	25
14.2	Total harmonic distortion	25
14.2.1	Characteristic to be specified	25
14.2.2	Method of measurement.....	26
14.3	Harmonic distortion of the n^{th} order ($n = 2, 3, \dots$)	26
14.3.1	Characteristic to be specified	26
14.3.2	Method of measurement.....	26
14.4	Difference frequency distortion of second order	27
14.4.1	Characteristic to be specified	27
14.4.2	Method of measurement.....	27
15	Limiting characteristics	28
15.1	Rated maximum permissible peak sound pressure	28
15.2	Overload sound pressure	28
15.2.1	Characteristic to be specified	28
15.2.2	Method of measurement.....	28
16	Balance.....	28
16.1	Balance of the microphone output.....	28
16.2	Balance under working conditions.....	29
17	Equivalent sound pressure level due to inherent noise.....	29
17.1	Characteristic to be specified	29
17.2	Method of measurement.....	29
18	Ambient conditions	30
18.1	General.....	30

18.2	Pressure range	30
18.3	Temperature range.....	30
18.4	Relative humidity range.....	30
19	External influences	30
19.1	General.....	30
19.1.1	Specification and methods of measurement.....	30
19.1.2	Other external interferences	31
19.2	Equivalent sound pressure due to mechanical vibration.....	31
19.2.1	Characteristic to be specified	31
19.2.2	Method of measurement.....	31
19.3	Equivalent sound pressure due to wind.....	31
19.3.1	Characteristic to be specified	31
19.3.2	Method of measurement.....	32
19.4	Transient equivalent sound pressure due to "pop" effect	35
19.4.1	General	35
19.4.2	Characteristic to be specified	35
19.4.3	Method of measurement.....	36
20	Electromagnetic compatibility (EMC).....	37
20.1	Regulatory requirements	37
20.2	Requirements for preserving programme quality	37
20.3	Performance criteria.....	38
20.3.1	Criterion A.....	38
20.3.2	Criterion B.....	38
20.4	Testing for immunity to disturbances in the presence of acoustical noise	39
20.5	Immunity to frequency-modulated radiated disturbances	39
20.6	Immunity to magnetic fields	39
20.7	Immunity to ripple on d.c. power supply	39
20.8	Permanent magnetic field.....	40
20.9	Evaluation and reporting of the test results	40
21	Physical characteristics	40
21.1	Dimensions	40
21.2	Weight.....	40
21.3	Cables and connectors.....	40
22	Classification of the characteristics to be specified	40
Annex A	(normative) Additional characteristics	43
A.1	Characteristic sensitivity for speech.....	43
A.1.1	Characteristic to be specified	43
A.1.2	Method of measurement.....	43
A.2	Front-to-rear sensitivity index (0° – 180°).....	44
A.2.1	Characteristic to be specified	44
A.2.2	Method of measurement.....	44
A.3	Noise-cancelling index	44
A.3.1	Characteristic to be specified	44
A.3.2	Method of measurement.....	44
A.4	Special characteristics for stereo microphones.....	45
A.4.1	General	45
A.4.2	Included angle of an XY (left-right) microphone.....	45
A.4.3	Acceptance angle	45

Annex B (informative) Sound insulation device	46
Annex C (informative) Recommendations for professional digital microphones	47
C.1 General.....	47
C.2 Data sheets for digital microphones.....	47
Annex D (informative) Recommended method for measuring noise levels according to ITU-R BS.468-4 in the digital domain	50
D.1 General.....	50
D.2 Recommended method.....	50
D.3 Matlab code	51
Bibliography	54
Figure 1 – Balance of the output	28
Figure 2 – Balance under working conditions.....	29
Figure 3 – Measurement set-up for wind influence	32
Figure 4 – Wind generators, type 1 (Figure 4a) and type 2 (Figure 4b).....	34
Figure 5 – Electrical and mechanical setup for the measuring of the "pop" effect.....	36
Figure B.1 – Sound insulation device	46
Figure D.1 – ITU weighting filter for weighted and unweighted measurements.....	50
Figure D.2 – Peak value rectifier scheme	51
Table 1 – Reverberation time of the empty room.....	15
Table 2 – Examples of EMC regulations and standards.....	37
Table 3 – Basic EMC standards and their application to microphones	38
Table 4 – Classification of characteristics.....	41
Table A.1 – Speech power weighting factor at octave-band centre frequencies	43
Table C.1 – Classification of the characteristics recommended to be specified	47
Table C.2 – Additional digital characteristics to be specified	49
Table D.1 – Time constants for the two PVRs.....	51

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SOUND SYSTEM EQUIPMENT –

Part 4: Microphones

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60268-4 has been prepared by IEC technical committee 100: Audio, video and multimedia systems and equipment.

This sixth edition cancels and replaces the fifth edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Subclause 19.4 on "pop" measurement replaces Annex C;
- b) new Annex D for noise measurements in the digital domain.

The text of this International Standard is based on the following documents:

CDV	Report on voting
100/2992/CDV	100/3109/RVC

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60268 series, under the general title *Sound system equipment*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60268-4:2018](#)

<https://standards.iteh.ai/catalog/standards/iec/da163510-25f9-4250-9bc4-b8400005ed72/iec-60268-4-2018>

SOUND SYSTEM EQUIPMENT –

Part 4: Microphones

1 Scope

This part of IEC 60268 specifies methods of measurement for the electrical impedance, sensitivity, directional response pattern, dynamic range and external influences of sound system microphones, and also details the characteristics to be specified by the manufacturer.

It applies to sound system microphones for all applications for speech and music. It does not apply to measurement microphones, but it does apply to each audio channel of microphones having more than one channel, for example for stereo or similar use. It is also applicable to flush-mounted microphones and to the analogue characteristics of microphones with digital audio output.

For the purposes of this International Standard, a microphone includes all such devices as transformers, pre-amplifiers, or other elements that form an integral part of the microphone, up to the output terminals specified by the manufacturer.

The major characteristics of a microphone are considered in Clauses 6 to 21. Additional characteristics are considered in Annex A and Annex C.

NOTE The characteristics specified in this document do not describe the subjective response of the microphone. Further work is necessary to find new definitions and measurement procedures for a later introduction of objective characteristics for at least some of the subjective descriptions used to describe microphone performance.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CISPR 35:2016, *Electromagnetic compatibility of multimedia equipment – Immunity requirements*

IEC 60268-1:1985, *Sound system equipment – Part 1: General*
IEC 60268-1:1985/AMD1:1988
IEC 60268-1:1985/AMD2:1988

IEC 60268-2:1987, *Sound system equipment – Part 2: Explanation of general terms and calculation methods*
IEC 60268-2:1987/AMD1:1991

IEC 60268-3:2013, *Sound system equipment – Part 3: Amplifiers*

IEC 60268-5:2003, *Sound system equipment – Part 5: Loudspeakers*
IEC 60268-5:2003/AMD1:2007

IEC 60268-11:1987, *Sound system equipment – Part 11: Application of connectors for the interconnection of sound system components*
IEC 60268-11:1987/AMD1:1989
IEC 60268-11:1987/AMD2:1991

IEC 60268-12:1987, *Sound system equipment – Part 12: Application of connectors for broadcast and similar use*

IEC 60268-12:1987/AMD1:1991

IEC 60268-12:1987/AMD2:1994

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3:2006, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-3:2006/AMD1:2007

IEC 61000-4-3:2006/AMD2:2010

IEC 61000-4-4:2012, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-6:2013, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-8:2009, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-16:2015, *Electromagnetic compatibility (EMC) – Part 4-16: Testing and measurement techniques – Test for immunity to conducted, common mode disturbances in the frequency range 0 Hz to 150 kHz*

IEC 61000-4-17:1999, *Electromagnetic compatibility (EMC) – Part 4-17: Testing and measurement techniques – Ripple on d.c. input power port immunity test*

61000-4-17:1999/AMD1:2001

61000-4-17:1999/AMD2:2008

<https://standards.iteh.ai/>

IEC 61260-1:2014, *Electroacoustics – Octave-band and fractional-octave-band filters – Part 1: Specifications*

IEC 61938:2013, *Multimedia systems – Guide to the recommended characteristics of analogue interfaces to achieve interoperability*

ITU-T Recommendation P.51:1996, *Artificial mouth*

EN 55103-2:2009, *Electromagnetic compatibility – Product family standard for audio, video, audio-visual and entertainment lighting control apparatus for professional use – Part 2: Immunity*

EN 300 422-2 V1.3.1:2011, *Electromagnetic compatibility and radio spectrum matters (ERM) – Wireless microphones in the 25 MHz to 3 GHz frequency range – Part 2: Harmonized EN covering the essential requirements of article 3.2 of the R&TTE Directive*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60268-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>

- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

far-field microphone

microphone for use mainly at a distance of 1 m or more from the source of sound

Note 1 to entry: The term "far-field microphone" describes a microphone application (see 6.4) and not a type of microphone. A specific microphone may have one or more applications, but the term is helpful in specifying the method of measurement.

3.2

near-field microphone

microphone for use by an individual performer at a distance of approximately 30 cm

Note 1 to entry: The term "near-field microphone" describes a microphone application (see 6.4) and not a type of microphone. A specific microphone may have one or more applications, but the term is helpful in specifying the method of measurement.

3.3

close-talking microphone

microphone for use at a distance of approximately 25 mm from the source of sound

Note 1 to entry: The term "close-talking microphone" describes a microphone application (see 6.4) and not a type of microphone. A specific microphone may have one or more applications, but the term is helpful in specifying the method of measurement.

4 General conditions

4.1 General

Special reference is made to IEC 60268-1, concerning:

- units and system of measurement;
- frequencies of measurement;
- quantities to be specified and their accuracy (see also 5.7);
- marking (see also 7.1);
- ambient conditions;
- filters, networks and measuring instruments for noise specification and measurement;
- individual specifications and type specifications;
- graphical presentation of characteristics;
- scales for graphical presentation;
- personal safety and prevention of spread of fire;
- method of producing a uniform alternating magnetic field;
- search coils for measuring the magnetic field strength,

and to IEC 61938 concerning powering of microphones.

4.2 Measurement conditions

4.2.1 General

For convenience in specifying how microphones shall be set up for measurement, three sets of conditions have been defined in this document, under the title of "rated conditions".

Microphones should be measured in conditions approximating those in which they are intended to be used. Three sets of measurement conditions are specified in this document: free-field, near-field and close-talking. The differences between these sets of conditions are in

the distance to the sound source and the sound pressure level of the measurement. Measurements shall be reported using at least one of these sets of conditions. Additional data may be included, provided that the measurement conditions are specified.

Three ratings are basic to the formulation of these concepts:

- rated power supply (see 9.1);
- rated impedance (see 10.2);
- rated sensitivity (see 11.3).

To obtain the correct conditions for measurement, the above-mentioned ratings shall be taken from the specifications supplied by the manufacturer of the equipment.

The term "rated" applied to other characteristics relates to the specification or measurement of the particular characteristic under rated conditions or under conditions unambiguously connected to them. This applies, for example, to the following two characteristics:

- rated output voltage;
- rated equivalent sound pressure level due to inherent noise.

Methods of measurement are given in this document for electrical impedance, sensitivity, directional pattern, dynamic range and external influences. Where alternative methods are given, the chosen method shall be specified.

4.2.2 Rated conditions

The microphone is understood to be working under rated conditions when the following conditions are fulfilled:

- the microphone is connected to the resistive load specified in 5.4, or as specified by the manufacturer;
- if the microphone needs a power supply, this is the rated power supply;
- the microphone (except a close-talking or near-field microphone) is placed in a sound field meeting the free-field conditions in 5.5.2, the waves having zero-degree incidence with respect to the reference direction;
- far-field microphones shall be measured in free-field conditions;
- the undisturbed sound pressure (in the absence of the microphone) in the sound field at the reference point of the microphone is sinusoidal and set at a level of 1 Pa (94 dB SPL);
- for close-talking microphones, the microphone is placed at a stated distance, no more than 25 mm from the artificial mouth complying with ITU-T Recommendation P.51, and the undisturbed sound pressure in the sound field at the reference point of microphone is sinusoidal and set at a level of 3 Pa (104 dB SPL);
- for near-field microphones, the microphone is placed at 30 cm from the artificial mouth complying with ITU-T Recommendation P.51, and the undisturbed sound pressure in the sound field at the reference point of microphone is sinusoidal and set at a level of 1 Pa (94 dB SPL);
- if a special microphone needs a different measurement level or procedure (e.g. Lavalier or boundary layer microphones), it shall be stated in the technical data together with the reason for this. Levels related to the normal reference level of 94 dB by multiples of 10 dB are preferred;
- controls, if any, are set to the position recommended by the manufacturer;
- in the absence of a clear reason to the contrary, the measurement frequency is 1 000 Hz (see IEC 60268-1);
- the ambient pressure, relative humidity and ambient temperature are within the limits given in IEC 60268-1, and shall be stated.

Measurements may be made at a sound pressure of 0,3 Pa if this is necessary due to limitations of the performance of the loudspeaker or other measurement equipment, and only if any change in performance between the level used and the reference level is known with the necessary accuracy for the relevant characteristics.

5 Particular conditions

5.1 Pre-conditioning

A microphone with preamplifier shall be switched on for the period of time specified by the manufacturer, before measurements are made, to allow the components to reach the stationary temperature for rated conditions. If the manufacturer specifies no period, a period of 10 s shall be allowed for stabilization. If the microphone contains a vacuum tube or other heating device the time shall be 10 min.

5.2 Sound source

The sound source shall be capable of producing at the microphone position the sound pressure level as defined for rated conditions. The amplitude non-linearity of the sound source shall be held to such a value that the effect on the measured response does not exceed 0,5 dB. If the conditions of measurement preclude the possibility of securing sufficiently low distortion, a narrow-band filter may be used at the microphone output terminals, which allows the response at the fundamental frequency to be measured.

For free-field calibration and calibration of near-field microphones, the sound source shall be contained in an enclosure which radiates sound from one well-defined opening fulfilling the sound field requirements, preferably by only one being radially symmetrical with respect to the axis of the reference direction of the microphone.

5.3 Measurement of sound pressure

A calibrated reference pressure microphone shall be used to measure the sound pressure. The reference microphone shall be calibrated with an accuracy of ± 1 dB at 1 kHz or better.

5.4 Voltage measuring system

The voltage generated by the microphone, when in a sound field, shall be determined by using a voltmeter with an input resistance negligible to the specified microphone load. This load is five times the rated impedance of the microphone, unless otherwise stated by the manufacturer. If external equipment, such as a power supply, applies an impedance in parallel with the microphone, its impedance shall be taken into account.

NOTE Microphones having a rated impedance of 200 Ω often have an actual internal impedance in the order of 50 Ω , and many of them perform best with a minimum load impedance around 1 000 Ω .

5.5 Acoustical environment

5.5.1 General

The microphone can be measured in different acoustical environments:

- a) in a free field or similar with negligible boundary effects, e.g. by using special computer-generated sound source signals:
 - spherical waves, or
 - plane waves, or
 - waves produced by a specific sound source (artificial mouth or artificial head);
- b) in a diffuse field;
- c) coupled to a sound source by means of a small cavity (coupler).