



Designation: D 924 – 99^{ε2}

Standard Test Method for Dissipation Factor (or Power Factor) and Relative Permittivity (Dielectric Constant) of Electrical Insulating Liquids¹

This standard is issued under the fixed designation D 924; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

ε¹ NOTE—Editorial corrections were made in February 2003.

1. Scope

1.1 This test method covers new electrical insulating liquids as well as liquids in service or subsequent to service in cables, transformers, oil circuit breakers, and other electrical apparatus.

1.2 This test method provides a procedure for making referee tests at a commercial frequency of between 45 and 65 Hz.

1.3 Where it is desired to make routine determinations requiring less accuracy, certain modifications to this test method are permitted as described in Sections 19 to 27.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and to determine the applicability of regulatory limitations prior to use.* Specific warnings are given in 14.4.2.

2. Referenced Documents

2.1 ASTM Standards:

D 150 Test Methods for AC Loss Characteristics and Permittivity (Dielectric Constant) of Solid Electrical Insulating Materials²

D 923 Test Method for Sampling Electrical Insulating Liquids³

D 2864 Terminology Relating to Electrical Insulating Liquids and Gases³

E 145 Specification for Gravity-Convection and Forced-Ventilation Ovens⁴

2.2 Other Standard:

IEC 247–1978 Measurement of Relative Permittivity, Dielectric Dissipation Factor (Tan δ) and DC Resistivity of Insulating Liquids⁵

3. Terminology

3.1 Definitions—Definitions of terms used in this test method are given in Terminology D 2864D 2864.

4. Significance and Use

4.1 *Dissipation Factor (or Power Factor)*—This is a measure of the dielectric losses in an electrical insulating liquid when used in an alternating electric field and of the energy dissipated as heat. A low dissipation factor or power factor indicates low ac dielectric losses. Dissipation factor or power factor may be useful as a means of quality control, and as an indication of changes in quality resulting from contamination and deterioration in service or as a result of handling.

4.1.1 The loss characteristic is commonly measured in terms of dissipation factor (tangent of the loss angle) or of power factor (sine of the loss angle) and may be expressed as a decimal value or as a percentage. For decimal values up to 0.05, dissipation factor and power factor values are equal to each other within about one part in one thousand. In general, since the dissipation factor or power factor of insulating oils in good condition have decimal values below 0.005, the two measurements (terms) may be considered interchangeable.

4.1.2 The exact relationship between dissipation factor (*D*) and power factor (*PF*) is given by the following equations:

$$PF = \frac{D}{\sqrt{1 + D^2}} \quad D = \frac{PF}{\sqrt{1 - (PF)^2}} \quad (1)$$

The reported value of *D* or *PF* may be expressed as a decimal value or as a percentage. For example:

⁵ Available from American National Standards Institute, 25 W. 43rd St., 4th Floor, New York, NY 10036.

¹ This test method is under the jurisdiction of ASTM Committee D27 on Electrical Insulating Liquids and Gases and is the direct responsibility of Subcommittee D27.05 on Electrical Test.

Current edition approved Oct. 10, 1999. Published December 1999. Originally published as D 924 – 47 T. Last previous edition D 924 – 92.

² *Annual Book of ASTM Standards*, Vol 10.01.

³ *Annual Book of ASTM Standards*, Vol 10.03.

⁴ *Annual Book of ASTM Standards*, Vol 14.02.

D or PF at $25^{\circ}C = 0.002$ or 0.2% (2)

4.2 *Relative Permittivity (Dielectric Constant)*—Insulating liquids are used in general either to insulate components of an electrical network from each other and from ground, alone or in combination with solid insulating materials, or to function as the dielectric of a capacitor. For the first use, a low value of relative permittivity is often desirable in order to have the capacitance be as small as possible, consistent with acceptable chemical and heat transfer properties. However, an intermediate value of relative permittivity may sometimes be advantageous in achieving a better voltage distribution of a-c electric fields between the liquid and solid insulating materials with which the liquid may be in series. When used as the dielectric in a capacitor, it is desirable to have a higher value of relative permittivity so the physical size of the capacitor may be as small as possible.

NOTE 1—See Terminology D 2864D 2864 for further definitions.

5. General Considerations

5.1 Measuring equipment used in these procedures shall be in accordance with Test Methods D 150D 150.

5.2 Theory relating to dielectric measurement techniques and to the sources of dielectric loss is given in Test Methods D 150D 150.

6. Sampling

6.1 Sample electrical insulating liquids in accordance with Test Methods D 923D 923. Samples to be subjected to this test should preferably be obtained through a closed system. If exposed to atmospheric conditions, it is preferable to take the sample when the relative humidity is 50 % or less. If it is not feasible, the length of time the sample is exposed to atmospheric conditions must be kept to a minimum.

6.2 Some liquids, in certain applications, require special handling and processes in the sampling, and these will be found in the governing procedures. Consult such procedures before samples are taken. The relative humidity should be taken at the time of sampling and recorded with the sample identification.

6.3 The quantity of sample taken for this test shall be sufficient for at least three separate determinations of loss characteristics and relative permittivity.

6.4 The loss characteristic measurement (dissipation factor or power factor) may be affected by contamination introduced during sampling and subsequent handling.

7. Conditioning and Storing Sample

7.1 Store the sample in its original sealed container, shielded from either natural or artificial light. Some liquids, such as oils of petroleum origin, undergo changes when exposed to sunlight. Allow the sealed container to stand undisturbed in the room in which the test is to be made for a sufficient period of time to permit the sample to attain room temperature before it is opened.

8. Storing Test Cell

8.1 When not in use, clean and dry the test cell in accordance with Section 13 and store in a dust-free cabinet until

ready for use, at which time clean and dry the cell again in accordance with Section 13.

PROCEDURE FOR MAKING REFEREE TESTS

9. Test Cells

9.1 The design of test cells that conform to the general requirements given in the Annex are considered suitable for use in making these tests.

9.2 *Automatic Thermo-Regulator Cell:*

9.2.1 When tests are to be made above room temperature but below the flash point, an automatic thermo-regulator cell can be used as long as it provides uniform heating of the test cell.

9.2.2 The automatic thermo-regulator cell must be able to provide rapid, controlled rate of temperature rise, and be able to maintain a liquid temperature constant to within $\pm 1^{\circ}C$.

10. Apparatus

10.1 *Forced-Draft Oven:*

10.1.1 When the tests are to be made above room temperature, a suitable forced-draft, thermostatically controlled oven shall be used as the test chamber. The oven must be capable of meeting the temperature requirements set out in Section 14. For tests at room temperature the unheated oven can be conveniently used as the test chamber.

10.1.2 Provide the test chamber with an opening in the wall through which two lengths of TFE-fluorocarbon-insulated (or similar) shielded cable pass to make electrical connection from the measuring equipment and high-voltage transformer, respectively, to the test cell. Use a perforated ceramic plate or disk to insulate the test cell from the metal flooring of the oven if the flooring is not insulated from the oven. Provide a safety interlock on the door of the oven so that the electrical circuit supplying voltage to the test cell will be broken when the oven door is opened.

10.1.3 A cross-sectional view of the test chamber with a three-electrode test cell in place and with test cables connected is shown in Fig. 1.

11. Test Temperature

11.1 The temperature at which a referee test is made shall be mutually agreed upon between the purchaser and the seller. Measurements are made at many different temperatures. For acceptance tests, it is generally made at a temperature of $100^{\circ}C$, while for routine testing it is usually made at room temperature, 85 or $100^{\circ}C$. In some research investigations, tests may be made at considerably higher temperatures while in other cases, particularly for tests on cable oils in service, tests may be made over a range of temperatures.

12. Test Voltage

12.1 The average stress to which the specimen is subjected shall not be less than 200 V/mm (5 V/mil) (rms). Tests at higher stresses are desirable but shall not reach such values that electrical discharges across the cell insulating surfaces occur or that internal ionization of the specimen may be expected. Stress ranges in normal usage for referee tests are 200 to 1200 V/mm (5 to 30 V/mil) (rms).




FIG. 1 Test Set-Up for Dissipation Factor Measurements at Elevated Temperatures Using Three-Electrode Test Cell

12.2 Because the ac loss characteristics can vary with voltage stress, for reference purposes it is desirable to make the measurements at a specific value of voltage stress within the limits in 12.1.

12.3 Referee tests should be carried out in the frequency range 45–65 Hz.

13. Cleaning Test Cell

13.1 The cleanliness of the test cell is of paramount importance when measuring loss characteristics because of the inherent susceptibility of most insulating liquids to contaminating influences of the most minute nature. For this reason, clean and dry the cell immediately prior to making the test, and strictly observe the procedures and precautions outlined in 13.2 to 13.5.

13.2 Dismantle the cell completely and wash all the component parts thoroughly with a technical grade of a suitable solvent (such as acetone, pentane, petroleum ether, or heptane). Wash the component parts with a mild abrasive soap or detergent. Take care not to lay the electrodes on any surface. Rinse all parts thoroughly with hot tap water, then with cold tap water, followed by several rinsings with distilled water. Take extreme care during the washing and rinsing of some test cells to prevent any moisture from entering the thermometer well in the inner electrode. As a precaution against this eventuality, use a suitable stopper to plug this opening prior to starting the cleaning operation.

13.3 After the surfaces of the measuring, guard, and high voltage electrodes have been washed, do not touch these surfaces during the rinsing or any subsequent operation.

13.4 Place the component parts of the test cell in an oven maintained at 110°C for a period of not less than 60 min. Do not dry test cells made of Monel at this elevated temperature for more than 90 min as oxidation will take place causing

erroneous results. Take care that the surfaces on which the component parts of the cell are placed in the oven are clean.

13.5 At the expiration of the drying period, assemble the cell in the oven, using clean cotton gloves as protection for the hands and observing the precaution given in 13.3.

13.6 If using a forced-draft oven, quickly transfer the assembled test cell to the test chamber maintained at a temperature of above the desired test temperature and allow the cell to attain temperature equilibrium. The exact temperature will depend on both the oven and cell design. The test chamber shall be such that when the test specimen, preheated to 2°C below the test temperature, is transferred to the cell, the test temperature is attained and maintained within 20 min. If using an automatic thermo-regulator cell, follow 14.5.

14. Preparation of Specimen and Filling Test Cell

14.1 Use only a three-terminal cell for these tests.

14.2 When insulating liquids are heated to elevated temperatures, some of their characteristics undergo a change with time and the change, even though of the minutest nature, may be reflected in the loss measurement. It is therefore desirable that the elapsed time necessary for the test specimen to attain temperature equilibrium with the test cell be held to a minimum. For optimum procedure do not exceed 20 min for this time. It is essential, therefore, that the procedure outlined in 14.3, 14.4.1 through 14.4.3, or 14.5.1 through 14.5.4 be closely followed.

14.3 In order that representative test specimens may be obtained, gently tilt or invert the sample container and swirl the liquid several times. Immediately after mixing the sample, pour a quantity of liquid sufficient for four fillings of the test cell into a chemically clean, dry beaker and heat on a hot plate to a temperature 2°C below the desired test temperature. During the heating period, stir the fluid frequently.