

INTERNATIONAL STANDARD



Power transformers –
Part 11: Dry-type transformers

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60076-11:2018](https://standards.iteh.ai/catalog/standards/iec/4f01aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018)

<https://standards.iteh.ai/catalog/standards/iec/4f01aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018>





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2018 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 21 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

[IEC 60076-11:2018](https://standards.iteh.ai/catalog/standards/iec/4f01aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018)

<https://standards.iteh.ai/catalog/standards/iec/4f01aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018>



IEC 60076-11

Edition 2.0 2018-08
REDLINE VERSION

INTERNATIONAL STANDARD



Power transformers –
Part 11: Dry-type transformers

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60076-11:2018](https://standards.iteh.ai/catalog/standards/iec/4f01aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018)

<https://standards.iteh.ai/catalog/standards/iec/4f01aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.180

ISBN 978-2-8322-5967-2

Warning! Make sure that you obtained this publication from an authorized distributor.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

IEC 60076-11
Edition 2.0 2018-08

POWER TRANSFORMERS –

Part 11: Dry-type transformers

INTERPRETATION SHEET 1

This interpretation sheet has been prepared by IEC technical committee 14: Power transformers.

The text of this interpretation sheet is based on the following documents:

DISH	Report on voting
14/1052/DISH	14/1054/RVDISH

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

[IEC 60076-11:2018](https://standards.iteh.ai/catalog/standards/iec/4f01aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018)

<https://standards.iteh.ai/catalog/standards/iec/4f01aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018>

14.3.2 Temperature-rise test

Question

The independent certification body in Poland "Instytut Energetyki" carries out the testing of transformers or its inspectors witness this testing at the manufacturers' premises. The description of resistance measurement during the temperature rise test has caused a dispute between a manufacturer and the inspector on where exactly the resistance should be measured. The inspector requested that the resistance be measured on "winding lead exits" inside the enclosure, while the manufacturer argued for the measurement to be made on "winding terminals" which in its opinion were the bushings on the enclosure cover.

Subclause 14.3.2.1 General, states:

The winding temperature rise shall be established by the rise in resistance method or by superposition method. For the determination of the average winding temperature rise the measured temperatures of the cooling air or of the water intake of the cooling equipment shall be used.

For three-phase transformers, the resistance measurements shall be made between the central and an outer phase line terminals.

NOTE When the temperature rise is performed it is advisable to measure the windings resistance close to the windings.

Where should the measurements be made?

Interpretation

Testing of the winding resistance at transformer terminals (bushings) includes leadwork or busbars and often also multiple connections. Because of this, the tested winding resistance and its change due to heating is affected by the resistance of all these leads and connections. Consequently, the derived winding temperature rise if measured at the transformer terminals could be lower than if the winding resistance were tested directly on the winding lead exits. That is why the standard suggests (in the NOTE) that measurement of the windings' resistance be carried out close to the windings. That way, the accuracy of the indirect winding temperature measurement by resistance is higher.

In the case of dry-type transformers without enclosures, it is possible to have access close to the winding lead exits and not only to the transformer line terminals. Therefore, measurements shall normally be made at such locations.

On the other hand, if the dry-type transformer is equipped with an enclosure, the resistance measurement close to the winding lead exits requires opening the enclosure to have access to carry out the test (hence, affecting the normal cooling efficiency of the unit). Nevertheless, the advice to measure the resistance normally close to the winding lead exits holds. Limiting the enclosure opening by using special through elements for the cabling and/or by closing the required opening by temporary means as well as possible will minimize the impact on the normal cooling efficiency.

CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references.....	8
3 Terms and definitions	9
4 Service conditions	10
4.1 General.....	10
4.2 Normal service conditions	10
4.3 Electromagnetic compatibility (EMC).....	12
5 Rating and general requirements	12
5.1 General.....	12
5.2 Rated power	12
5.2.1 General	12
5.2.2 Operation Definition of the rated power with fans cooling or heat exchangers	13
5.2.3 Transformer IP00 (without enclosure).....	13
5.2.4 Operation in an Transformer with enclosure.....	13
5.2.5 Preferred values of rated power.....	14
5.2.6 Loading beyond rated power	14
5.3 Provision for unusual service conditions	14
5.4 Transportation and storage conditions	15
5.4.1 Transport limitation	15
5.4.2 Transport acceleration	15
5.4.3 Temperature and environment conditions for transport and storage.....	15
5.5 Rated voltage and rated frequency	15
5.5.1 Rated voltage	15
5.5.2 Rated frequency.....	16
5.6 Operation at higher than rated voltage.....	16
5.7 Highest voltage for equipment U_m and dielectric tests levels.....	16
5.8 Identification according to cooling method	16
5.8.1 General	16
5.8.2 Identification symbols.....	16
5.8.3 Arrangement of symbols.....	17
5.9 Guaranteed temperature rise at rated conditions.....	17
5.10 Additional information required for enquiry.....	17
5.11 Sound level.....	17
5.12 Components and materials	17
6 Tappings	17
7 Connections	18
8 Ability to withstand short circuit.....	18
9 Rating plate.....	18
9.1 Rating plate fitted to the transformer.....	18
9.2 Rating plate fitted to the transformer enclosure.....	19
10 Temperature-rise limits	19
10.1 Normal temperature-rise limits.....	19

10.2	Reduced temperature rises for transformers designed for high cooling-air medium temperatures or special-air cooling medium conditions	20
10.3	High altitude temperature rise correction	20
11	Insulation levels	21
11.1	General	21
11.2	Transformers for use at high altitudes	22
12	Climatic, environmental and fire behaviour classes	23
12.1	Climatic classes	23
12.2	Environmental classes	24
12.2.1	Transformers for indoor application with or without enclosure and for outdoor application with enclosure	24
12.2.2	Dry-type transformers without enclosure for outdoor application	25
12.3	Fire behaviour classes	25
12.4	Test criteria for climatic, environmental and fire behaviour classes	25
13	Seismic	26
13.1	General	26
13.2	General seismic class approach	27
13.2.1	Generalities	27
13.2.2	The standard amplitude method	27
13.2.3	The calculated amplitude method	28
14	Test	29
14.1	General requirements for tests	29
14.2	Routine tests	30
14.2.1	Measurement of winding resistance	30
14.2.2	Measurement of voltage ratio and check of phase displacement	30
14.2.3	Measurement of short-circuit impedance and load loss	30
14.2.4	Measurement of no-load loss and current	31
14.2.5	Separate source AC withstand voltage test Applied voltage test (AV)	31
14.2.6	Induced AC withstand voltage test Induced voltage withstand test (IVW)	31
14.2.7	Partial discharge measurement	31
14.3	Type tests	33
14.3.1	Full wave lightning impulse test (LI)	33
14.3.2	Temperature-rise test	34
14.4	Additional procedure test (Special tests)	38
14.4.1	Partial discharge measurement for transformers operated under a single phase line-to-earth fault condition	38
14.4.2	Measurement of sound level	38
14.4.3	Short-circuit test	39
14.4.4	Climatic tests	39
	Thermal shock test for C1 class transformers	
	Thermal shock test for C2 class transformers	
14.4.5	Environmental test	41
14.4.6	Fire behaviour test	44
14.4.7	Seismic test	51
14.4.8	Special test for transformers equipped with amorphous core	52
15	Tolerances	53
16	Protection against direct contact	53
17	Degrees of protection provided by enclosures	53

18	Earthing terminal	53
19	Information required with enquiry and order.....	53
Annex A (informative) Installation and safety of dry-type transformers.....		54
A.1	Manuals	54
A.2	Installation	54
A.2.1	General	54
A.2.2	Intrinsic safety	54
A.2.3	Installation precautions	55
A.2.4	Installation design	55
Annex B (informative) Environmental test for evaluation of outdoor transformers without enclosure.....		56
B.1	General.....	56
B.2	Salt-fog and UV-radiation chamber test	56
B.2.1	Test description	56
B.2.2	Acceptance criteria:	58
B.3	Core and clamp coating test.....	58
B.3.1	Test description	58
B.3.2	Acceptance criteria	58
B.4	Field test.....	58
B.4.1	Test description	58
B.4.2	Acceptance criteria	59
Annex C (normative) Cooling of transformer in naturally ventilated room		60
C.1	Assumptions	60
C.2	Data for the calculation of ventilation	61
C.3	Output	61
C.4	Numerical application for a 1 000 kVA transformer	62
Annex D (normative) Calculation of the losses with different reference temperatures and/or winding material		63
Bibliography		66

Figure 1 – Basic measuring circuit for the partial discharge test for a single-phase transformer.....	32
Figure 2 – Basic measuring circuit for the partial discharge test for a three-phase transformer.....	32
Figure 3 – Voltage application for routine partial discharge test.....	33
Figure 4 – Example of back-to-back method – Single phase	36
Figure 5 – Example of back-to-back method – Three-phase	37
Figure 6 – Voltage application for special partial discharge test	38
Figure 7 – Test chamber	47
Figure 8 – Test chamber details	48
Figure B.1 – Salt fog multi-parameter ageing cycle	57
Figure C.1 – Heat dissipation in a natural ventilated room.....	60

~~Table – Insulation levels based on European practice.....~~

~~Table – Insulation levels based on North American practice.....~~

Table 1 – Letter symbols.....	16
-------------------------------	----

Table 2 – Winding temperature-rise limits.....	20
Table 3 – Test voltage levels.....	22
Table 4 – Applied voltage level correction factor.....	23
Table 5 – Sequence of tests.....	26
Table 6 – Approximate acceleration level and performance level.....	28
Table 7 – Ground acceleration level (<i>AG</i>).....	28
Table 8 – Recommended super elevation factors (<i>K</i>).....	29
Table 9 – Direction factors (<i>D</i>).....	29
Table 10 – Climatic class features.....	39
Table 11 – Environmental classes.....	43
Table 12 – Dimension of the chamber.....	46
Table B.1 – Outdoor environmental classes.....	56

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60076-11:2018](https://standards.iteh.ai/catalog/standards/iec/4f01aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018)

<https://standards.iteh.ai/catalog/standards/iec/4f01aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

POWER TRANSFORMERS –

Part 11: Dry-type transformers

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International Standard IEC 60076-11 has been prepared by IEC technical committee 14: Power transformers.

This second edition cancels and replaces the first edition published in 2004 and constitutes a technical revision.

The main changes with regard to the previous edition are as follows:

- Extension of the scope up to 72,5kV
- Enclosure management in regards of the performance
- Management of the dielectric and thermal features with altitude
- New climatic classes for a better adaptation of customers' need
- Establishment of the relation between location and environmental classes
- For fire behaviour classes, limitation at 1 000 kVA and process of test more robust
- Introduction of Seismic class
- Recommendations for amorphous transformers

The text of this International Standard is based on the following documents:

FDIS	Report on voting
14/964/FDIS	14/972/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60076 series, published under the general title *Power transformers*, can be found on the IEC website.

<https://standards.iec.ch/catalog/standards/iec/4101aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018>

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the corrigendum of March 2019 and the Interpretation sheet 1 of July 2020 have been included in this copy.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

POWER TRANSFORMERS –

Part 11: Dry-type transformers

1 Scope

This part of IEC 60076 applies to dry-type power transformers (including auto-transformers) having values of highest voltage for equipment up to and including ~~36~~ 72,5 kV and at least one winding operating at greater than 1,1 kV. ~~The standard applies to all construction technologies.~~

This document does not apply to:

- gas-filled dry-type transformers where the gas is not air;
- single-phase transformers rated at less than 5 kVA;
- polyphase transformers rated at less than 15 kVA;
- instrument transformers (~~see IEC 60044 and IEC 60186~~);
- starting transformers;
- testing transformers;
- traction transformers mounted on rolling stock;
- flameproof and mining transformers;
- welding transformers;
- voltage regulating transformers;
- small power transformers in which safety is a special consideration.

Where IEC standards do not exist for the transformers mentioned above or for other special transformers, this document may be applicable as a whole or in parts.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

~~IEC 60050 (all parts), International electrotechnical vocabulary (IEV)~~

IEC 60068-3-3, *Environmental testing – Part 3-3: Guidance – Seismic test methods for equipments*

~~IEC 60071 (all parts), Insulation co-ordination~~

IEC 60071-1, *Insulation co-ordination – Part 1: Definitions, principles and rules*

IEC 60071-2, *Insulation co-ordination – Part 2: Application guidelines*

IEC 60076-1: ~~1993~~ 2011, *Power transformers – Part 1: General Amendment 1 (1999)*

IEC 60076-2, *Power transformers – Part 2: Temperature rise for liquid-immersed transformers*

IEC 60076-3:2013, *Power transformers – Part 3: Insulation levels, dielectric tests and external clearances in air*

IEC 60076-5, *Power transformers – Part 5: Ability to withstand short-circuit*

IEC 60076-10, *Power transformers – Part 10: Determination of sound levels*

IEC 60076-12:2008, *Power transformers – Part 12: Loading guide for dry-type power transformers*

IEC 60085, *Electrical insulation – Thermal evaluation and ~~classification of electrical insulation designation~~*

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC 60332-3-10, *Tests on electric cables under fire conditions – Part 3-10: Test for vertical flame spread of vertically-mounted bunched wires or cables – Apparatus*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60721-3-4, *Classification of environmental conditions – Part 3: Classification of groups of environmental parameters and their severities – Section 4: Stationary use at non-weatherprotected locations*

IEC TS 60815-1, *Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 1: Definitions, information and general principles*

~~IEC 60905:1987, Loading guide for dry-type power transformers~~

~~IEC 61330, High-voltage/low voltage prefabricated substations~~

IEC 61378-1, *Converter transformers – Part 1: Transformers for industrial applications*

IEC 62271-202, *High-voltage switchgear and controlgear – Part 202: High-voltage/low-voltage prefabricated substation*

ISO 12944-6, *Paints and varnishes – Corrosion protection of steel structures by protective paint systems – Part 6: Laboratory performance test methods*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

dry-type transformer

transformer of which the magnetic circuit and windings are not immersed in an insulating liquid

3.2

totally enclosed dry-type transformer

transformer in an un-pressurised enclosure cooled by the circulation of the internal air having no intentional exchange with external air

3.3

enclosed dry-type transformer

transformer in a ventilated enclosure cooled by the circulation of the external air

3.4

non-enclosed dry-type transformer

transformer supplied without a protective enclosure cooled by natural or forced air ventilation

4 Service conditions

4.1 General

The requirements of IEC 60076-1 apply to dry-type transformers only in so far as they are referred to in this document.

4.2 Normal service conditions

~~4.2.1 General~~

~~Unless otherwise stated, the service conditions in 4.2.2 to 4.2.6 apply. When transformers are required to operate outside the normal service conditions, de-rating in accordance with 11.2 and/or 11.3 applies.~~

a) Altitude:

~~A height above sea level not exceeding 1 000 m.~~ See IEC 60076-1.

b) Temperature of cooling air and water: IEC 60076-11:2018

<https://standards.iteh.ai/catalog/standards/iec/4f01aca6-8980-4da4-9074-7142085e4078/iec-60076-11-2018>

~~The temperature of cooling air not exceeding:~~

- ~~40 °C at any time;~~
- ~~30 °C monthly average of the hottest month;~~
- ~~20 °C yearly average.~~

~~and not below:~~

- ~~–25 °C in the case of outdoor transformers;~~
- ~~–5 °C in the case of indoor transformers.~~

~~where the monthly and yearly averages are as defined in 3.12 of IEC 60076-1.~~

See IEC 60076-1.

For water cooled transformers, specification of the water (temperature, water flow, etc.) has to be defined by agreement between manufacturer and purchaser if the temperature of the water is different from that specified in IEC 60076-1 and IEC 60076-2

NOTE Liquids other than water can be used as a cooling medium then all technical data of the liquid has to be defined by agreement between manufacturer and purchaser.

c) Wave-shape of supply voltage:

~~A supply voltage of which the waveshape is approximately sinusoidal.~~