

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**High-voltage switchgear and controlgear –
Part 209: Cable connections for gas-insulated metal-enclosed switchgear for
rated voltages above 52 kV – Fluid-filled and extruded insulation cables –
Fluid-filled and dry-type cable-terminations**

[IEC 62271-209:2019](#)

**Appareillage à haute tension –
Partie 209: Raccordement de câbles pour appareillage sous enveloppe
métallique à isolation gazeuse de tension assignée supérieure à 52 kV – Câbles
remplis d'un fluide ou à isolation extrudée – Extrémité de câble de type sec ou
remplie d'un fluide**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.



IEC 62271-209

Edition 2.1 2022-03
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**High-voltage switchgear and controlgear –
Part 209: Cable connections for gas-insulated metal-enclosed switchgear for
rated voltages above 52 kV – Fluid-filled and extruded insulation cables –
Fluid-filled and dry-type cable-terminations**

[IEC 62271-209:2019](#)

**Appareillage à haute tension –
Partie 209: Raccordement de câbles pour appareillage sous enveloppe
métallique à isolation gazeuse de tension assignée supérieure à 52 kV – Câbles
remplis d'un fluide ou à isolation extrudée – Extrémité de câble de type sec ou
remplie d'un fluide**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.130.10

ISBN 978-2-8322-5290-1

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

REDLINE VERSION

VERSION REDLINE



**High-voltage switchgear and controlgear –
Part 209: Cable connections for gas-insulated metal-enclosed switchgear for
rated voltages above 52 kV – Fluid-filled and extruded insulation cables –
Fluid-filled and dry-type cable-terminations**

[IEC 62271-209:2019](#)

**Appareillage à haute tension –
Partie 209: Raccordement de câbles pour appareillage sous enveloppe
métallique à isolation gazeuse de tension assignée supérieure à 52 kV – Câbles
remplis d'un fluide ou à isolation extrudée – Extrémité de câble de type sec ou
remplie d'un fluide**

CONTENTS

FOREWORD	4
INTRODUCTION TO Amendment 1	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 Normal and special service conditions	9
4.1 General	9
4.2 Normal service conditions	9
4.3 Special service conditions	9
5 Ratings	9
5.1 General	9
5.2 Rated voltage of the equipment of the cable connection (U_{rm})	10
5.3 Rated insulation level (U_d , U_p , U_s)	10
5.4 Rated frequency (f_r)	10
5.5 Rated continuous current (I_r)	10
5.6 Rated short-time withstand current (I_k)	10
5.7 Rated peak withstand current (I_p)	10
5.8 Rated duration of short circuit (t_k)	10
6 Design and construction	11
6.1 Gas and vacuum tightness	11
6.101 Limits of supply	11
6.101.1 General	11
6.101.2 Over-voltage protection and earthing	11
6.102 Filling pressure of insulating gas in the cable connection enclosure	12
6.103 Pressure withstand requirements	12
6.104 Mechanical forces on cable terminations	13
6.105 Switchgear connection interface and cable termination connection interface	13
7 Type tests	13
7.1 General	13
7.2 Electrical type tests of cable terminations	13
7.2.1 General	13
7.2.2 Electrical type test of cable terminations in a single-phase enclosure	14
7.2.3 Electrical type test of cable termination in a three-phase enclosure	14
7.2.4 Additional electrical type tests on the insulator to be installed by switchgear manufacturer (plug in cable termination)	14
7.3 Pressure test on the insulator of a cable termination	15
7.4 Leak rate type test on the insulator of a cable termination	15
8 Routine tests	16
8.1 General	16
8.2 Pressure test	16
8.3 Visual inspection	16
9 Standard dimensions	16
9.1 General	16
9.2 Fluid-filled cable terminations	16
9.3 Dry-type cable terminations	16

9.4	Three-phase cable connection enclosure	17
10	Information to be given with enquiries, tenders and orders	17
11	Rules for transport, storage, erection, service and maintenance	17
11.1	General.....	17
11.2	Tests after cable system installation	17
12	Safety practices and constraints during installation of cable connection to switchgear	18
13	Influence of the product on the environment	18
	Annex A (informative) Mechanical forces applied on the flange of the cable connection enclosure.....	24
A.1	General.....	24
A.2	Recommendation when connecting cable systems to switchgear	24
	Bibliography.....	26
	Figure 1 – Operating pressure of the SF₆ gas insulation in the cable connection enclosure.....	12
	Figure 2 – Fluid-filled cable connection assembly – Typical arrangement.....	20
	Figure 3 – Fluid-filled cable connection – Assembly dimensions	21
	Figure 4 – Dry-type cable connection assembly – Typical arrangement.....	22
	Figure 5 – Dry-type cable connection assembly – Assembly dimensions	23
	Table 1 – Test voltages for additional electrical type tests according to 7.2.4.....	15
	Table A.1 – Moment and forces applied on the flange of the cable connection enclosure attached to the cable termination during normal operation	25

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 209: Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-filled and dry-type cable terminations

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 62271-209 edition 2.1 contains the second edition (2019-02) [documents 17C/696/FDIS and 17C/701/RVD] and its amendment 1 (2022-03) [documents 17C/833/FDIS and 17C/841/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 62271-209 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear.

This second edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) New numbering in accordance with ISO/IEC directives, Part 2 (2016) and to IEC 62271-1:2017;
- b) Clause 3: addition of a definition for plug-in cable termination, filling pressure and minimum function pressure for insulation;
- c) Clause 7: An additional dielectric type test for plug-in cable termination was added; also a pressure type test as well as a leak rate test on the insulator of a cable termination was implemented;
- d) Clause 12: New clause about safety practices;
- e) Clause 13: New clause about influence of the product on the environment;
- f) New informative Annex A: Mechanical forces applied on the flange of the cable connection enclosure.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard is to be read in conjunction with IEC 62271-1:2017, to which it refers and which is applicable unless otherwise specified in this standard. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1. Amendments to these clauses and subclauses are given under the same references whilst additional subclauses are numbered from 101.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under webstore.iec.ch in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION TO Amendment 1

This amendment includes the following modifications:

- a) In accordance with the decision taken at IEC Plenary Meeting October 2019 in Shanghai (17C/Shanghai/Sec07) Subclause 6.103, Figure 1 and Figure 2 have been modified;
- b) The CDV was modified in accordance with the above-mentioned documents and based on the decision taken at the virtual IEC Plenary Meeting in October 2021 (17C/823/RM).

NOTE CIGRE has published TB 784 "Standard design of a common, dry type plug-in interface for GIS and power cables up to 145 kV describing the basis for further standardisation of such a common interface. The matter will be dealt with during the next revision of IEC 62271-209.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 62271-209:2019](https://standards.iteh.ai/catalog/standards/sist/a3f865aa-c8db-426d-b14a-5cf861a793a9/iec-62271-209-2019)

<https://standards.iteh.ai/catalog/standards/sist/a3f865aa-c8db-426d-b14a-5cf861a793a9/iec-62271-209-2019>

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 209: Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-filled and dry-type cable terminations

1 Scope

This part of IEC 62271 covers the connection assembly of fluid-filled and extruded cables to gas-insulated metal enclosed switchgear (GIS), in single- or three-phase arrangements where the cable terminations are fluid-filled or dry-type and there is a separating insulating barrier between the cable insulation and the gas insulation of the switchgear.

The purpose of this document is to establish electrical and mechanical interchangeability between cable terminations and the gas-insulated metal-enclosed switchgear and to determine the limits of supply. It complements and amends, if applicable, the relevant IEC standards. For the purpose of this document the term "switchgear" is used for "gas-insulated metal enclosed switchgear".

It does not cover directly immersed cable terminations, as described in CIGRE brochure 89 [4]¹.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60068-2-17:1994, *Basic environmental testing procedures – Part 2-17:Tests – Test Q: Sealing*

IEC 60141 (all parts), *Tests on oil-filled and gas-pressure cables and their accessories*

IEC 60376, *Specification of technical grade sulphur hexafluoride (SF₆) and complementary gases to be used in its mixtures for use in electrical equipment*

IEC 60480, *Guidelines for the checking and treatment of sulphur hexafluoride (SF₆) taken from electrical equipment and specification for its re-use*

IEC 60840, *Power cables with extruded insulation and their accessories for rated voltages above 30 kV (U_m = 36 kV) up to 150 kV (U_m = 170 kV) – Test methods and requirements*

IEC 62067, *Power cables with extruded insulation and their accessories for rated voltages above 150 kV (U_m = 170 kV) up to 500 kV (U_m = 550 kV) – Test methods and requirements*

¹ Numbers in square brackets refer to the Bibliography.

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-203:2011, *High-voltage switchgear and controlgear – Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

cable termination

equipment fitted to the end of a cable to ensure electrical connection with other parts of the system and to maintain the insulation up to the point of connection

3.1.1

fluid-filled cable termination

cable termination which comprises a separating insulating barrier between the cable insulation and the gas insulation of switchgear, including a fluid

3.1.2

dry-type cable termination

cable termination which comprises an elastomeric electrical stress control component in direct contact with a separating insulating barrier (insulator) between the cable insulation and the gas insulation of the switchgear, not requiring any fluid

3.2

main circuit end terminal

part of the main circuit of a gas-insulated metal enclosed switchgear forming part of the connection interface

3.3

cable connection enclosure

part of the gas-insulated metal-enclosed switchgear which houses the cable termination and the main circuit end terminal

3.4

cable connection assembly

combination of a cable termination, a cable connection enclosure and a main circuit end terminal, which mechanically and electrically connects the cable to the gas-insulated metal enclosed switchgear

3.5

plug-in cable termination

cable termination where cable/stress cone assembly can be engaged into the insulator assembly that is already installed into switchgear enclosure

3.6

design pressure

pressure used to determine the design of the enclosure and the components of the cable termination subjected to that pressure

Note 1 to entry: It is at least equal to the maximum pressure in the enclosure at the highest temperature that the gas used for insulation can reach under specified maximum service conditions.

3.7

fluid

liquid or gas for insulation purposes

3.8

cable system

cable with installed accessories

3.9

filling pressure p_{re} for insulation

filling density ρ_{re} for insulation

pressure (in Pa), for insulation, referred to the standard atmospheric air conditions of 20 °C and 101,3 kPa, which may be expressed in relative or absolute terms (or density), to which the assembly is filled before being put into service

3.10

minimum functional pressure p_{me} for insulation

minimum functional density ρ_{me} for insulation

pressure (in Pa), for insulation, referred to the standard atmospheric air conditions of 20 °C and 101,3 kPa, which may be expressed in relative or absolute terms (or density), at which and above which the characteristics of the switchgear-cable connection are maintained and at which replenishment becomes necessary

4 Normal and special service conditions

4.1 General

Clause 2 of IEC 62271-203:2011 is applicable.

4.2 Normal service conditions

Subclause 2.1 of IEC 62271-203:2011 is applicable.

4.3 Special service conditions

Subclause 2.2 of IEC 62271-203:2011 is applicable.

5 Ratings

5.1 General

When dimensioning the cable connection assembly, the following rated values shall apply:

- rated voltage of the equipment of the cable connection (U_{rm});
- rated insulation level (U_p , U_d and U_s where applicable);
- rated frequency (f_r);
- rated continuous current (I_r);
- rated short-time withstand current (I_k);
- rated peak withstand current (I_p);
- rated duration of short circuit (t_k).

5.2 Rated voltage of the equipment of the cable connection (U_{rm})

The rated voltage for the equipment of the cable connection (U_{rm}) is equal to the lower of the values U_m for the cable system and U_r for the gas-insulated metal-enclosed switchgear and shall be selected from the following standard values:

72,5 kV – 100 kV – 123 kV – 145 kV – 170 kV – 245 kV – 300 kV – 362 kV – 420 kV – 550 kV

NOTE 1 Values above $U_r = 550$ kV are not considered.

NOTE 2 $U_m = 100$ kV is not defined in IEC 60840.

5.3 Rated insulation level (U_d , U_p , U_s)

The rated insulation level for the cable connection assembly shall be selected from the values given in IEC 60038 as well as IEC 62271-203.

5.4 Rated frequency (f_r)

The preferred values of the rated frequency are 16,7 Hz, 25 Hz, 50 Hz and 60 Hz.

5.5 Rated continuous current (I_r)

The connection interface of the main circuit shown in Figures 2 and 3 for fluid-filled cable terminations and Figures 4 and 5 for dry-type cable terminations is applicable at rated continuous currents up to 3 150 A.

The connection interface shall be designed so that at a current equal to the cable rated current corresponding to a maximum temperature of 90 °C, no heat transfer from the switchgear main circuit end terminal to the cable termination will occur.

IEC 62271-209:2019

NOTE As the maximum conductor temperature for cables is limited by the maximum operating temperature for the insulation, there are certain cable dielectrics which cannot withstand the maximum temperature specified for gas-insulated metal-enclosed switchgear if there is heat transfer across the connection interface to the cable terminations.

For cases when the above design requirement of 90 °C at rated continuous current of the cable system cannot be allowed because of cable design limitations, the manufacturer of the switchgear should provide the necessary data on temperature rise of the main circuit end terminal and of the insulating gas as a function of current.

5.6 Rated short-time withstand current (I_k)

Short-time currents of short circuit shall refer to the levels provided by the cable system, not exceeding the values defined for the switchgear in line with IEC 62271-1.

5.7 Rated peak withstand current (I_p)

Peak withstand currents of short circuit shall refer to the levels provided by the cable system, not exceeding the values defined for the switchgear in line with IEC 62271-1.

5.8 Rated duration of short circuit (t_k)

The duration of short circuit shall refer to the levels provided by the cable system, not exceeding the values given in IEC 62271-1.

6 Design and construction

6.1 Gas and vacuum tightness

Subclause 6.16 of IEC 62271-1:2017 is applicable with the following addition:

For conditions up to the maximum occurring gas operating pressure, the cable termination shall prevent insulating gas from the switchgear diffusing into the interior of the cable termination and into the cable. The cable termination shall prevent insulating fluid from the cable termination entering the switchgear. The insulator (part 4 in Figures 2 and 4) shall be capable of withstanding the vacuum conditions when the cable connection enclosure is evacuated, as part of the gas filling process.

In the case of a gas insulated cable or a gas insulated termination, the gas compartment of the cable or of the gas insulated termination shall be treated independently from the switchgear with respect to tightness.

6.101 Limits of supply

6.101.1 General

The limits of supply of gas-insulated metal-enclosed switchgear and the cable termination shall be in accordance with Figure 2 for fluid-filled cable terminations and Figure 4 for dry-type cable terminations.

6.101.2 Over-voltage protection and earthing

It is necessary to have either a direct low resistance connection or an insulated section bridged by non-linear resistors between part 6 and part 13 of Figure 2 for fluid-filled cable terminations and Figure 4 for dry-type cable terminations. To enable suitable connections to be made to the switchgear, for the purposes of this direct connection or installation of any sheath voltage limiting device, the switchgear manufacturer shall provide four connection points per phase (evenly spaced around each phase) each comprising an M12 threaded hole of minimum 21 mm length (for all voltage levels). The position of these 4 connection points is different from the mechanical connection points used for fixing the cable termination insulator. The number of connection points used shall be determined by the cable system designer.

Where applicable, the number and characteristics of the non-linear resistors shall be determined by the cable system designer, and they shall be supplied by the cable termination manufacturer, taking into consideration the requirements of the user and the switchgear manufacturer. Reference is made to CIGRE TB 44, 1993 [5], as well as to IEEE 1300-2011, Clause 11 [3].

In addition, the installation design of the area around the cable termination shall take into account the space required to install any non-linear resistors, including adequate clearances to earth.

For three phases in one enclosure arrangements special clarification between the GIS manufacturer, the cable termination manufacturer and the cable system designer may be necessary because of limited space between the three phases.

The overvoltage protection elements, i.e. connections between part 6 and part 13 of Figure 2 for fluid-filled cable terminations and Figure 4 for dry-type cable terminations as described above, are not meant to serve as the cable system grounding connection.

Earthing of enclosures shall be in accordance with the relevant subclause of IEC 62271-203:2011.