

---

**Industrijska komunikacijska omrežja - Specifikacije za procesna vodila - 6-22. del: Specifikacija protokola na aplikacijskem nivoju - Elementi tipa 22 (IEC 61158-6-22:2010)**

Industrial communication networks - Fieldbus specifications - Part 6-22: Application layer protocol specification - Type 22 elements (IEC 61158-6-22:2010)

Industrielle Kommunikationsnetze - Feldbusse - Teil 6-22: Protokollspezifikation des Application Layer (Anwendungsschicht) - Typ 22-Elemente (IEC 61158-6-22:2010)

Réseaux de communication industriels - Spécifications des bus de terrain - Partie 6-22: Spécification des protocoles des couches d'application - Éléments de type 22 (CEI 61158-6-22:2010)

**Ta slovenski standard je istoveten z: EN 61158-6-22:2012**

---

**ICS:**

25.040.40	Merjenje in krmiljenje industrijskih postopkov	Industrial process measurement and control
35.100.70	Uporabniški sloj	Application layer
35.110	Omreževanje	Networking

**SIST EN 61158-6-22:2012**

**en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 61158-6-22:2012

<https://standards.iteh.ai/catalog/standards/sist/618f4549-5048-475a-8931-3c1bf6d029b9/sist-en-61158-6-22-2012>

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN 61158-6-22**

June 2012

ICS 25.040.40; 35.100.70; 35.110

English version

**Industrial communication networks -  
Fieldbus specifications -  
Part 6-22: Application layer protocol specification -  
Type 22 elements  
(IEC 61158-6-22:2010)**

Réseaux de communication industriels -  
Spécifications des bus de terrain -  
Partie 6-22: Spécification des protocoles  
des couches d'application -  
Éléments de type 22  
(CEI 61158-6-22:2010)

Industrielle Kommunikationsnetze -  
Feldbusse -  
Teil 6-22: Protokollspezifikation des  
Application Layer (Anwendungsschicht) -  
Typ 22-Elemente  
(IEC 61158-6-22:2010)

**ITEH STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 61158-6-22:2012](https://standards.iteh.ai/catalog/standards/sist/618f4549-5048-475a-8931-100000000000/61158-6-22:2012)

[https://standards.iteh.ai/catalog/standards/sist/618f4549-5048-475a-8931-](https://standards.iteh.ai/catalog/standards/sist/618f4549-5048-475a-8931-100000000000/61158-6-22:2012)

This European Standard was approved by CENELEC on 2012-03-28. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Management Centre: Avenue Marnix 17, B - 1000 Brussels**

## Foreword

The text of document 65C/607/FDIS, future edition 1 of IEC 61158-6-22, prepared by SC 65C, "Industrial networks", of IEC/TC 65, "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-6-22:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-12-28
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2015-03-28

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

## iTeh STANDARD PREVIEW

### Endorsement notice

The text of the International Standard IEC 61158-6-22:2010 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC/TR 61158-1:2010 NOTE Harmonized as CLC/TR 61158-1:2010 (not modified).  
<https://standards.iteh.ai/catalog/standards/sist/6184549-5048-475a-8931-3c16bd02969/sist-en-61158-6-22-2012>

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60559	-	Binary floating-point arithmetic for microprocessor systems	HD 592 S1	-
IEC 61158-3-22	2010	Industrial communication networks - Fieldbus specifications - Part 3-22: Data-link layer service definition - Type 22 elements	EN 61158-3-22	2012
IEC 61158-4-22	2010	Industrial communication networks - Fieldbus specifications - Part 4-22: Data-link layer protocol specification - Type 22 elements	EN 61158-4-22	2012
IEC 61158-5-22	2010	Industrial communication networks - Fieldbus specifications - Part 5-22: Application layer service definition - Type 22 elements	EN 61158-5-22	2012
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic Reference Model: The Basic Model	-	-
ISO/IEC 8802-3	-	Information technology - Telecommunications and information exchange between systems - Local and metropolitan area networks - Specific requirements - Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications	-	-
ISO/IEC 8822	-	Information technology - Open Systems Interconnection - Presentation service definition	-	-
ISO/IEC 8824-1	-	Information technology - Abstract Syntax Notation One (ASN.1): Specification of basic notation	-	-
ISO/IEC 9545	-	Information technology - Open Systems Interconnection - Application Layer structure	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic reference model - Conventions for the definition of OSI services	-	-

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 61158-6-22:2012

<https://standards.iteh.ai/catalog/standards/sist/618f4549-5048-475a-8931-3c1bf6d029b9/sist-en-61158-6-22-2012>



IEC 61158-6-22

Edition 1.0 2010-08

# INTERNATIONAL STANDARD

---

**Industrial communication networks – Fieldbus specifications –  
Part 6-22: Application layer protocol specification – Type 22 elements**

***STANDARD PREVIEW***  
***(standards.iteh.ai)***  
[SIST EN 61158-6-22:2012  
https://standards.iteh.ai/catalog/standards/sist/618f4549-5048-475a-8931-3c1bf6d029b9/sist-en-61158-6-22-2012](https://standards.iteh.ai/catalog/standards/sist/618f4549-5048-475a-8931-3c1bf6d029b9/sist-en-61158-6-22-2012)

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

PRICE CODE **XC**

---

ICS 25.04.40; 35.100.70; 35.110

ISBN 978-2-88912-136-6

## CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
1.1 General.....	9
1.2 Specifications.....	10
1.3 Conformance.....	10
2 Normative references.....	10
3 Terms, definitions, abbreviations, symbols and conventions.....	11
3.1 Terms and definitions from other ISO/IEC standards.....	11
3.2 Fieldbus application-layer specific definitions.....	11
3.3 Abbreviations and symbols.....	15
3.4 Conventions.....	17
4 Application layer protocol specification.....	18
4.1 Operating principle.....	18
4.2 Device reference models.....	19
4.3 Application layer structure.....	21
5 FAL syntax description.....	21
5.1 Introduction and coding principles.....	21
5.2 Data type encoding.....	21
5.3 CeS encoding.....	25
5.4 ISO/IEC 8802-3 DLPDU communication inside Type 22 RTFL.....	72
5.5 Management encoding.....	72
6 FAL protocol state machines.....	73
6.1 Overview.....	73
6.2 Fieldbus service protocol machine (FSPM).....	74
6.3 Application relationship protocol machine (ARPM).....	74
6.4 DLL mapping protocol machine.....	74
7 AP-context state machine.....	75
8 FAL service protocol machine (FSPM).....	75
9 Application layer state machine (ALSM).....	75
9.1 Description.....	75
9.2 States.....	77
9.3 Primitive definitions.....	78
9.4 State table.....	79
9.5 AL-service forwarding depending on AL-state.....	79
10 DLL mapping protocol machine (DMPM).....	80
10.1 Overview.....	80
10.2 Primitives exchanged between ALSM and DMPM.....	80
10.3 Primitives exchanged between DLL and DMPM.....	84
10.4 ALSM to DLL mapping.....	86
Bibliography.....	88
Figure 1 – RTFL device reference model.....	20
Figure 2 – RTFN device reference model.....	21
Figure 3 – Encoding of TimeOfDay value.....	22



Figure 4 – Encoding of TimeDifference value.....	23
Figure 5 – Object dictionary addressing schema.....	26
Figure 6 – Relationships among protocol machines and adjacent layers.....	73
Figure 7 – ALSM protocol machine.....	74
Figure 8 – ALSM diagram.....	76
Table 1 – PDU element definition.....	18
Table 2 – Object definition.....	18
Table 3 – Transfer syntax for bit sequences.....	22
Table 4 – Transfer syntax for Integer data type.....	24
Table 5 – Transfer syntax for Unsigned data type.....	24
Table 6 – Object dictionary structure.....	25
Table 7 – Object dictionary object type definitions.....	26
Table 8 – Basic data type definitions.....	27
Table 9 – Complex data type definition.....	28
Table 10 – Communication section.....	29
Table 11 – Device type.....	31
Table 12 – Error register encoding.....	31
Table 13 – Error register.....	31
Table 14 – Object definition template.....	32
Table 15 – Encoding of event log entries.....	32
Table 16 – Event log.....	33
Table 17 – Manufacturer device name.....	33
Table 18 – Manufacturer HW version.....	34
Table 19 – Manufacturer SW version.....	34
Table 20 – CL configuration.....	34
Table 21 – Time sync IRQ configuration encoding.....	36
Table 22 – Time sync IRQ configuration.....	36
Table 23 – Time sync IRQ state.....	37
Table 24 – Store parameters read information.....	38
Table 25 – Store parameters.....	38
Table 26 – Restore parameters read information.....	39
Table 27 – Restore default parameters.....	39
Table 28 – Diagnostic information.....	41
Table 29 – Diagnostic threshold.....	44
Table 30 – IP address EMCY.....	45
Table 31 – Inhibit time EMCY.....	46
Table 32 – Encoding of consumer heartbeat entries.....	46
Table 33 – Consumer heartbeat list.....	47
Table 34 – Producer heartbeat parameter.....	47
Table 35 – Identity object.....	49
Table 36 – SDO protocol timeout.....	51
Table 37 – Enable client SDO parameter.....	51

Table 38 – Enable EMCY .....	52
Table 39 – PDO timeout tolerance .....	52
Table 40 – Store EDS .....	52
Table 41 – Storage format .....	53
Table 42 – OS command .....	53
Table 43 – OS command mode .....	54
Table 44 – OS debugger interface .....	55
Table 45 – OS prompt .....	56
Table 46 – Module list .....	57
Table 47 – Emergency subscriber encoding .....	57
Table 48 – Emergency subscriber .....	57
Table 49 – Client SDO parameter encoding .....	58
Table 50 – Client SDO parameter .....	58
Table 51 – Receive PDO communication parameter .....	59
Table 52 – Transmit PDO communication parameter .....	61
Table 53 – Mapping format .....	63
Table 54 – Receive PDO mapping parameter .....	63
Table 55 – Transmit PDO mapping parameter .....	64
Table 56 – Initiate SDO expedited download request .....	65
Table 57 – Initiate SDO expedited download response .....	65
Table 58 – Initiate SDO normal download request .....	65
Table 59 – Initiate SDO normal download response .....	66
Table 60 – SDO download request .....	66
Table 61 – SDO download response .....	66
Table 62 – Initiate SDO expedited upload request .....	67
Table 63 – Initiate SDO expedited upload response .....	67
Table 64 – Initiate SDO normal upload response .....	67
Table 65 – SDO upload request .....	68
Table 66 – SDO upload response .....	68
Table 67 – SDO abort request .....	68
Table 68 – SDO abort codes .....	68
Table 69 – Process data write request via MSC .....	69
Table 70 – Process data write request via CDC .....	70
Table 71 – Emergency request .....	70
Table 72 – Emergency error codes .....	70
Table 73 – Heartbeat request via MSC .....	71
Table 74 – Heartbeat request via CDC .....	71
Table 75 – Send frame request .....	72
Table 76 – Application layer management request .....	72
Table 77 – State transitions and management services .....	76
Table 78 – Primitives issued by ALSM to DLL .....	78
Table 79 – Primitives issued by DLL to ALSM .....	78
Table 80 – Primitives issued by FSPM to ALSM .....	78

Table 81 – Primitives issued by ALSM to FSPM .....	78
Table 82 – ALSM state table .....	79
Table 83 – Application layer states and communication services .....	80
Table 84 – Primitives issued by ALSM to DMPM .....	80
Table 85 – Primitives issued by DMPM to ALSM .....	82
Table 86 – Primitives issued by DMPM to DLL .....	84
Table 87 – Primitives issued by DLL to DMPM .....	85
Table 88 – ALSM to DLL mapping .....	86

## **iTeh STANDARD PREVIEW** **(standards.iteh.ai)**

[SIST EN 61158-6-22:2012](https://standards.iteh.ai/catalog/standards/sist/61158-6-22:2012)

<https://standards.iteh.ai/catalog/standards/sist/61158-6-22:2012>

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**INDUSTRIAL COMMUNICATION NETWORKS –  
 FIELDBUS SPECIFICATIONS –**
**Part 6-22: Application layer protocol specification –  
 Type 22 elements**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

NOTE 1 Use of some of the associated protocol Types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol Type to be used with physical layer and application layer protocols in Type combinations as specified explicitly in the profile parts. Use of the various protocol Types in other combinations may require permission of their respective intellectual-property-right holders.

International Standard IEC 61158-6-22 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This standard cancels and replaces IEC/PAS 61158-6-22 published in 2009. This first edition constitutes a technical revision.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/607/FDIS	65C/621/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

NOTE 2 The revision of this standard will be synchronized with the other parts of the IEC 61158 series.

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 61158-6-22:2012](https://standards.iteh.ai/catalog/standards/sist/618f4549-5048-475a-8931-3c1bf6d029b9/sist-en-61158-6-22-2012)

<https://standards.iteh.ai/catalog/standards/sist/618f4549-5048-475a-8931-3c1bf6d029b9/sist-en-61158-6-22-2012>

## INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

The application protocol provides the application service by making use of the services available from the data-link or other immediately lower layer. The primary aim of this standard is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer application entities (AEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- as a guide for implementors and designers;
- for use in the testing and procurement of equipment;
- as part of an agreement for the admittance of systems into the open systems environment;
- as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this standard together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

## **iTeh STANDARD PREVIEW** **(standards.iteh.ai)**

[SIST EN 61158-6-22:2012](https://standards.iteh.ai/catalog/standards/sist/61158-6-22-2012)

<https://standards.iteh.ai/catalog/standards/sist/61158-6-22-2012>

## INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

### Part 6-22: Application layer protocol specification – Type 22 elements

#### 1 Scope

##### 1.1 General

The Fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 22 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible behavior provided by the different Types of the fieldbus Application Layer in terms of:

- a) the abstract syntax defining the application layer protocol data units conveyed between communicating application entities;
- b) the transfer syntax defining the application layer protocol data units conveyed between communicating application entities;
- c) the application context state machine defining the application service behavior visible between communicating application entities; and
- d) the application relationship state machines defining the communication behavior visible between communicating application entities.

The purpose of this standard is to define the protocol provided to:

- a) define the wire-representation of the service primitives defined in IEC 61158-5-22:2010; and
- b) define the externally visible behavior associated with their transfer.

This standard specifies the protocol of the IEC fieldbus Application Layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498) and the OSI Application Layer Structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the