

SLOVENSKI STANDARD

SIST EN 61557-8:2015

01-junij-2015

Nadomešča:

SIST EN 61557-8:2007

Električna varnost v nizkonapetostnih razdelilnih sistemih izmenične napetosti do 1 kV in enosmerne napetosti do 1,5 kV - Oprema za preskušanje, merjenje ali nadzorovanje zaščitnih ukrepov - 8. del: Naprave za nadzorovanje izolacije v IT sistemih (IEC 61557-8:2014)

Electrical safety in low voltage distribution systems up to 1 000 v a.c. And 1 500 v d.c. - Equipment for testing, measuring or monitoring of protective measures - Part 8: Insulation monitoring devices for IT systems (IEC 61557-8:2014)

(standards.iteh.ai)

Elektrische Sicherheit in Niederspannungsnetzen bis AC 1 000 V und DC 1 500 V - Geräte zum Prüfen, Messen oder Überwachen von Schutzmaßnahmen - Teil 8: Isolationsüberwachungsgeräte für IT-Systeme (IEC 61557-8:2014)

Ta slovenski standard je istoveten z: EN 61557-8:2015

ICS:

17.220.20	Merjenje električnih in magnetnih veličin	Measurement of electrical and magnetic quantities
29.080.01	Električna izolacija na splošno	Electrical insulation in general
29.240.01	Omrežja za prenos in distribucijo električne energije na splošno	Power transmission and distribution networks in general

SIST EN 61557-8:2015

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 61557-8:2015

<https://standards.iteh.ai/catalog/standards/sist/9bf79943-20ba-4c56-9385-43915046b7f7/sist-en-61557-8-2015>

EUROPEAN STANDARD

EN 61557-8

NORME EUROPÉENNE

EUROPÄISCHE NORM

February 2015

ICS 17.220.20; 29.240.01; 29.080.01

Supersedes EN 61557-8:2007

English Version

Electrical safety in low voltage distribution systems up to 1 000 V
a.c. and 1 500 V d.c. - Equipment for testing, measuring or
monitoring of protective measures - Part 8: Insulation monitoring
devices for IT systems
(IEC 61557-8:2014)

Sécurité électrique dans les réseaux de distribution basse
tension de 1 000 V c.a. et 1 500 V C:C - Dispositifs de
contrôle, de mesure ou de surveillance de mesures de
protection - Partie 8: Contrôleur permanent d'isolement
pour réseaux IT
(CEI 61557-8:2014)

Elektrische Sicherheit in Niederspannungsnetzen bis AC 1
000 V und DC 1 500 V - Geräte zum Prüfen, Messen oder
Überwachen von Schutzmaßnahmen - Teil 8:
Isolationsüberwachungsgeräte für IT-Systeme
(IEC 61557-8:2014)

This European Standard was approved by CENELEC on 2015-01-15. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member. [SIST EN 61557-8:2015](https://standards.iteh.ai/catalog/standards/sist/9bf79943-20ba-4c56-9385-)

<https://standards.iteh.ai/catalog/standards/sist/9bf79943-20ba-4c56-9385->

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 85/485/FDIS, future edition 3 of IEC 61557-8, prepared by IEC/TC 85 "Measuring equipment for electrical and electromagnetic quantities" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61557-8:2015.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-10-15
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2018-01-15

This document supersedes EN 61557-8:2007.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD).

Endorsement notice

The text of the International Standard IEC 61557-8:2014 was approved by CENELEC as a European Standard without any modification.

(standards.iteh.ai)

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

		SIST EN 61557-8:2015
IEC 60364-4-41	NOTE	Harmonized as HD 60364-4-41. https://standards.iteh.ai/catalog/standards/sist/96179945-26ba-4c56-9385-43915046b7f7/sist-en-61557-8-2015
IEC 60664-1	NOTE	Harmonized as EN 60664-1.
IEC 60664-3	NOTE	Harmonized as EN 60664-3.
IEC 61140	NOTE	Harmonized as EN 61140.
IEC 60027-7	NOTE	Harmonized as EN 60027-7.
IEC 61557-9	NOTE	Harmonized as EN 61557-9.
IEC 60364-7-712	NOTE	Harmonized as HD 60364-7-712.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60068-2-1	-	Environmental testing -- Part 2-1: Tests - Test A: Cold	EN 60068-2-1	-
IEC 60068-2-2	-	Environmental testing -- Part 2-2: Tests - Test B: Dry heat	EN 60068-2-2	-
IEC 60068-2-6	-	Environmental testing -- Part 2-6: Tests - Test Fc: Vibration (sinusoidal)	EN 60068-2-6	-
IEC 60068-2-27	-	Environmental testing -- Part 2-27: Tests - Test Ea and guidance: Shock	EN 60068-2-27	-
IEC 60364-7-710 (mod)	2002	Electrical installations of buildings -- Part 7-710: Requirements for special installations or locations - Medical locations	HD 60364-7-710	2012
IEC 60691	-	Thermal-links - Requirements and application - guid	+AC	2013
IEC 60721-3-1	-	Classification of environmental conditions -- Part 3: Classification of groups of environmental parameters and their severities -- Section 1: Storage	EN 60721-3-1	-
IEC 60721-3-2	-	Classification of environmental conditions -- Part 3: Classification of groups of environmental parameters and their severities -- Section 2: Transportation	EN 60721-3-2	-
IEC 60721-3-3	-	Classification of environmental conditions -- Part 3: Classification of groups of environmental parameters and their severities -- Section 3: Stationary use at weatherprotected locations	EN 60721-3-3	-
IEC 60947-5-1	-	Low-voltage switchgear and controlgear -- Part 5-1: Control circuit devices and switching elements - Electromechanical control circuit devices	EN 60947-5-1	-
			+EN 60947-5-1:2004/corrigendum Jul. 2005	2005
			+EN 60947-5-1:2004/corrigendum Nov. 2004	2004
IEC 60947-5-4	-	Low-voltage switchgear and controlgear -- Part 5-4: Control circuit devices and switching elements - Method of assessing the performance of low-energy contacts - Special tests	EN 60947-5-4	-

EN 61557-8:2015

- 4 -

IEC 61010-1	2010	Safety requirements for electrical equipment for measurement, control and laboratory use - - Part 1: General requirements	EN 61010-1	2010
IEC 61010-2-030:2010/corrigendum May 2011	-	Safety requirements for electrical equipment for measurement, control and laboratory use - - Part 2-030: Particular requirements for testing and measuring circuits	-	-
IEC 61326-2-4	-	Electrical equipment for measurement, control and laboratory use - EMC requirements -- Part 2-4: Particular requirements - Test configurations, operational conditions and performance criteria for insulation monitoring devices according to IEC 61557-8 and for equipment for insulation fault location according to IEC 61557-8	EN 61326-2-4	-
IEC 61557-1	-	Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. - Equipment for testing, measuring or monitoring of protective measures -- Part 1: General requirements	EN 61557-1	-
IEC 61810-2	-	Electromechanical elementary relays -- Part 2: Reliability	EN 61810-2	-
IEC 62109-2	2011	Safety of power converters for use in photovoltaic power systems -- Part 2: Particular requirements for inverters	EN 62109-2	2011
CISPR 11	-	Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement	EN 55011	-

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 61557-8:2015

<https://standards.iteh.ai/catalog/standards/sist/9bf79943-20ba-4c56-9385-43915046b7f7/sist-en-61557-8-2015>



IEC 61557-8

Edition 3.0 2014-12

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measuring or monitoring of protective measures –

Part 8: Insulation monitoring devices for IT systems

<https://standards.iteh.ai/catalog/standards/sist/9bf79943-20ba-4c56-9385-33692207/iec-61557-8-2015>

Sécurité électrique dans les réseaux de distribution basse tension de 1 000 V c.a. et 1 500 V c.c. – Dispositifs de contrôle, de mesure ou de surveillance de mesures de protection –

Partie 8: Contrôleur permanent d'isolement pour réseaux IT

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX



ICS 17.220.20; 29.080.01; 29.240.01

ISBN 978-2-8322-1973-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references	8
3 Terms, definitions and abbreviations	9
3.1 Terms and definitions.....	9
3.2 Abbreviations.....	13
4 Requirements	13
4.1 General requirements	13
4.2 Types of IMDs.....	14
4.2.1 General	14
4.2.2 Mandatory functions provided by IMDs	14
4.2.3 Mandatory service function provided by the IMD – Test function	15
4.3 Optional functions provided by IMD.....	15
4.3.1 General	15
4.3.2 Local transformer monitoring warning (LTMW).....	15
4.3.3 Remote transformer monitoring warning (RTMW).....	15
4.3.4 Remote enabling and disabling command (REDC).....	16
4.4 Performance requirements.....	16
4.4.1 Specified response value R_{an}	16
4.4.2 System leakage capacitance C_e	16
4.4.3 Relative percentage uncertainty A of the specified response value R_{an}	16
4.4.4 Response time t_{an}	17
4.4.5 Measuring voltage U_m and measuring current I_m	17
4.4.6 Internal d.c. resistance R_i and internal impedance Z_i	17
4.4.7 Indication of the value of the insulation resistance R_F	18
4.4.8 Permanently admissible nominal voltage U_n	18
4.4.9 Permanently admissible extraneous d.c. voltage U_{fg}	18
4.4.10 Supply voltage U_S	18
4.5 Electromagnetic compatibility (EMC).....	18
4.6 Safety requirements.....	18
4.6.1 General	18
4.6.2 Clearances and creepage distances	19
4.6.3 Protection class and earth connection of an IMD	19
4.7 Climatic environmental conditions	19
4.8 Mechanical requirements	19
4.8.1 General	19
4.8.2 Product mechanical robustness	19
4.8.3 IP protection class requirements.....	20
5 Marking and operating instructions	21
5.1 Marking.....	21
5.2 Operating instructions.....	22
6 Tests	23
6.1 General.....	23
6.2 Type tests.....	23
6.2.1 General	23
6.2.2 Test of response values.....	23

6.2.3	Test of response time t_{an}	24
6.2.4	Test of peak value of the measuring voltage U_m	24
6.2.5	Test of the peak value of the measuring current I_m	24
6.2.6	Test of internal d.c. resistance R_i and internal impedance Z_i	25
6.2.7	Test of facilities for indicating the insulation resistance R_F	25
6.2.8	Test of effectiveness of the test device.....	25
6.2.9	Test of permanently admissible nominal voltage U_n	25
6.2.10	Test of permanently admissible extraneous d.c. voltage U_{fg}	25
6.2.11	Test of supply voltage U_S	26
6.2.12	Test of optional functions.....	26
6.2.13	Voltage tests.....	26
6.2.14	Test of electromagnetic compatibility (EMC).....	26
6.2.15	Inspection of the marking and operating instructions.....	26
6.2.16	Mechanical tests.....	26
6.3	Routine tests.....	27
6.3.1	General.....	27
6.3.2	Test of response values.....	27
6.3.3	Test of effectiveness of the test function.....	27
6.3.4	Test of facility for indicating the insulation resistance R_F	27
6.3.5	Voltage tests.....	27
6.3.6	Compliance with tests of 6.3.....	27
7	Overview of requirements and tests for IMDs.....	27
Annex A	(normative) Medical insulation monitoring devices (MED-IMD).....	29
A.1	Scope and object.....	29
A.2	Requirements.....	29
A.2.1	General.....	29
A.2.2	Types of MED-IMDs.....	29
A.2.3	Mandatory functions provided by MED-IMD.....	29
A.2.4	Performance requirements.....	30
A.2.5	Electromagnetic compatibility (EMC).....	31
A.3	Marking and operating instructions.....	31
A.4	Tests.....	32
A.4.1	General.....	32
A.4.2	Type tests.....	32
A.5	Overview of requirements and tests for MED-IMDs.....	32
Annex B	(informative) Monitoring of overload current and over-temperature.....	34
B.1	Scope and object.....	34
B.2	Requirements.....	34
B.2.1	General.....	34
B.2.2	Local transformer monitoring warning (LTMW) and/or remote transformer monitoring warning (RTMW).....	34
B.2.3	Monitoring of overload current.....	34
B.2.4	Monitoring of over-temperature of the IT system transformer.....	34
B.3	Operating instructions.....	35
B.4	Tests.....	35
B.4.1	General.....	35
B.4.2	Test of overload current and over-temperature monitoring.....	35
Annex C	(normative) Insulation monitoring devices for photovoltaic systems (PV-IMD).....	36
C.1	Scope and object.....	36

C.2	Requirements for PV-IMDs for PV installations	36
C.2.1	General	36
C.2.2	Types of PV-IMDs.....	37
C.2.3	Mandatory functions provided by PV-IMDs.....	37
C.2.4	Performance requirements.....	37
C.3	Marking and operating instructions.....	38
C.3.1	Marking	38
C.3.2	Operating instructions.....	39
C.4	Tests	39
C.4.1	General	39
C.4.2	Additional type tests	39
C.4.3	Additional routine tests	40
C.5	Overview of requirements and tests for PV-IMDs	40
Annex D (normative) Insulation monitoring function of a photovoltaic inverter (PV-IMF) or in a charge controller		41
D.1	Scope and object	41
D.2	Requirements for PV-IMFs	41
D.2.1	General requirements for PV-IMFs.....	41
D.2.2	Types of PV-IMFs	42
D.2.3	Mandatory functions provided by PV-IMFs	42
D.2.4	Performance requirements for PV-IMFs	43
D.2.5	Electromagnetic compatibility (EMC)	44
D.2.6	Safety requirements.....	44
D.2.7	Climatic environmental conditions.....	44
D.2.8	Mechanical requirements.....	44
D.3	Marking and operating instructions.....	44
D.3.1	Marking	44
D.3.2	Operating instructions.....	44
D.4	Tests	45
D.4.1	General	45
D.4.2	Type tests.....	45
D.4.3	Routine tests	46
D.5	Overview of requirements and tests for PV-IMF	46
Bibliography.....		47
Figure A.1 – Pictogram for marking a MED-IMD		32
Figure C.1 – Dynamic reference characteristics of d.c. PV system voltage.....		38
Figure C.2 – Pictogram for marking a PV-IMD.....		39
Table 1 – Abbreviations		13
Table 2 – Product mechanical requirements.....		20
Table 3 – Minimum IP requirements for IMDs.....		21
Table 4 – Pictograms for marking the type of IMD		22
Table 5 – Reference conditions for tests in operation.....		23
Table 6 – Reference conditions for storage tests (product not powered)		23
Table 7 – Requirements and tests applicable to IMD.....		28
Table A.1 – Summary of additional requirements and tests applicable to MED-IMDs.....		32

Table A.2 – Emission test for MED-IMDs	33
Table C.1 – Requirements and tests for PV-IMDs	40
Table D.1 – Requirements and tests for PV-IMF integrated in the inverter	46

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 61557-8:2015

<https://standards.iteh.ai/catalog/standards/sist/9bf79943-20ba-4c56-9385-43915046b7f7/sist-en-61557-8-2015>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS
UP TO 1 000 V AC AND 1 500 V DC – EQUIPMENT FOR TESTING,
MEASURING OR MONITORING OF PROTECTIVE MEASURES –**

Part 8: Insulation monitoring devices for IT systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61557-8 has been prepared by IEC technical committee 85: Measuring equipment for electrical and electromagnetic quantities.

This third edition cancels and replaces the second edition published in 2007. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Terms and definitions have been complemented;
- b) Abbreviations are listed and explained;
- c) Requirements have been revised;
- d) Mandatory and optional functions and their terminology have been adapted from IEC 61557-15;

- e) Mechanical requirements have been added;
- f) Information on operating instructions has been added;
- g) Type tests and routine tests have been complemented;
- h) An Annex C: 'Insulation monitoring devices for photovoltaic systems (PV-IMD)' has been added;
- i) An Annex D: 'Insulation monitoring function of a photovoltaic inverter (PV-IMF) or in a charge controller' has been added.

The text of this standard is based on the following documents:

FDIS	Report on voting
85/485/FDIS	85/502/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This part of IEC 61557 shall be used in conjunction with Part 1.

A list of all parts in the IEC 61557 series, published under the general title *Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measuring or monitoring of protective measures*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS UP TO 1 000 V AC AND 1 500 V DC – EQUIPMENT FOR TESTING, MEASURING OR MONITORING OF PROTECTIVE MEASURES –

Part 8: Insulation monitoring devices for IT systems

1 Scope

This part of IEC 61557 specifies the requirements for insulation monitoring devices (IMD) which permanently monitor the insulation resistance R_F to earth of unearthed a.c. IT systems, of a.c. IT systems with galvanically connected d.c. circuits having nominal voltages up to 1 000 V a.c., as well as of unearthed d.c. IT systems with voltages up to 1 500 V d.c. independent from the method of measuring.

IT systems are described in IEC 60364-4-41 amongst other literature. Additional data for the selection of devices in other standards should be noted.

NOTE Various standards specify the use of IMDs in IT systems. In such cases, the objective of the equipment is to signal a drop in insulation resistance R_F below a minimum limit.

IMDs according to this part of IEC 61557 can also be used for de-energized TT, TN and IT systems or appliances.

(standards.iteh.ai)

2 Normative references

SIST EN 61557-8:2015

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-1, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-6, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

IEC 60068-2-27, *Environmental testing – Part 2-27: Tests – Test Ea and guidance: Shock*

IEC 60364-7-710:2002, *Electrical installations of buildings – Part 7-710: Requirements for special installations or locations – Medical locations*

IEC 60691, *Thermal-links – Requirements and application guide*

IEC 60721-3-1, *Classification of environmental conditions – Part 3: Classification of groups of environmental parameters and their severities – Section 1: Storage*

IEC 60721-3-2, *Classification of environmental conditions – Part 3: Classification of groups of environmental parameters and their severities – Section 2: Transportation*

IEC 60721-3-3, *Classification of environmental conditions – Part 3: Classification of groups of environmental parameters and their severities – Section 3: Stationary use at weatherprotected locations*

IEC 60947-5-1, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 60947-5-4, *Low-voltage switchgear and controlgear – Part 5-4: Control circuit devices and switching elements – Method of assessing the performance of low-energy contacts – Special tests*

IEC 61010-1:2010, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*

IEC 61010-2-030, *Safety requirements for electrical equipment for measurement, control, and laboratory use –Part 2-030: Particular requirements for testing and measuring circuits*

IEC 61326-2-4, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 2-4: Particular requirements – Test configurations, operational conditions and performance criteria for insulation monitoring devices according to IEC 61557-8 and for equipment for insulation fault location according to IEC 61557-9*

IEC 61557-1, *Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measuring or monitoring of protective measures – Part 1: General requirements*

IEC 61810-2, *Electromechanical elementary relays – Part 2: Reliability*

IEC 62109-2:2011, *Safety of power converters for use in photovoltaic power systems – Part 2: Particular requirements for inverters*

CISPR 11, *Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement*

<https://standards.iteh.ai/catalog/standards/sis/9bf79943-20ba-4c56-9385-43915046b7f7/sist-en-61557-8-2015>

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61557-1 and the following apply.

3.1.1

extraneous d.c. voltage

U_{fg}

d.c. voltage occurring in a.c. systems between the a.c. conductors and earth (derived from d.c. parts)

3.1.2

insulation resistance

R_F

resistance in the system being monitored, including the resistance of all the connected appliances to earth

3.1.3

response value

R_a

value of the insulation resistance at which the device responds under specified conditions