



SLOVENSKI STANDARD

SIST EN 62682:2015

01-junij-2015

Upravljanje alarmov za procesno industrijo (IEC 62682:2014)

Management of alarms for the process industries (IEC 62682:2014)

Alarmmanagement in der Prozessindustrie (IEC 62682:2014)

Gestion de systèmes d'alarme dans les industries de transformation (IEC 62682:2014)

Ta slovenski standard je istoveten z: **EN 62682:2015**

[SIST EN 62682:2015](https://standards.iteh.ai/catalog/standards/sist/82aa14e3-3d99-416f-a49a-f2000b0aba45/sist-en-62682-2015)

<https://standards.iteh.ai/catalog/standards/sist/82aa14e3-3d99-416f-a49a-f2000b0aba45/sist-en-62682-2015>

ICS:

13.320	Alarmni in opozorilni sistemi	Alarm and warning systems
25.040.01	Sistemi za avtomatizacijo v industriji na splošno	Industrial automation systems in general

SIST EN 62682:2015

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 62682:2015](#)

<https://standards.iteh.ai/catalog/standards/sist/82aa14e3-3d99-416f-a49a-f2000b0aba45/sist-en-62682-2015>

EUROPEAN STANDARD

EN 62682

NORME EUROPÉENNE

EUROPÄISCHE NORM

January 2015

ICS 13.320; 25.040

English Version

Management of alarms systems for the process industries (IEC 62682:2014)

Gestion de systèmes d'alarme dans les industries de
transformation
(IEC 62682:2014)

Alarmmanagement in der Prozessindustrie
(IEC 62682:2014)

This European Standard was approved by CENELEC on 2014-11-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

(standards.iteh.ai)

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

https://standards.iteh.ai/catalog/standards/sist/82aa14e3-3d99-416f-a49a-f2000b0aba45/sist-en-62682-2015



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65A/704/FDIS, future edition 1 of IEC 62682, prepared by SC 65A "System aspects" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62682:2015.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-08-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-11-19

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62682:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61511 Series	NOTE	Harmonized as EN 61511 Series (not modified).
IEC 61511-1	NOTE	Harmonized as EN 61511-1.
IEC 62541-9	NOTE	Harmonized as EN 62541-9.

<https://standards.iteh.ai/catalog/standards/sist/82aa14e3-3d99-416f-a49a-f2000b0aba45/sist-en-62682-2015>



IEC 62682

Edition 1.0 2014-10

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Management of alarms systems for the process industries

Gestion de systèmes d'alarme dans les industries de transformation

[SIST EN 62682:2015](https://standards.iteh.ai/catalog/standards/sist/82aa14e3-3d99-416f-a49a-f2000b0aba45/sist-en-62682-2015)

<https://standards.iteh.ai/catalog/standards/sist/82aa14e3-3d99-416f-a49a-f2000b0aba45/sist-en-62682-2015>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XC

ICS 13.320; 25.040

ISBN 978-2-8322-1868-6

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	9
INTRODUCTION.....	11
1 Scope.....	12
1.1 General applicability.....	12
1.2 Exclusions and inclusions.....	13
1.2.1 Operators	13
1.2.2 Process sensors and final control elements	13
1.2.3 Safety instrumented systems.....	13
1.2.4 Event data	13
1.2.5 Alarm identification methods	14
1.2.6 Management of change	14
2 Normative references.....	14
3 Terms, definitions, and abbreviations	14
3.1 Terms and definitions	14
3.2 Abbreviations	22
4 Conformance to this standard	22
4.1 Conformance guidance.....	22
4.2 Existing systems.....	23
4.3 Responsibility	23
5 Alarm system models.....	23
5.1 Alarm systems	23
5.2 Alarm management lifecycle.....	23
5.2.1 Alarm management lifecycle model.....	23
5.2.2 Alarm management lifecycle stages.....	24
5.2.3 Alarm lifecycle entry points.....	27
5.2.4 Simultaneous and encompassing stages	27
5.2.5 Alarm management lifecycle loops.....	27
5.2.6 Alarm management lifecycle stage inputs and outputs	28
5.3 Alarm states.....	29
5.3.1 Alarm state transition diagram	29
5.3.2 Alarm states.....	30
5.3.3 Alarm state transition paths	31
5.4 Alarm response timeline	32
5.4.1 General	32
5.4.2 Normal (A).....	33
5.4.3 Unacknowledged (B).....	33
5.4.4 Acknowledged (C) and response	33
5.4.5 Return-to-normal (D).....	34
5.4.6 Consequence threshold.....	34
5.5 Feedback model of operator-process interaction	34
5.5.1 General	34
5.5.2 Detect.....	35
5.5.3 Diagnose	35
5.5.4 Respond	35
5.5.5 Performance shaping factors	35
6 Alarm philosophy	35

6.1	Purpose	35
6.2	Alarm philosophy contents.....	35
6.2.1	General	35
6.2.2	Purpose of alarm system	36
6.2.3	Definitions	37
6.2.4	References	37
6.2.5	Roles and responsibilities for alarm management	37
6.2.6	Alarm design principles	37
6.2.7	Rationalization	37
6.2.8	Alarm class definition	37
6.2.9	Highly managed alarms	38
6.2.10	HMI design principles.....	38
6.2.11	Prioritization method	38
6.2.12	Alarm setpoint determination	39
6.2.13	Alarm system performance monitoring	39
6.2.14	Alarm system maintenance.....	39
6.2.15	Testing of the alarm system	39
6.2.16	Approved enhanced and advanced alarming techniques	39
6.2.17	Alarm documentation	39
6.2.18	Implementation guidance	40
6.2.19	Management of change.....	40
6.2.20	Training	40
6.2.21	Alarm history preservation.....	40
6.2.22	Related site procedures	40
6.2.23	Specific alarm design considerations	41
6.2.24	Alarm system audit.....	41
6.3	Alarm philosophy development and maintenance	41
7	Alarm system requirements specification.....	41
7.1	Purpose	41
7.2	Recommendations.....	42
7.3	Development.....	42
7.4	Systems evaluation	42
7.5	Customization	43
7.6	Alarm system requirements testing	43
8	Identification.....	43
8.1	Purpose	43
8.2	Alarm identification methods.....	43
8.3	Identification training	43
9	Rationalization.....	43
9.1	Purpose	43
9.2	Rationalization documentation	44
9.2.1	Rationalization documentation requirements	44
9.2.2	Rationalization documentation recommendations	44
9.3	Alarm justification.....	44
9.3.1	Alarm justification process.....	44
9.3.2	Justification approach	44
9.3.3	Individual alarm justification	45
9.3.4	Impact on alarm system	45
9.4	Alarm setpoint determination	45

9.5	Prioritization.....	45
9.6	Removal	45
9.7	Classification	46
9.8	Review.....	46
9.9	Use of documentation.....	46
10	Detailed design: Basic alarm design.....	46
10.1	Purpose	46
10.2	Usage of alarm states	46
10.2.1	Alarm state triggering.....	46
10.2.2	Alarm states and other logic functions	46
10.2.3	Alarm suppression and other logic functions	47
10.3	Alarm types.....	47
10.4	Alarm attributes.....	47
10.4.1	General	47
10.4.2	Alarm description	48
10.4.3	Alarm setpoints	48
10.4.4	Alarm priority	48
10.4.5	Alarm deadbands	48
10.4.6	Alarm on-delay and off-delay.....	48
10.5	Programmatic changes to alarm attributes	49
10.6	Review basic alarm design.....	49
11	Detailed design: Human-machine interface design for alarm systems.....	49
11.1	Purpose	49
11.2	HMI functions.....	49
11.2.1	General.....	49
11.2.2	HMI information requirements.....	49
11.2.3	HMI functional requirements.....	50
11.2.4	HMI display requirements.....	50
11.2.5	Alarm records requirements	50
11.2.6	Alarm records recommendations	50
11.3	Alarm states indications	50
11.3.1	General	50
11.3.2	Required alarm state indications.....	51
11.3.3	Recommended alarm state indications.....	51
11.3.4	Audible alarm state indications	52
11.4	Alarm priority indications	52
11.4.1	General	52
11.4.2	Alarm priority indication requirements.....	52
11.4.3	Colour alarm priority indications requirements	52
11.4.4	Recommended alarm priority indications.....	53
11.5	Alarm message indications	53
11.5.1	General	53
11.5.2	Recommended alarm message indications	53
11.6	Alarm displays	53
11.6.1	General	53
11.6.2	Alarm summary display	54
11.6.3	Alarm summary status.....	55
11.6.4	Alarm log displays.....	55
11.6.5	Process displays	56

11.6.6	Tag detail displays	56
11.6.7	Other display elements.....	56
11.7	Alarm shelving	56
11.7.1	General	56
11.7.2	Alarm shelving functional requirements.....	56
11.7.3	Alarm shelving functional recommendations.....	57
11.7.4	Shelved alarm displays	57
11.8	Out-of-service alarms	57
11.8.1	General	57
11.8.2	Out-of-service alarm functional requirements	58
11.8.3	Out-of-service alarm displays	58
11.9	Alarms suppressed by design	58
11.9.1	General	58
11.9.2	Designed suppression functional requirements	58
11.9.3	Design suppression functional recommendations	59
11.9.4	Suppressed-by-design displays	59
11.10	Alarm annunciator integration	59
11.10.1	General	59
11.10.2	Alarm annunciator integration recommendations	59
11.10.3	Alarm annunciator display integration recommendations	60
11.11	Safety alarm HMI	60
11.11.1	General	60
11.11.2	Independent safety alarm HMI	60
12	Detailed design: Enhanced and advanced alarm methods.....	60
12.1	Purpose	60
12.2	Basis of enhanced and advanced alarming.....	60
12.2.1	General	60
12.2.2	Effort, manpower requirements and complexity	60
12.3	Information linking.....	61
12.4	Logic-based alarming	61
12.4.1	General	61
12.4.2	Alarm attribute modification	61
12.4.3	Externally enabled systems	61
12.4.4	Logical alarm suppression and attribute modification	61
12.4.5	State-based alarming	61
12.5	Model-based alarming	61
12.6	Additional alarming considerations	62
12.6.1	General	62
12.6.2	Non-control room considerations	62
12.6.3	Remote alarm systems.....	62
12.6.4	Supplementary alarm systems.....	62
12.6.5	Batch process considerations.....	62
12.7	Training, testing, and auditing systems	63
12.8	Alarm attribute enforcement	63
13	Implementation.....	63
13.1	Purpose	63
13.2	Implementation planning	63
13.3	Implementation training	63
13.3.1	General	63

13.3.2	Implementation training	63
13.3.3	Implementation training requirements	64
13.3.4	Training documentation requirements for highly managed alarms	64
13.3.5	Training documentation recommendations	64
13.3.6	Implementation training requirements for new or modified alarm systems	64
13.3.7	Implementation training recommendations for new or modified alarm systems	64
13.4	Implementation testing and validation	64
13.4.1	General	64
13.4.2	Implementation testing requirements for highly managed alarms	64
13.4.3	Implementation testing recommendations for new or modified alarms	65
13.4.4	Implementation testing requirements for new or modified alarm systems	65
13.5	Implementation documentation	65
13.5.1	General	65
13.5.2	Documentation requirements	65
13.5.3	Implementation documentation recommendations	65
14	Operation	66
14.1	Purpose	66
14.2	Alarm response procedures	66
14.2.1	Alarm response requirements	66
14.2.2	Alarm response procedure recommendations	66
14.3	Alarm shelving	66
14.3.1	Alarm shelving requirements	66
14.3.2	Alarm shelving for highly managed alarms	67
14.3.3	Alarm shelving recommendations	67
14.3.4	Alarm shelving record requirements	67
14.4	Refresher training for operators	67
14.4.1	Refresher training requirements for operators	67
14.4.2	Refresher training documentation for highly managed alarms	67
14.4.3	Refresher training content for highly managed alarms	67
14.4.4	Refresher training recommendations for alarms	67
15	Maintenance	68
15.1	Purpose	68
15.2	Periodic alarm testing	68
15.2.1	General	68
15.2.2	Periodic alarm testing requirements	68
15.2.3	Periodic alarm testing for highly managed alarms	68
15.2.4	Periodic alarm test procedure requirements	68
15.2.5	Periodic alarm test procedure recommendations	68
15.2.6	Periodic alarm testing recommendations	69
15.3	Out-of-service alarms	69
15.3.1	General	69
15.3.2	Out-of-service process requirements	69
15.3.3	Out-of-service highly managed alarms	69
15.3.4	Out-of-service process recommendations	69
15.3.5	Requirements for returning alarms to service	69
15.4	Equipment repair	69
15.5	Equipment replacement	70

15.6	Refresher training for maintenance	70
15.6.1	General requirements.....	70
15.6.2	Refresher training requirements for highly managed alarms	70
15.6.3	Refresher training recommendations for alarms	70
16	Monitoring and assessment	70
16.1	Purpose	70
16.2	Requirements.....	70
16.3	Monitoring, assessment, audit, and benchmark.....	70
16.4	Alarm system monitoring	71
16.5	Alarm system performance metrics	71
16.5.1	General	71
16.5.2	Average alarm rate per operator console	71
16.5.3	Peak alarm rate per operator console	72
16.5.4	Alarm floods.....	72
16.5.5	Frequently occurring alarms	73
16.5.6	Chattering and fleeting alarms.....	73
16.5.7	Stale alarms.....	73
16.5.8	Annunciated alarm priority distribution	73
16.5.9	Alarm priority distribution	74
16.6	Unauthorized alarm suppression.....	74
16.7	Alarm attribute monitoring	74
16.8	Reporting of alarm system analyses	74
16.9	Alarm performance metric summary.....	74
17	Management of change.....	75
17.1	Purpose https://standards.iteh.ai/catalog/standards/sist/82aa14e3-3d99-416f-a49a-7299b0ad157c/iec-62682-2015	75
17.2	Changes subject to management of change	75
17.3	Change documentation requirements.....	76
17.4	Change documentation recommendations.....	76
17.5	Alarm removal recommendations	76
17.6	Alarm attribute modification recommendations	76
18	Audit	77
18.1	Purpose	77
18.2	Benchmark.....	77
18.2.1	General	77
18.2.2	Initial audit or benchmark requirements	77
18.3	Audit interviews.....	77
18.4	Audit recommendations	77
18.5	Action plans	78
	Bibliography	79
	Figure 1 – Alarm system dataflow.....	13
	Figure 2 – Alarm management lifecycle	24
	Figure 3 – Alarm state transition diagram	29
	Figure 4 – Alarm response timeline	33
	Figure 5 – Feedback model of operator-process interaction	35
	Table 1 – Alarm management lifecycle stage inputs and outputs	28

Table 2 – Alarm states	31
Table 3 – Required and recommended alarm philosophy content	36
Table 4 – Recommended alarm state indications	52
Table 5 – Average alarm rates	72
Table 6 – Annunciated alarm priority distribution	73
Table 7 – Recommended alarm performance metrics summary	75

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 62682:2015](https://standards.iteh.ai/catalog/standards/sist/82aa14e3-3d99-416f-a49a-f2000b0aba45/sist-en-62682-2015)

<https://standards.iteh.ai/catalog/standards/sist/82aa14e3-3d99-416f-a49a-f2000b0aba45/sist-en-62682-2015>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MANAGEMENT OF ALARMS SYSTEMS FOR THE PROCESS INDUSTRIES

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62682 has been prepared by subcommittee 65A: System aspects, of IEC technical committee 65: Industrial-process measurement, control and automation.

The text of this standard is based on the following documents:

FDIS	Report on voting
65A/704/FDIS	65A/706/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 62682:2015](#)

<https://standards.iteh.ai/catalog/standards/sist/82aa14e3-3d99-416f-a49a-f2000b0aba45/sist-en-62682-2015>

INTRODUCTION

Purpose

This International Standard addresses the development, design, installation, and management of alarm systems in the process industries. Alarm management includes multiple work processes throughout the alarm system lifecycle. This standard defines the terminology and models to develop an alarm system, and it defines the work processes recommended to effectively maintain the alarm system throughout the lifecycle.

This standard was adapted from ANSI/ISA-18.2-2009, *Management of Alarm Systems for the Process Industries*, an International Society of Automation (ISA) standard, and with due consideration of other guidance documents that have been developed throughout industry. Ineffective alarm systems have often been cited as contributing factors in the investigation reports following major process incidents. This standard is intended to provide a methodology that will result in the improved safety of the process industries.

This standard is not the first effort to define terminology and practices for effective alarm systems. In 1999 the Engineering Equipment and Materials Users' Association (EEMUA) issued Publication 191, *Alarm Systems: A Guide to Design, Management and Procurement*. In 2003 the User Association of Process Control Technology in Chemical and Pharmaceutical Industries (NAMUR) issued worksheet NA 102, *Alarm Management*.

During the development of this standard every effort was made to keep terminology and practices consistent with the previous work of these respected organizations and committees.

This document provides requirements for alarm management and alarm systems. It is intended for those individuals and organizations that

- a) manufacture or implement embedded alarm systems,
- b) manufacture or implement third-party alarm system software,
- c) design or install alarm systems,
- d) operate and/or maintain alarm systems, and
- e) audit or assess alarm system performance.

Organization

This standard is organized in two parts. The first part is introductory in nature, (Clauses 1 to 5). The main body of the standard follows (Clauses 6 to 18).