



SLOVENSKI STANDARD

SIST EN 61936-1:2011/AC:2013

01-september-2013

Nadomešča:

SIST EN 61936-1:2010/AC:2011:2012

SIST EN 61936-1:2011/AC:2012

Elektroenergetski postroji za izmenične napetosti nad 1 kV - 1. del: Skupna pravila

Power installations exceeding 1 kV a.c. - Part 1: Common rules

Starkstromanlagen mit Nennwechselspannungen über 1 kV - Teil 1: Allgemeine Bestimmungen

Installations électriques en courant alternatif de puissance supérieure à 1 kV - Partie 1: Règles communes

<https://standards.iteh.ai/catalog/standards/sist/62363907-e353-4997-9dbe-b1ae47627428/sist-en-61936-1-2011-ac-2013>

Ta slovenski standard je istoveten z: EN 61936-1:2010/AC:2013

ICS:

29.240.01	Omrežja za prenos in distribucijo električne energije na splošno	Power transmission and distribution networks in general
-----------	--	---

SIST EN 61936-1:2011/AC:2013 en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 61936-1:2011/AC:2013

<https://standards.iteh.ai/catalog/standards/sist/62363907-e353-4997-9dbe-b1ae47627428/sist-en-61936-1-2011-ac-2013>



Corrigendum to EN 61936-1:2010

English version

Add the following SNCs in Annex ZA:

<u>Clause</u>	<u>Special national condition</u>
---------------	-----------------------------------

6.2.9.5	Iceland
----------------	----------------

Minimum depth of a buried cable is 0,7 m.

7.2.6	Iceland
--------------	----------------

Minimum height of the external fence is 2 500 mm.

7.7	Iceland
------------	----------------

Minimum height H' of live parts above accessible surfaces to the general public shall be: $H' = 5\,500$ mm for rated voltages U_m up to 52 kV.

[SIST EN 61936-1:2011/AC:2013](https://standards.iteh.ai/catalog/standards/sist/62363907-e353-4997-9dbe-b1ae47627428/sist-en-61936-1-2011-ac-2013)

<https://standards.iteh.ai/catalog/standards/sist/62363907-e353-4997-9dbe-b1ae47627428/sist-en-61936-1-2011-ac-2013>

February 2013