

SLOVENSKI STANDARD

SIST EN 60947-4-3:2014

01-september-2014

Nadomešča:

SIST EN 60947-4-3:2000

SIST EN 60947-4-3:2000/A1:2007

SIST EN 60947-4-3:2000/A2:2011

Nizkonapetostne stikalne in krmilne naprave - 4-3. del: Kontaktorji in motorski zaganjalniki, polprevodniški krmilniki in kontaktorji na izmenični tok za nemotorske obremenitve (IEC 60947-4-3:2014)

Low-voltage switchgear and controlgear - Part 4-3: Contactors and motor-starters - AC semiconductor controllers and contactors for non-motor loads

Niederspannungsschaltgeräte - Teil 4-3: Schütze und Motorstarter - Halbleiter-Steuergeräte und -Schütze für nichtmotorische Lasten für Wechselspannung

Appareillage à basse tension - Partie 4-3: Contacteurs et démarreurs de moteurs - Gradateurs et contacteurs à semiconducteurs pour charges, autres que des moteurs, à courant alternatif

Ta slovenski standard je istoveten z: EN 60947-4-3:2014

ICS:

29.130.20	Nizkonapetostne stikalne in krmilne naprave	Low voltage switchgear and controlgear
-----------	---	--

SIST EN 60947-4-3:2014

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60947-4-3:2014

<https://standards.iteh.ai/catalog/standards/sist/83ce812a-2656-4d90-b6e3-bfae1bae3bbe/sist-en-60947-4-3-2014>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60947-4-3

June 2014

ICS 29.130.20; 31.180

Supersedes EN 60947-4-3:2000

English Version

**Low-voltage switchgear and controlgear - Part 4-3: Contactors
and motor-starters - AC semiconductor controllers and
contactors for non-motor loads
(IEC 60947-4-3:2014)**

Appareillage à basse tension - Partie 4-3: Contacteurs et
démarreurs de moteurs - Gradateurs et contacteurs à
semiconducteurs pour charges, autres que des moteurs, à
courant alternatif
(CEI 60947-4-3:2014)

Niederspannungsschaltgeräte - Teil 4-3: Schütze und
Motorstarter - Halbleiter-Steuergeräte und -Schütze für
nichtmotorische Lasten für Wechselspannung
(IEC 60947-4-3:2014)

This European Standard was approved by CENELEC on 2014-06-11. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 121A/2/FDIS, future edition 2 of IEC 60947-4-3, prepared by SC 17B "Low-voltage switchgear and controlgear" of IEC/TC 17 "Switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60947-4-3:2014.

The following dates are fixed:

- latest date by which the document has to be (dop) 2015-03-11
implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2017-06-11
standards conflicting with the
document have to be withdrawn

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and covers essential requirements of EU Directive 2004/108/EC.

For relationship with EU Directive(s), see informative Annex ZZ, which is an integral part of this document.

This document supersedes EN 60947-4-3:2000.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD, 2006/95/EC).

Endorsement notice

The text of the International Standard IEC 60947-4-3:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60085:2007	NOTE	Harmonized as EN 60085:2008 (modified).
IEC 60146 (series)	NOTE	Harmonized as EN 60146 (series) (not modified).
IEC 60664 (series)	NOTE	Harmonized as EN 60664 (series) (not modified).
IEC 60947-4-2:2011	NOTE	Harmonized as EN 60947-4-2:2012 (modified).
IEC 61439 (series)	NOTE	Harmonized as EN 61439 (series) (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60269-1	2006	Low-voltage fuses -- Part 1: General requirements	EN 60269-1	2007
IEC 60410	1973	Sampling plans and procedures for inspection by attributes	-	-
IEC 60947-1	2007	Low-voltage switchgear and controlgear -- Part 1: General rules	EN 60947-1	2007
+A1	2010		+A1	2011
IEC 61000-4 (series)	-	Electromagnetic compatibility (EMC) -- Part 4-1: Testing and measurement techniques (series) - Overview of IEC 61000-4 series	EN 61000-4	-
IEC 61000-4-5	2005	Electromagnetic compatibility (EMC) -- Part 4-5: Testing and measurement techniques - Surge immunity test	EN 61000-4-5	2006
CISPR 11 (mod)	2009	Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement	EN 55011	2009
CISPR 11:2009/A1	2010		EN 55011:2009/A1	2010

Annex ZZ (informative)

Coverage of Essential Requirements of EU Directives

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and within its scope the standard covers protection requirements of Annex I Article 1 of the EU Directive 2004/108/EC.

Compliance with this standard provides presumption of conformity with the specified essential requirements of the Directives concerned.

NOTE: Other requirements and other EU Directives may be applicable to the products falling within the scope of this standard.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60947-4-3:2014

<https://standards.iteh.ai/catalog/standards/sist/83ce812a-2656-4d90-b6e3-bfae1bae3bbe/sist-en-60947-4-3-2014>



IEC 60947-4-3

Edition 2.0 2014-05

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Low-voltage switchgear and controlgear –
Part 4-3: Contactors and motor-starters – AC semiconductor controllers and
contactors for non-motor loads

Appareillage à basse tension –
Partie 4-3: Contacteurs et démarreurs de moteurs – Gradateurs et contacteurs à
semiconducteurs pour charges, autres que des moteurs, à courant alternatif

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XC

ICS 29.130.20, 31.180

ISBN 978-2-8322-1567-8

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	10
3 Terms, definitions, symbols and abbreviations.....	10
3.1 Terms and definitions concerning a.c. semiconductor (non-motor-load) control devices.....	11
3.1.1 AC semiconductor controllers and contactors (solid-state contactors) (see Figure 1).....	11
3.1.2 Hybrid controllers and contactors (see Figure 1).....	14
3.2 Vacant	18
3.3 Symbols and abbreviations	18
4 Classification.....	18
5 Characteristics of a.c. semiconductor controllers and contactors	19
5.1 Summary of characteristics	19
5.2 Type of equipment	19
5.3 Rated and limiting values for main circuits	22
5.3.1 Rated voltages	22
5.3.2 Currents	22
5.3.3 Rated frequency	22
5.3.4 Rated duty	22
5.3.5 Normal load and overload characteristics	23
5.3.6 Rated conditional short-circuit current.....	24
5.4 Utilization category	24
5.4.1 Assignment of ratings based on the results of tests	25
5.5 Control circuits.....	26
5.6 Auxiliary circuits.....	26
5.7 Vacant	26
5.8 Coordination with short-circuit protective devices (SCPD)	26
6 Product information	26
6.1 Nature of information	26
6.2 Marking.....	28
6.3 Instructions for installation, operation and maintenance	28
7 Normal service, mounting and transport conditions.....	28
7.1 Normal service conditions	28
7.1.1 Ambient air temperature	28
7.1.2 Altitude	28
7.1.3 Atmospheric conditions.....	28
7.1.4 Shock and vibrations	29
7.2 Conditions during transport and storage.....	29
7.3 Mounting.....	29
7.4 Electrical system disturbances and influences	29
8 Constructional and performance requirements	29
8.1 Constructional requirements	29
8.1.1 General	29

8.1.2	Materials	29
8.1.3	Current-carrying parts and their connections	29
8.1.4	Clearances and creepage distances	29
8.1.5	Actuator	30
8.1.6	Indication of the contact position	30
8.1.7	Additional requirements for equipment suitable for isolation	30
8.1.8	Terminals	30
8.1.9	Additional requirements for equipment provided with a neutral pole	30
8.1.10	Provisions for protective earthing	30
8.1.11	Enclosures for equipment	30
8.1.12	Degrees of protection of enclosed equipment	30
8.1.13	Conduit pull-out, torque and bending with metallic conduits	30
8.2	Performance requirements	30
8.2.1	Operating conditions	30
8.2.2	Temperature rise	32
8.2.3	Dielectric properties	34
8.2.4	Normal load and overload performance requirements	35
8.2.5	Coordination with short-circuit protective devices	42
8.3	EMC requirements	42
8.3.1	General	42
8.3.2	Emission	43
8.3.3	Immunity	43
9	Tests	45
9.1	Kinds of tests	45
9.1.1	General	45
9.1.2	Type tests	45
9.1.3	Routine tests	45
9.1.4	Sampling tests	45
9.1.5	Special tests	46
9.2	Compliance with constructional requirements	46
9.3	Compliance with performance requirements	46
9.3.1	Test sequences	46
9.3.2	General test conditions	47
9.3.3	Performance under no load, normal load and overload conditions	47
9.3.4	Performance under short-circuit conditions	54
9.3.5	Disponible	58
9.4	General	58
9.4.1	EMC emission tests	58
9.4.2	EMC immunity tests	59
9.5	Routine and sampling tests	61
9.5.1	General	61
9.5.2	Operation and operating limits	61
9.5.3	Dielectric tests	61
Annex A (normative)	Marking and identification of terminals	62
A.1	General	62
A.2	Marking and identification of terminals of controller and contactors	62
A.2.1	Marking and identification of terminals of main circuits	62

A.2.2	Marking and identification of terminals of control circuits	62
A.2.3	Marking and identification of auxiliary circuits	62
Annex B (informative)	Typical service conditions for controllers and contactors	65
B.1	Control of resistive heating elements	65
B.2	Switching of electric discharge lamp controls	65
B.3	Switching of incandescent lamps	66
B.4	Switching of transformers.....	66
B.5	Switching of capacitor banks.....	66
Annex C	Vacant.....	67
Annex D	Vacant.....	68
Annex E	Vacant.....	69
Annex F (informative)	Operating capability.....	70
Annex G	Vacant.....	73
Annex H	Vacant.....	74
Annex I (normative)	Modified test circuit for short-circuit testing of semiconductor contactors and controllers.....	75
Annex J (informative)	Flowchart for constructing bypassed semiconductor controllers tests	77
Bibliography.....		78
Figure 1 – Graphical possibilities of controllers.....		13
Figure 2 – Methods of connecting		21
Figure F.1 – Thermal stability test profile		70
Figure F.2 – Overload capability test profile		71
Figure F.3 – Blocking and commutating capability test profile		72
Figure I.1 – Modified circuit for short-circuit testing of semiconductor devices.....		75
Figure I.2 – Time line for the short-circuit test of 9.3.4.1.6		76
Table 1 – Functional possibilities of controllers and contactors		14
Table 2 – Utilization categories		25
Table 3 – Relative levels of severity.....		25
Table 4 – Temperature rise limits for insulated coils in air and in oil.....		34
Table 5 – Intermittent duty test cycle data.....		34
Table 6 – Minimum overload current withstand time (T_X) in relation to overload current ratio (X)		36
Table 7 – Minimum requirements for thermal stability test conditions		37
Table 8 – Minimum requirements for overload capability test conditions		38
Table 9 – Minimum requirements and conditions for performance testing, including blocking and commutating capability.....		39
Table 10 – Making and breaking capacity test – Making and breaking conditions according to utilization categories for the mechanical switching device of hybrid semiconductor controller and contactor H4, H5.....		40
Table 11 – Conventional operational performance – Making and breaking conditions according to utilization categories for the mechanical switching device of hybrid controllers and contactors H4B, H5B		41
Table 12 – Specific performance criteria when EM disturbances are present		44

Table 13 – Thermal stability test specifications	51
Table 14 – Initial case temperature requirements	52
Table 15 – Terminal disturbance voltage limits for conducted radiofrequency emission	59
Table 16 – Radiated emissions test limits	59
Table A.1 – Main circuit terminal markings	62

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[SIST EN 60947-4-3:2014](https://standards.iteh.ai/catalog/standards/sist/83ce812a-2656-4d90-b6e3-bfae1bae3bbe/sist-en-60947-4-3-2014)

<https://standards.iteh.ai/catalog/standards/sist/83ce812a-2656-4d90-b6e3-bfae1bae3bbe/sist-en-60947-4-3-2014>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 4-3: Contactors and motor-starters –
AC semiconductor controllers and
contactors for non-motor loads**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60947-4-3 has been prepared by subcommittee 17B: Low-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

This second edition cancels and replaces the first edition published in 1999, Amendment 1:2006 and Amendment 2:2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Update of the marking requirements (6.1);
- b) Update of the EMC requirements (8.3.2); and
- c) Update of the tests requirements (9.3.1, 9.4, 9.4.1.1, 9.4.1.2, 9.4.2.1, 9.4.2.2, 9.4.2.3, 9.4.2.4, 9.4.2.6).

The text of this standard is based on the following documents:

FDIS	Report on voting
121A/2/FDIS	121A/14/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60947 series, published under the general title *Low-voltage switchgear and controlgear*, can be found on the IEC website.

This standard shall be read in conjunction with IEC 60947-1, *Low voltage switchgear and controlgear – Part 1: General rules*. The provisions of the general rules are applicable to this standard, where specifically called for.

The provisions of the general rules (IEC 60947-1) are applicable to this standard, where specifically called for. Clauses and subclauses thus applicable, as well as tables, figures, and annexes, are identified by reference to IEC 60947-1, for example 1.2.3 of IEC 60947-1:2007, Amendment 1 (2010), Table 4 of IEC 60947-1:2007, Amendment 1 (2010) or Annex A of IEC 60947-1:2007.

iTeh STANDARD PREVIEW

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed, [SIST EN 60947-4-3:2014](https://standards.iteh.ai/catalog/standards/sist/83ce812a-2656-4d90-b6e3-bfae1bae3bbe/sist-en-60947-4-3-2014)
- withdrawn, <https://standards.iteh.ai/catalog/standards/sist/83ce812a-2656-4d90-b6e3-bfae1bae3bbe/sist-en-60947-4-3-2014>
- replaced by a revised edition, or
- amended.

INTRODUCTION

This part of IEC 60947 covers low-voltage a.c. semiconductor controllers and contactors (solid-state contactors) intended for the use with non-motor loads. As controllers, they have many capabilities beyond the simple switching on and off of non-motor loads. As contactors, they perform the same functions as mechanical contactors, but utilize one or more semiconductor switching devices in their main poles.

The devices may be single-pole or multi-pole (see 2.3.1 of IEC 60947-1:2007,). This standard refers to complete devices rated as a unit incorporating all necessary heat-sinking material and terminals. It includes devices with all necessary terminals, which are supplied with or without heat-sink in knocked-down form for combination by the users, when the manufacturer gives with the device detailed information about choosing the heat-sink and mounting the device on the heat-sink.

The generic term, "controller", is used in this standard wherever the unique features of the power semiconductor switching elements are the most significant points of interest. The generic term "contactor" is used in this standard wherever the feature of simple switching on and off is the most significant point of interest. Specific designations (for example, form 4, form HxB, etc.) are used wherever the unique features of various configurations comprise significant points of interest.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 60947-4-3:2014](https://standards.iteh.ai/catalog/standards/sist/83ce812a-2656-4d90-b6e3-bfae1bae3bbe/sist-en-60947-4-3-2014)

<https://standards.iteh.ai/catalog/standards/sist/83ce812a-2656-4d90-b6e3-bfae1bae3bbe/sist-en-60947-4-3-2014>

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 4-3: Contactors and motor-starters – AC semiconductor controllers and contactors for non-motor loads

1 Scope

This part of IEC 60947 applies to a.c. semiconductor non-motor load controllers and contactors intended for performing electrical operations by changing the state of a.c. electric circuits between the ON-state and the OFF-state. Typical applications are classified by utilization categories given in Table 2.

As controllers, they may be used to reduce the amplitude of the r.m.s. a.c. voltage on the load terminals from that of the applied voltage – either continuously or for a specified period of time. The half-wave period of the a.c. wave form remains unchanged from that of the applied voltage.

They may include a series mechanical switching device and are intended to be connected to circuits, the rated voltage of which does not exceed 1 000 V a.c.

This standard characterizes controllers and contactors for use with or without bypass switching devices.

The semiconductor controllers and contactors dealt with in this standard are not normally intended to interrupt short-circuit currents. Therefore, suitable short-circuit protection (see 8.2.5) should form part of the installation but not necessarily of the controller itself.

In this context, this standard gives requirements for semiconductor controllers and contactors associated with separate short-circuit protective devices.

This standard does not apply to:

- operation of a.c. and d.c. motors;
- low-voltage a.c. semiconductor motor controllers and starters covered by IEC 60947-4-2;
- electronic a.c. power controllers covered by the IEC 60146 series;
- all-or-nothing solid-state relays.

Contactors and control-circuit devices used in semiconductor controllers and contactors should comply with the requirements of their relevant product standard. Where mechanical switching devices are used, they should meet the requirements of their own IEC product standard and the additional requirements of this standard.

The object of this standard is to state

- a) the characteristics of semiconductor controllers and contactors and associated equipment;
- b) the conditions with which semiconductor controllers and contactors should comply with reference to:
 - their operation and behaviour;
 - their dielectric properties;
 - the degrees of protection provided by their enclosures, where applicable;