



SLOVENSKI STANDARD
SIST HD 60364-7-710:2012/AC:2013
01-maj-2013

Nizkonapetostne električne inštalacije - 7-710. del: Zahteve za posebne inštalacije ali lokacije - Medicinski prostori - Popravek AC

Low-voltage electrical installations - Part 7-710: Requirements for special installations or locations - Medical locations

Errichten von Niederspannungsanlagen - Teil 7-710: Anforderungen für Betriebsstätten, Räume und Anlagen besonderer Art - Medizinisch genutzte Bereiche

Installations électriques à basse tension - Partie 7-710: Règles pour les installations ou emplacements spéciaux - Locaux à usages médicaux

<https://standards.iteh.ai/catalog/standards/sist/cb8f63b2-5dd4-4e79-9353-57e224b04467/sist-hd-60364-7-710-2012-ac-2013>

Ta slovenski standard je istoveten z: HD 60364-7-710:2012/AC:2013

ICS:

11.020	Medicinske vede in zdravstvenovarstveni pripomočki na splošno	Medical sciences and health care facilities in general
91.140.50	Sistemi za oskrbo z elektriko	Electricity supply systems

SIST HD 60364-7-710:2012/AC:2013 **en,fr,de**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST HD 60364-7-710:2012/AC:2013](https://standards.iteh.ai/catalog/standards/sist/cb8f63b2-5dd4-4e79-9353-57e224b04467/sist-hd-60364-7-710-2012-ac-2013)

<https://standards.iteh.ai/catalog/standards/sist/cb8f63b2-5dd4-4e79-9353-57e224b04467/sist-hd-60364-7-710-2012-ac-2013>



Corrigendum to HD 60364-7-710:2012

English version

Add the following special national conditions to the Annex ZA:

Subclause	Special national conditions
710.415.2.2	<p>Slovakia</p> <p>Replace the first paragraph as follows:</p> <p>In medical locations of group 1 the resistance of the protective conductors, including the resistance of the connections, between the terminals for the protective conductor of socket-outlets and of fixed equipment or any extraneous conductive-parts and the equipotential bonding bus bar, shall not exceed 0,2 Ω.</p>
710.512.2.1	<p>Slovakia</p> <p>Replace the paragraph above NOTE 4 as follows:</p> <p>Electrical devices (e.g. socket-outlets and switches) shall be installed at a distance of at least 0,2 m in all directions (centre to centre) from any medical gas-outlets, so as to minimize the risk of ignition of flammable gases.</p>
Table B.1, line 19	<p>Slovakia</p> <p>In Slovakia, haemodialysis rooms fall into group 2.</p>

March 2013