



SLOVENSKI STANDARD

SIST EN 62453-1:2017

01-november-2017

Nadomešča:
SIST EN 62453-1:2010

Specifikacija vmesnika orodja procesne naprave (FDT) - 1. del: Pregled in vodilo (IEC 62453-1:2016)

Field Device Tool (FDT) interface specification -- Part 1: Overview and guidance (IEC 62453-1:2016)

Field Device Tool (FDT)-Schnittstellenspezifikation - Teil 1: Überblick und Leitfaden - Teil 1: Überblick und Leitfaden (IEC 62453-1:2016)

Spécification des interfaces des outils des dispositifs de terrain (FDT) -- Partie 1: Vue générale et recommandations (IEC 62453-1:2016)

Ta slovenski standard je istoveten z: EN 62453-1:2017

ICS:

25.040.40	Merjenje in krmiljenje industrijskih postopkov	Industrial process measurement and control
35.240.50	Uporabniške rešitve IT v industriji	IT applications in industry

SIST EN 62453-1:2017

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 62453-1:2017

<https://standards.iteh.ai/catalog/standards/sist/13f81f11-496e-4de1-95da-3c1c3623441d/sist-en-62453-1-2017>

EUROPEAN STANDARD

EN 62453-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2017

ICS 25.040.40; 35.100.05; 35.110

Supersedes EN 62453-1:2009

English Version

Field Device Tool (FDT) interface specification - Part 1: Overview and guidance (IEC 62453-1:2016)

Spécification des interfaces des outils des dispositifs de terrain (FDT) - Partie 1: Vue d'ensemble et guide
(IEC 62453-1:2016)

Field Device Tool (FDT)-Schnittstellenspezifikation - Teil 1:
Überblick und Leitfaden - Teil 1: Überblick und Leitfaden
(IEC 62453-1:2016)

This European Standard was approved by CENELEC on 2017-01-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

EN 62453-1:2017**European foreword**

The text of document 65E/333/CDV, future edition 2 of IEC 62453-1, prepared by SC 65E "Devices and integration in enterprise systems" of IEC/TC 65 "Industrial process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62453-1:2017.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2017-10-20
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2020-01-20

This document supersedes EN 62453-1:2009.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62453-1:2016 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

	<u>SIST EN 62453-1:2017</u>	
	https://standards.iteh.ai/catalog/standards/sist/13f81ff1-1-496e-4de1-95da-3c2344	
IEC 61131 (Series)	NOTE	Harmonized as EN 61131 (Series)
IEC 61131-3	NOTE	Harmonized as EN 61131-3
IEC 61158-1	NOTE	Harmonized as EN 61158-1
IEC 61375-3-3	NOTE	Harmonized as EN 61375-3-3
IEC 61499 (Series)	NOTE	Harmonized as EN 61499 (Series)
IEC 61499-1	NOTE	Harmonized as EN 61499-1
IEC 61784-1	NOTE	Harmonized as EN 61784-1
IEC 61784-2	NOTE	Harmonized as EN 61784-2
IEC 61784 (Series)	NOTE	Harmonized as EN 61784 (Series)
IEC 61800-7-1	NOTE	Harmonized as EN 61800-7-1
IEC 61800-7-2 (Series)	NOTE	Harmonized as EN 61800-7-2 (Series)
IEC 61800-7-3 (Series)	NOTE	Harmonized as EN 61800-7-3 (Series)
IEC 61804-2	NOTE	Harmonized as EN 61804-2

IEC 61804-3	NOTE	Harmonized as EN 61804-3
IEC 61804-4	NOTE	Harmonized as EN 61804-4
IEC 61850 (Series)	NOTE	Harmonized as EN 61850 (Series)
IEC 61915-1	NOTE	Harmonized as EN 61915-1
IEC/TS 61970-2	NOTE	Harmonized as CLC/TS 61970-2
IEC 62026 (Series)	NOTE	Harmonized as EN 62026 (Series)
IEC 62026-1	NOTE	Harmonized as EN 62026-1
IEC 62264 (Series)	NOTE	Harmonized as EN 62264 (Series)
IEC 62402	NOTE	Harmonized as EN 62402
IEC 62453 (Series)	NOTE	Harmonized as EN 62453 (Series)
IEC 62541 (Series)	NOTE	Harmonized as EN 62541 (Series)
IEC/TR 62541-1	NOTE	Harmonized as CLC/TR 62541-1
IEC 62769 (Series)	NOTE	Harmonized as EN 62769 (Series)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 62453-1:2017](https://standards.iteh.ai/catalog/standards/sist/13f81f11-496e-4de1-95da-3c1c3623441d/sist-en-62453-1-2017)

<https://standards.iteh.ai/catalog/standards/sist/13f81f11-496e-4de1-95da-3c1c3623441d/sist-en-62453-1-2017>

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158	series	Industrial communication networks - Fieldbus specifications	EN 61158	series
IEC 61784	series	Industrial communication networks - Profiles	EN 61784	series

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 62453-1:2017

<https://standards.iteh.ai/catalog/standards/sist/13f81f11-496e-4de1-95da-3c1c3623441d/sist-en-62453-1-2017>



IEC 62453-1

Edition 2.0 2016-12

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Field device tool (FDT) interface specification –
Part 1: Overview and guidance

(standards.iteh.ai)

Spécification des interfaces des outils des dispositifs de terrain (FDT) –
Partie 1: Vue d'ensemble et guide

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.05; 35.110

ISBN 978-2-8322-3745-8

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms, definitions, symbols, abbreviations and conventions	8
3.1 Terms and definitions.....	8
3.2 Abbreviations	13
3.3 Conventions.....	14
4 FDT overview	14
4.1 State of the art.....	14
4.2 Objectives of FDT	15
4.2.1 General features.....	15
4.2.2 Device and module manufacturer benefits	15
4.2.3 System manufacturer and integrator benefits	16
4.2.4 Other applications	16
4.3 FDT model.....	16
4.3.1 General	16
4.3.2 Frame Applications.....	18
4.3.3 Device Type Manager.....	19
4.3.4 Communication Channel concept.....	20
4.3.5 Presentation object.....	22
5 Structure of the IEC 62453 series.....	22
5.1 Structure overview.....	22
5.2 Part 2 – Concepts and detailed description	24
5.3 Parts 3xy – Communication profile integration	24
5.3.1 General	24
5.3.2 Communication profile integration – IEC 61784 CPF 1.....	25
5.3.3 Communication profile integration – IEC 61784 CPF 2.....	25
5.3.4 Communication profile integration – IEC 61784 CP 3/1 and 3/2	25
5.3.5 Communication profile integration – IEC 61784 CP 3/4, CP 3/5 and 3/6.....	25
5.3.6 Communication profile integration – IEC 61784 CPF 6.....	25
5.3.7 Communication profile integration – IEC 61784 CPF 9.....	25
5.3.8 Communication profile integration – IEC 61784 CPF 15.....	25
5.4 Parts 4z – Object model integration profiles	26
5.4.1 General	26
5.4.2 Object model integration profile – Common object model (COM)	26
5.4.3 Object model integration profile – Common language infrastructure (CLI).....	26
5.5 Parts 51-xy/52-xy – Communication profile implementation.....	26
5.5.1 General	26
5.5.2 Communication profile implementation – IEC 61784 CPF 1.....	26
5.5.3 Communication profile implementation – IEC 61784 CPF 2.....	26
5.5.4 Communication profile implementation – IEC 61784 CP 3/1 and 3/2	27
5.5.5 Communication profile implementation – IEC 61784 CP 3/4, CP 3/5 and 3/6.....	27

5.5.6	Communication profile implementation – IEC 61784 CPF 6.....	27
5.5.7	Communication profile implementation – IEC 61784 CPF 9.....	27
5.5.8	Communication profile implementation – IEC 61784 CPF 15.....	27
5.6	Parts 6z – DTM styleguides	27
5.6.1	General	27
5.6.2	Device Type Manager (DTM) styleguide for common object model	27
5.6.3	Field Device Tool (FDT) styleguide for common language infrastructure	27
6	Relation of the IEC 62453 series to other standardization activities	27
7	Migration to DTM	31
8	How to read IEC 62453.....	32
8.1	Architecture	32
8.2	Dynamic behavior	32
8.3	Structured data types.....	33
8.4	Fieldbus communication.....	33
Annex A (informative)	UML notation.....	34
A.1	General.....	34
A.2	Class diagram.....	34
A.3	Statechart diagram.....	36
A.4	Use case diagram	37
A.5	Sequence diagram	38
Annex B (informative)	Implementation policy.....	39
Bibliography.....		40
Figure 1	Different tools and fieldbuses result in limited integration.....	15
Figure 2	Full integration of all devices and modules into a homogeneous system.....	16
Figure 3	General architecture and components	17
Figure 4	FDT software architecture	19
Figure 5	General FDT client/server relationship	20
Figure 6	Typical FDT channel architecture	21
Figure 7	Channel/parameter relationship.....	22
Figure 8	Structure of the IEC 62453 series	23
Figure 9	Standards related to IEC 62453 in an automation hierarchy	28
Figure 10	Standards related to IEC 62453 – Grouped by purpose	31
Figure 11	DTM implementations.....	32
Figure A.1	Note.....	34
Figure A.2	Class	34
Figure A.3	Association	34
Figure A.4	Composition.....	35
Figure A.5	Aggregation	35
Figure A.6	Dependency.....	35
Figure A.7	Abstract class, generalization and interface	35
Figure A.8	Multiplicity	36
Figure A.9	Elements of UML statechart diagrams.....	36

Figure A.10 – Example of UML state chart diagram.....	37
Figure A.11 – UML use case syntax.....	37
Figure A.12 – UML sequence diagram	38
Table 1 – Overview of related standards	29

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

SIST EN 62453-1:2017

<https://standards.iteh.ai/catalog/standards/sist/13f81f11-496e-4de1-95da-3c1c3623441d/sist-en-62453-1-2017>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FIELD DEVICE TOOL (FDT) INTERFACE SPECIFICATION –

Part 1: Overview and guidance

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62453-1 has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition: introduction of a new implementation technology (defined in IEC 62453-42).

The text of this standard is based on the following documents:

CDV	Report on voting
65E/333/CDV	65E/393A/RVC

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 62453 series, under the general title *Field Device Tool (FDT) interface specification*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.itech.ai)

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

<https://standards.itech.ai/catalog/standards/sist/15181111-496e-4de1-95da-3c1c3623441d/sist-en-62453-1-2017>

INTRODUCTION

Enterprise automation requires two main data flows: a “vertical” data flow from enterprise level down to the field devices including signals and configuration data, and a “horizontal” communication between field devices operating on the same or different communication technologies.

With the integration of fieldbuses into control systems, there are a few additional tasks to be performed. They may result in a large number of fieldbus- and device-specific tools in addition to system and engineering tools. Integration of these tools into higher-level system-wide planning or engineering tools is an advantage. In particular, for use in extensive and heterogeneous control systems, typically in the area of the process industry, the unambiguous definition of engineering interfaces that are easy to use for all those involved is of great importance.

Several different manufacturer specific tools are used. The data in these tools are often invisible data islands from the viewpoint of system life-cycle management and plant-wide automation.

To ensure the consistent management of a plant-wide control and automation technology, it is important to fully integrate fieldbuses, devices and sub-systems as a seamless part of a wide range of automation tasks covering the whole automation life-cycle.

IEC 62453 provides an interface specification for developers of FDT (Field Device Tool) components to support function control and data access within a client/server architecture. The availability of this standard interface facilitates development of servers and clients by multiple manufacturers and supports open interoperation.

A device or module-specific software component, called a DTM (Device Type Manager) is supplied by a manufacturer with the related device type or software entity type. Each DTM can be integrated into engineering tools via defined FDT interfaces. This approach to integration is in general open for all fieldbuses and thus supports integration of different devices and software modules into heterogeneous control systems.

The IEC 62453 common application interface supports the interests of application developers, system integrators, and manufacturers of field devices and network components. It also simplifies procurement, reduces system costs and helps manage the lifecycle. Significant savings are available in operating, engineering and maintaining the control systems.

The objectives of the IEC 62453 series are to support:

- universal plant-wide tools for life-cycle management of heterogeneous fieldbus environments, multi-manufacturer devices, function blocks and modular sub-systems for all automation domains (e.g. process automation, factory automation and similar monitoring and control applications);
- integrated and consistent life-cycle data exchange within a control system including its fieldbuses, devices, function blocks and modular sub-systems;
- simple and powerful manufacturer-independent integration of different automation devices, function blocks and modular sub-systems into the life-cycle management tools of a control system.

The FDT concept supports planning and integration of monitoring and control applications, it does not provide a solution for other engineering tasks such as “electrical wiring planning”, “mechanical planning”. Plant management subjects such as “maintenance planning”, “control optimization”, “data archiving”, are not part of this FDT standard. Some of these aspects may be included in future editions of FDT publications.