

**SLOVENSKI STANDARD
SIST EN 62541-100:2015****01-september-2015**

Enotna arhitektura OPC - 100. del: Vmesnik naprave (IEC 62541-100:2015)

OPC Unified Architecture Specification -- Part 100: Device Interface (IEC 62541-100:2015)

OPC Unified Architecture - Teil 100: Geräteschnittstelle (IEC 62541-100:2015)

Architecture unifiée OPC - Partie 100: Interface d'appareils (IEC 62541-100:2015)

**STANDARD PREVIEW
(standards.iteh.ai)****Ta slovenski standard je istoveten z: EN 62541-100:2015**

<https://standards.iteh.ai/catalog/standards/sist/d40b9ba3-c51b-4e92-be4b-7002bb2dacea/sist-en-62541-100-2015>

ICS:

25.040.40	Merjenje in krmiljenje industrijskih postopkov	Industrial process measurement and control
35.240.50	Uporabniške rešitve IT v industriji	IT applications in industry

SIST EN 62541-100:2015**en,fr,de**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 62541-100:2015

<https://standards.iteh.ai/catalog/standards/sist/d40b9ba3-c51b-4e92-be4b-7002bb2dacea/sist-en-62541-100-2015>

EUROPEAN STANDARD

EN 62541-100

NORME EUROPÉENNE

EUROPÄISCHE NORM

May 2015

ICS 25.040.40; 35.100

English Version

**OPC unified architecture - Part 100: Device Interface
(IEC 62541-100:2015)**Architecture unifiée OPC - Partie 100: Interface d'appareils
(IEC 62541-100:2015)OPC Unified Architecture - Teil 100: Geräteschnittstelle
(IEC 62541-100:2015)

This European Standard was approved by CENELEC on 2015-04-29. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

<https://standards.iteh.ai/catalog/standards/sist/d40b9ba3-c51b-4e92-be4b-7002bb2dacea/sist-en-62541-100-2015>



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65E/372/CDV, future edition 1 of IEC 62541-100, prepared by SC 65E "Devices and integration in enterprise systems", of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62541-100:2015.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2016-01-29
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2018-04-29

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

Endorsement notice
<https://standards.iteh.ai/catalog/standards/sist/6a3-c51b-4e92-be4b-7002bb2dacea/sist-en-62541-100-2015>

The text of the International Standard IEC 62541-100:2015 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61131	NOTE	Harmonized in EN 61131 series (not modified).
IEC 61499-1:2012	NOTE	Harmonized as EN 61499-1:2013 (not modified).
IEC 61784	NOTE	Harmonized in EN 61784 series (not modified).
IEC 62591	NOTE	Harmonized as EN 62591.
IEC 62769	NOTE	Harmonized in EN 62769 series ¹⁾ (not modified).

1) At draft stage.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC/TR 62541-1	-	OPC unified architecture - Part 1: Overview and concepts	CLC/TR 62541-1	-
IEC 62541-3	-	OPC unified architecture - Part 3: Address Space Model	EN 62541-3	-
IEC 62541-4	-	OPC unified architecture - Part 4: Services	EN 62541-4	-
IEC 62541-5	-	OPC unified architecture - Part 5: Information Model	EN 62541-5	-
IEC 62541-6	-	OPC unified architecture - Part 6: Mappings	EN 62541-6	-
IEC 62541-7	-	OPC unified architecture - Part 7: Profiles	EN 62541-7	-
IEC 62541-8	-	OPC Unified Architecture - Part 8: Data Access	EN 62541-8	-

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 62541-100:2015

<https://standards.iteh.ai/catalog/standards/sist/d40b9ba3-c51b-4e92-be4b-7002bb2dacea/sist-en-62541-100-2015>



IEC 62541-100

Edition 1.0 2015-03

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**OPC unified architecture –
Part 100: Device Interface**

STANDARD PREVIEW
(standards.iteh.ai)

**Architecture unifiée OPC –
Partie 100: Interface d'appareils**

SIST EN 62541-100:2015

<https://standards.iteh.ai/catalog/standards/sist/d40b9ba3-c51b-4e92-be4b-7002bb2dacea/sist-en-62541-100-2015>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100

ISBN 978-2-8322-2299-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Reference documents.....	8
3 Terms, definitions, abbreviations and used data types.....	8
3.1 Terms and definitions.....	8
3.2 Abbreviations.....	10
3.3 Used data types.....	10
4 Fundamentals.....	10
4.1 OPC UA.....	10
4.2 Conventions used in this document.....	11
4.2.1 Conventions for Node descriptions.....	11
4.2.2 NodeIds and BrowseNames.....	12
5 Device model.....	13
5.1 General.....	13
5.2 TopologyElementType.....	14
5.3 FunctionalGroupType.....	16
5.4 Identification FunctionalGroup.....	18
5.5 UIElement Type.....	19
5.6 DeviceType.....	19
5.7 Device support information.....	22
5.7.1 General.....	22
5.7.2 Device Type Image.....	23
5.7.3 Documentation.....	23
5.7.4 Protocol support files.....	23
5.7.5 Images.....	24
5.8 DeviceSet entry point.....	24
5.9 ProtocolType.....	25
5.10 BlockType.....	26
5.11 Configurable components.....	28
5.11.1 General pattern.....	28
5.11.2 ConfigurableObjectType.....	28
6 Device vommunication model.....	29
6.1 General.....	29
6.2 Network.....	30
6.3 ConnectionPoint.....	31
6.4 ConnectsTo and ConnectsToParent ReferenceTypes.....	33
6.5 NetworkSet Object (mandatory).....	34
7 Device integration host model.....	35
7.1 General.....	35
7.2 DeviceTopology Object.....	36
7.3 Online/Offline.....	37
7.3.1 General.....	37
7.3.2 IsOnline ReferenceType.....	38
8 AddIn Capabilities.....	39
8.1 Overview.....	39

8.2	Offline-Online data transfer	40
8.2.1	Definition	40
8.2.2	TransferServices Type	40
8.2.3	TransferServices Object	41
8.2.4	TransferToDevice Method	41
8.2.5	TransferFromDevice Method	42
8.2.6	FetchTransferResultData Method	43
8.3	Locking	45
8.3.1	Overview	45
8.3.2	LockingServices Type	45
8.3.3	LockingServices Object	47
8.3.4	MaxInactiveLockTime Property	47
8.3.5	InitLock Method	48
8.3.6	ExitLock Method	48
8.3.7	RenewLock Method	49
8.3.8	BreakLock Method	49
9	Specialized topology elements	50
9.1	General	50
9.2	Block Devices (BlockOriented DeviceType)	50
9.3	Modular Devices	51
10	Profiles	52
10.1	General	52
10.2	Device Server Facets	52
10.3	Device Client Facets	53
Annex A (normative)	Namespace and mappings	55
Bibliography	56
Figure 1	– Device model overview	13
Figure 2	– Components of the TopologyElementType	14
Figure 3	– FunctionalGroupType	16
Figure 4	– Analyser Device use for FunctionalGroups (UA Companion ADI)	17
Figure 5	– PLCOpen use for FunctionalGroups (UA Companion PLCOpen)	18
Figure 6	– Example of an Identification FunctionalGroup	19
Figure 7	– DeviceType	20
Figure 8	– Integration of support information within a DeviceType	22
Figure 9	– Standard entry point for Devices	25
Figure 10	– Example of a ProtocolType hierarchy with instances that represent specific communication profiles	26
Figure 11	– BlockType hierarchy	27
Figure 12	– Configurable component pattern	28
Figure 13	– ConfigurableObjectType	29
Figure 14	– Initial example of a communication topology	30
Figure 15	– NetworkType	30
Figure 16	– Example of ConnectionPointType hierarchy	31
Figure 17	– ConnectionPointType	32
Figure 18	– ConnectionPoint usage	33

Figure 19 – Type hierarchy for ConnectsTo and ConnectsToParent References	33
Figure 20 – Example with ConnectsTo and ConnectsToParent References	34
Figure 21 – Example of an automation system.....	35
Figure 22 – Example of a Device topology.....	36
Figure 23 – Online component for access to device data	37
Figure 24 – Type hierarchy for <i>IsOnline Reference</i>	39
Figure 25 – TransferServicesType.....	40
Figure 26 – TransferServices	41
Figure 27 – LockingServicesType.....	46
Figure 28 – LockingServices	47
Figure 29 – Block-oriented Device structure example.....	50
Figure 30 – Modular Device structure example	51
Table 1 – DataTypes defined in IEC 62541-3.....	10
Table 2 – Type definition table	11
Table 3 – Examples of DataTypes	12
Table 4 – TopologyElementType definition	15
Table 5 – ParameterSet definition	15
Table 6 – MethodSet definition.....	15
Table 7 – FunctionalGroupType definition.....	16
Table 8 – UIElementType definition.....	19
Table 9 – DeviceType definition.....	20
Table 10 – DeviceHealth values.....	22
Table 11 – DeviceTypeImage definition	23
Table 12 – Documentation definition	23
Table 13 – ProtocolSupport definition.....	23
Table 14 – ImageSet definition.....	24
Table 15 – DeviceSet definition	25
Table 16 – ProtocolType definition	26
Table 17 – BlockType definition	27
Table 18 – ConfigurableObjectType definition.....	29
Table 19 – NetworkType definition	31
Table 20 – ConnectionPointType definition.....	32
Table 21 – ConnectsTo ReferenceType.....	34
Table 22 – ConnectsToParent ReferenceType.....	34
Table 23 – NetworkSet definition.....	34
Table 24 – DeviceTopology definition.....	37
Table 25 – <i>IsOnline ReferenceType</i>	39
Table 26 – TransferServicesType definition	40
Table 27 – TransferToDevice Method arguments.....	42
Table 28 – TransferToDevice Method AddressSpace definition	42
Table 29 – TransferFromDevice Method arguments.....	42
Table 30 – TransferFromDevice Method AddressSpace definition	43

Table 31 – FetchTransferResultData Method Arguments.....	44
Table 32 – FetchTransferResultData Method AddressSpace definition	44
Table 33 – FetchResultData Type structure	44
Table 34 – TransferResultError DataType structure	44
Table 35 – TransferResultData DataType structure.....	45
Table 36 – LockingServicesType definition	46
Table 37 – MaxInactiveLockTime Property definition.....	47
Table 38 – InitLock Method Arguments.....	48
Table 39 – InitLock Method AddressSpace definition	48
Table 40 – ExitLock Method Arguments.....	49
Table 41 – ExitLock Method AddressSpace definition	49
Table 42 – RenewLock Method Arguments	49
Table 43 – RenewLock Method AddressSpace definition.....	49
Table 44 – BreakLock Method Arguments.....	50
Table 45 – BreakLock Method AddressSpace definition	50
Table 46 – BaseDevice_Server_Facet definition	52
Table 47 – DeviceIdentification_Server_Facet definition	52
Table 48 – BlockDevice_Server_Facet definition	52
Table 49 – Locking_Server_Facet definition	52
Table 50 – DeviceCommunication_Server_Facet definition	53
Table 51 – DeviceIntegrationHost_Server_Facet definition	53
Table 52 – BaseDevice_Client_Facet definition	53
Table 53 – DeviceIdentification_Client_Facet definition	53
Table 54 – BlockDevice_Client_Facet definition.....	54
Table 55 – Locking_Client_Facet definition.....	54
Table 56 – DeviceCommunication_Client_Facet definition	54
Table 57 – DeviceIntegrationHost_Client_Facet definition.....	54

STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 62541-100:2015
<https://standards.iteh.ai/catalog/standards/sist/d4069ba3-c516-4e92-bc46-70020914cc38/iec-62541-100-2015>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

OPC UNIFIED ARCHITECTURE –

Part 100: Device Interface

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62541-100 has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation.

The text of this standard is based on the following documents:

CDV	Report on voting
65E/372/CDV	65E/412/RVC

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 62541 series, published under the general title , can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 62541-100:2015](https://standards.iteh.ai/catalog/standards/sist/d40b9ba3-c51b-4e92-be4b-7002bb2dacea/sist-en-62541-100-2015)

<https://standards.iteh.ai/catalog/standards/sist/d40b9ba3-c51b-4e92-be4b-7002bb2dacea/sist-en-62541-100-2015>

OPC UNIFIED ARCHITECTURE –

Part 100: Device Interface

1 Scope

This part of IEC 62541 is an extension of the overall OPC Unified Architecture standard series and defines the information model associated with *Devices*. This part of IEC 62541 describes three models which build upon each other as follows:

- the (base) Device Model is intended to provide a unified view of devices irrespective of the underlying device protocols;
- the Device Communication Model adds Network and Connection information elements so that communication topologies can be created;
- the Device Integration Host Model finally adds additional elements and rules required for host systems to manage integration for a complete system. It allows reflecting the topology of the automation system with the devices as well as the connecting communication networks.

2 Reference documents

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC TR 62541-1, *OPC Unified Architecture – Part 1: Overview and Concepts*

IEC 62541-3, *OPC Unified Architecture – Part 3: Address Space Model*

IEC 62541-4 *OPC Unified Architecture – Part 4: Services*

IEC 62541-5, *OPC Unified Architecture – Part 5: Information Model*

IEC 62541-6, *OPC Unified Architecture – Part 6: Mappings*

IEC 62541-7, *OPC Unified Architecture – Part 7: Profiles*

IEC 62541-8, *OPC Unified Architecture – Part 8: Data Access*

NAMUR Recommendation NE107: *Self-monitoring and diagnosis of field devices*

3 Terms, definitions, abbreviations and used data types

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC TR 62541-1, IEC 62541-3, and IEC 62541-8 as well as the following apply.

3.1.1

block

functional *Parameter* grouping entity

Note 1 to entry: It could map to a function block (see IEC 62769 (all parts), *Field Device Integration (FDI)*

) or to the resource parameters of the device itself.

3.1.2

blockMode

mode of operation (target mode, permitted modes, actual mode, and normal mode) for a *Block*

Note 1 to entry: Further details about *Block* modes are defined by standard organisations.

3.1.3

Communication Profile

fixed set of mapping rules to allow unambiguous interoperability between *Devices* or *Applications*, respectively

Note 1 to entry: Examples of such profiles are the “Wireless communication network and communication profiles for WirelessHART” in IEC 62591 and the Protocol Mappings for OPC UA in IEC 62541-6.

3.1.4

Connection Point

logical representation of the interface between a *Device* and a *Network*

3.1.5

device

independent physical entity capable of performing one or more specified functions in a particular context and delimited by its interfaces

Note 1 to entry: See IEC 61499-1.

Note 2 to entry: *Devices* provide sensing, actuating, communication, and/or control functionality. Examples include transmitters, valve controllers, drives, motor controllers, PLCs, and communication gateways.

3.1.6

Device Integration Host

Server that manages integration of multiple *Devices* in an automation system

3.1.7

Device Topology

arrangement of *Networks* and *Devices* that constitute a communication topology

3.1.8

fieldbus

communication system based on serial data transfer and used in industrial automation or process control applications

Note 1 to entry: See IEC 61784.

Note 2 to entry: Designates the communication bus used by a *Device*.

3.1.9

parameter

variable of the *Device* that can be used for configuration, monitoring or control purposes

Note 1 to entry: In the information model it is synonymous to an OPC UA *DataVariable*.

3.1.10

network

means used to communicate with one specific protocol