



SLOVENSKI STANDARD
SIST EN ISO 16000-1:2006
01-julij-2006

BčfUbfU`nfU_`È`%`XY.`Gd`cýb`j`j`X`l`j`g`f`U`M`[`j`Y`j`n`c`f`Y`b`U`f`i`G`C``%`\$\$\$!`%`&`\$\$`(`L

Indoor air - Part 1: General aspects of sampling strategy (ISO 16000-1:2004)

Innenraumlufiverunreinigungen - Teil 1: Allgemeine Aspekte der Probenahmestrategie (ISO 16000-1:2004)

Air intérieur - Partie 1: Aspects généraux de la stratégie d'échantillonnage (ISO 16000-1:2004)

ITIH STANDARD PREVIEW
(standards.iteh.ai)

Ta slovenski standard je istoveten z: EN ISO 16000-1:2006

<https://standards.iteh.ai/catalog/standards/sist/25bdfd48-9ad3-45cf-ba7d-787c285ca3/sist-en-iso-16000-1-2006>

ICS:

13.040.20

SIST EN ISO 16000-1:2006

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 16000-1:2006

<https://standards.iteh.ai/catalog/standards/sist/25bdfd48-9ad3-45cf-ba7d-7f67c283ca3/sist-en-iso-16000-1-2006>

ICS 13.040.20

English Version

Indoor air - Part 1: General aspects of sampling strategy (ISO
16000-1:2004)

Air intérieur - Partie 1: Aspects généraux de la stratégie
d'échantillonnage (ISO 16000-1:2004)

Innenraumluftverunreinigungen - Teil 1: Allgemeine
Aspekte der Probenahmestrategie (ISO 16000-1:2004)

This European Standard was approved by CEN on 9 March 2006.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

[SIST EN ISO 16000-1:2006](https://standards.iteh.ai/catalog/standards/sist/25bdf48-9ad3-45cf-ba7d-7f67c283ca3/sist-en-iso-16000-1-2006)

<https://standards.iteh.ai/catalog/standards/sist/25bdf48-9ad3-45cf-ba7d-7f67c283ca3/sist-en-iso-16000-1-2006>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Foreword

The text of ISO 16000-1:2004 has been prepared by Technical Committee ISO/TC 146 "Air quality" of the International Organization for Standardization (ISO) and has been taken over as EN ISO 16000-1:2006 by Technical Committee CEN/TC 264 "Air quality" the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2006, and conflicting national standards shall be withdrawn at the latest by October 2006.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

Endorsement notice

The text of ISO 16000-1:2004 has been approved by CEN as a EN ISO 16000-1:2006 without any modification.

iTeh STANDARD PREVIEW

ISO 16000 consists of the following parts, under the general title *Indoor air*:

(standards.iteh.ai)

- *Part 1: General aspects of sampling strategy*
- *Part 2: Measurement strategy for formaldehyde*
- *Part 3: Determination of formaldehyde and other carbonyl compounds – Active sampling method*
- *Part 4: Determination of formaldehyde – Diffusive sampling method*
- *Part 6: Determination of volatile organic compounds in indoor and test chamber air by active sampling on Tenax TA sorbent, thermal desorption and gas-chromatography using MS/FID*
- *Part 9: Determination of the emission of volatile organic compounds from building products and furnishing – Emission test chamber method*
- *Part 10: Determination of the emission of volatile organic compounds from building products and furnishing – Emission test cell method*
- *Part 11: Determination of the emission of volatile organic compounds from building products and furnishing – Sampling, storage of samples and preparation of test specimens*

The following parts are under preparation:

- *Part 5: Sampling strategy for volatile organic compounds (VOCs)*
- *Part 7: Sampling strategy for determination of airborne asbestos fibre concentrations*
- *Part 8: Ventilation rate measurement*

Indoor air —

Part 1:

General aspects of sampling strategy

Air intérieur —

Partie 1: Aspects généraux de la stratégie d'échantillonnage

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 16000-1:2006

<https://standards.iteh.ai/catalog/standards/sist/25bdf48-9ad3-45cf-ba7d-7f67c283ca3/sist-en-iso-16000-1-2006>



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 16000-1:2006](https://standards.iteh.ai/catalog/standards/sist/25bdfd48-9ad3-45cf-ba7d-7f67c283ca3/sist-en-iso-16000-1-2006)

<https://standards.iteh.ai/catalog/standards/sist/25bdfd48-9ad3-45cf-ba7d-7f67c283ca3/sist-en-iso-16000-1-2006>

© ISO 2004

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Special characteristics of the indoor environment	1
4 Measurement objective	3
5 Sampling procedure	3
6 Time of sampling	4
7 Sampling duration and sampling frequency	4
8 Sampling location	6
9 Parallel outdoor air measurements	6
Annex A (informative) Important types of indoor environment and sources of air pollutants	7
Annex B (informative) Sources of indoor air pollutants	8
Annex C (informative) Examples of substances and their sources	10
Annex D (informative) Guidelines for information to be recorded during indoor air measurement	13
Bibliography	21

SIST EN ISO 16000-1:2006

<https://standards.iteh.ai/catalog/standards/sist/25bdfd48-9ad3-45cf-ba7d-7f67c283ca3/sist-en-iso-16000-1-2006>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 16000-1 was prepared by Technical Committee ISO/TC 146, *Air quality*, Subcommittee SC 6, *Indoor air*.

ISO 16000 consists of the following parts, under the general title *Indoor air*:

- Part 1: *General aspects of sampling strategy*
- Part 2: *Sampling strategy for formaldehyde*
- Part 3: *Determination of formaldehyde and other carbonyl compounds — Active sampling method*
- Part 4: *Determination of formaldehyde — Diffusive sampling method*
- Part 6: *Determination of volatile organic compounds in indoor and test chamber air by active sampling on Tenax TA sorbent, thermal desorption and gas chromatography using MS/FID*
- Part 9: *Determination of the emission of volatile organic compounds — Emission test chamber method*
- Part 10: *Determination of the emission of volatile organic compounds — Emission test cell method*
- Part 11: *Determination of the emission of volatile organic compounds — Sampling, storage of samples and preparation of test specimens*

The following parts are under preparation:

- Part 5: *Sampling strategy for volatile organic compounds (VOCs)*
- Part 7: *Sampling strategy for determination of airborne asbestos fibre concentrations*
- Part 8: *Ventilation rate measurement*

Introduction

The ISO 16000 series deals with indoor air measurements. This part of ISO 16000 is intended as an aid to planning indoor air pollution measurements. Additional parts of ISO 16000 describe the sampling strategy, including the conditions to be observed for the particular substances or groups of substances, such as the dependence of indoor air pollution concentrations on atmospheric humidity or temperature or other effects. The actual procedures dealing with indoor air measurements for the individual substances are also presented in other parts of ISO 16000.

An inappropriate monitoring strategy can contribute to the overall uncertainty of the measurement result to a greater extent than the monitoring procedure itself.

Attention should be given to the special role of the human sense of smell in identifying substances or classes of substances in indoor air. Here it is not so much the sensitivity of the sense of smell, but the memory of smell and the experience of the specialist (chemist, perfume specialist) that is important. Sensory information can greatly simplify the identification of air pollutants and consequently influence the sampling strategy. However, sensoric adaptation affects the sensory information, particularly in the case of persistent indoor pollutants.

The interpretation of indoor air measurements is assisted by the use of guideline values for acceptable indoor air quality. To draw a conclusion about whether and to what extent the concentrations of a pollutant measured in a room exceed the normal level or the level acceptable from the standpoint of health, it is useful to rely on guideline values or published literature. The column "Remarks" of Table C.1 (see Annex C) gives available World Health Organization (WHO) air quality guidelines for indoor air^[1]. It is emphasized, however, that these values are not legally binding. In the absence of published guideline values, the investigator may consult peer reviewed journal articles or other literature for guidance on typical values observed in buildings without reported complaints. <https://standards.iteh.ai/catalog/standards/sist/25bdfd48-9ad3-45cf-ba7d-7f67c28Bca3/sist-en-iso-16000-1-2006>

Representatives of various technical fields should be involved in the planning of indoor air quality measurements.

Table A.1 of this part of ISO 16000 summarizes the most important types of indoor environment, and examples of the sources that may be encountered in them. The list is not, of course, fully comprehensive because of the large number of possibilities.

Table B.1 shows the sources of indoor air pollutants and the most important substances emitted. Table C.1 lists substances frequently detected and their possible sources. In some cases, the sources of indoor pollution arise outside the building; for example, benzene from vehicle traffic and petrol stations, and chlorinated hydrocarbons from nearby dry-cleaning establishments. Soil emissions may also be important if, for example, buildings have been erected on old landfills, industrial sites, or uranium-containing soils which emit radon.

Annex D contains a checklist relating to information to be recorded when indoor air measurements are carried out. This list is also intended to aid the user of this part of ISO 16000 in the subsequent assessment of the analytical result.

The sampling strategy procedure described in this part of ISO 16000 is based on Guideline VDI 4300 Part 1^[2]. Similar national standards exist^{[3], [4], [5]}.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 16000-1:2006

<https://standards.iteh.ai/catalog/standards/sist/25bdfd48-9ad3-45cf-ba7d-7f67c283ca3/sist-en-iso-16000-1-2006>

Indoor air —

Part 1: General aspects of sampling strategy

1 Scope

This part of ISO 16000 is intended to aid the planning of indoor pollution monitoring.

Before a sampling strategy is devised for indoor air monitoring, it is necessary to clarify for what purposes, when, where, how often and over what periods of time monitoring is to be performed. The answers to these questions depend, in particular, on a number of special characteristics of the indoor environments, on the objective of the measurement and, finally, on the environment to be measured. This part of ISO 16000 deals with the significance of these factors and offers suggestions on how to develop a suitable sampling strategy.

This part of ISO 16000 is applicable to indoor environments such as dwellings with living rooms, bedrooms, do-it-yourself rooms, recreation rooms and cellars, kitchens and bathrooms; workrooms or work places in buildings which are not subject to health and safety inspections in regard to air pollutants (for example, offices, sales premises); public buildings (for example hospitals, schools, kindergartens, sports halls, libraries, restaurants and bars, theatres, cinemas and other function rooms), and also cabins of vehicles^[6].

NOTE In some countries, workplaces such as offices and sales premises are subject to health and safety inspections with regard to air pollutants.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories*

Guide to the expression of uncertainty in measurement (GUM), BIPM, IEC, IFCC, ISO, IUPAC, IUPAP, OIML, 1995

3 Special characteristics of the indoor environment

Careful planning of sampling and the entire measurement strategy are of particular significance since the result of the measurement may have far-reaching consequences (e.g. with regard to the need for remedial action or the success of such an action).

The determination of indoor air pollutants proceeds, as a rule, by either of two approaches.

- a) Sampling is carried out on-site using instruments that are as manageable and simple as possible, and subsequently analysis is carried out in the laboratory; or
- b) sampling and analysis are performed on-site by direct-reading measuring systems.

An indoor environment is rarely static, since the concentration of any substance may be constantly altered by the strength of the source, human activity, ventilation rate, external or internal climatic conditions, chemical reactions and possible sinks (e.g. sorption by surfaces and furnishings). Because of the proximity of source to receptor, human exposure in the indoor environment is of special concern. In addition, the composition of indoor air may vary within and between rooms, and be less homogeneous than the outdoor air surrounding the building.

Equation (1) describes a simplified relationship of some of the parameters that affect the concentration of a substance in indoor air. In special cases, e.g. fibres [asbestos, MMF (man-made fibres)] additional boundary conditions should be considered (see ISO 16000-7).

$$d\rho_i / dt = (q / V) + n\rho_o - f\rho_i - n\rho_i \quad (1)$$

where

ρ_i is the mass concentration of substance in indoor air, in milligrams per cubic metre;

q is the strength (mass flowrate) of the source, in milligrams per hour;

V is the volume of the room, in cubic metres;

n is the number of air changes per hour;

ρ_o is the mass concentration of substance in outdoor-air, in milligrams per cubic metre;

f is the elimination factor per hour;

t is the time, in hours.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

The left-hand side of the equation represents the change in the concentration of the substance with time. The first two terms on the right-hand side describe the increase in the concentration due to emissions from a source and the penetration of outdoor air, while the last two terms represent the decrease in the concentration which may result from removal by ventilation or from elimination mechanisms, such as sorption of the compound by textiles in the room.

The most important term in Equation (1) is the source strength. It is often observed to vary with time, but this is not taken into account by Equation (1). If it is found that the variation is of particular significance, a more complex equation is needed. Depending on how the strength varies with time, a distinction can be made between a constant and a variable source strength, and both cases can be subdivided still further into regular and irregular emissions. The strength of continuous sources may also depend on room temperature, the relative humidity and the amount of movement of the air in the room, and may only change in the long term; i.e. over weeks and months. The emission rate of intermittent sources is generally only slightly affected by room-climate parameters and often varies within much shorter periods of time.

Particle board with aminoplastic bonding is an example of a source that continually emits pollutants into the air. Such a source emits formaldehyde over long periods of time in amounts that depend heavily on environmental factors such as temperature and relative humidity.

A gas cooker, which may be operated at varying conditions according to cooking requirements, is an example of an intermittent source having variable strength. However, a very regular emission pattern may be observed from day to day, since the preparation of meals is often subject to a regular schedule.

The occasional use of insecticide sprays represents a combination of an intermittent source and an irregular emission pattern.