

SLOVENSKI STANDARD

SIST EN 1630:2012

01-januar-2012

Nadomešča:
SIST ENV 1630:2000

Vrata, okna, obešene fasade, mreže in polkna - Protivlomna odpornost - Preskusna metoda ugotavljanja odpornosti proti poskusu ročnega vloma

Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglar resistance - Test method for the determination of resistance to manual burglary attempts

Einbruchhemmende Bauprodukte (nicht für Betonfertigteile) - Prüfverfahren für die Ermittlung der Widerstandsfähigkeit gegen manuelle Einbruchversuche

Produits de construction résistants à l'effraction (sauf éléments en béton préfabriqué) - Méthode d'essai pour la détermination de la résistance aux tentatives manuelles d'effraction

Ta slovenski standard je istoveten z: EN 1630:2011

ICS:

| | | |
|-----------|-------------------------|--------------------------|
| 13.310 | Varstvo pred kriminalom | Protection against crime |
| 91.060.50 | Vrata in okna | Doors and windows |

SIST EN 1630:2012 en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 1630:2012

<https://standards.iteh.ai/catalog/standards/sist/8cfc02da-a31b-41ed-ba97-9168584730c6/sist-en-1630-2012>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 1630

May 2011

ICS 13.310; 91.060.50

Supersedes ENV 1630:1999

English Version

**Pedestrian doorsets, windows, curtain walling, grilles and
shutters - Burglar resistance - Test method for the determination
of resistance to manual burglary attempts**

Blocs-portes pour piétons, fenêtres, façades rideaux, grilles
et fermetures - Résistance à l'effraction - Méthode d'essai
pour la détermination de la résistance aux tentatives
manuelles d'effraction

Türen, Fenster, Vorhangfassaden, Gitterelemente und
Abschlüsse - Einbruchhemmung - Prüfverfahren für die
Ermittlung der Widerstandsfähigkeit gegen manuelle
Einbruchversuche

This European Standard was approved by CEN on 2 December 2010.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

| Contents | Page |
|---|-------------|
| Foreword | 4 |
| 1 Scope | 5 |
| 2 Normative references | 5 |
| 3 Terms and definitions | 6 |
| 4 Apparatus and test team | 7 |
| 4.1 Test rig | 7 |
| 4.2 Test team | 7 |
| 4.3 Measurement and recording devices | 8 |
| 4.3.1 Measuring equipment | 8 |
| 4.3.2 Video recording | 8 |
| 4.4 Tolerances | 8 |
| 4.5 Sub-frame | 9 |
| 5 Test specimen | 9 |
| 5.1 General | 9 |
| 5.2 Preparation and examination of the specimen | 10 |
| 6 Procedure | 10 |
| 6.1 General | 10 |
| 6.2 Test room climate | 10 |
| 6.3 Areas of attack | 10 |
| 6.3.1 General | 10 |
| 6.3.2 Construction products with moving elements | 11 |
| 6.3.3 Fixed construction products | 11 |
| 6.4 Attack side and attack height | 11 |
| 6.5 Pre-test | 11 |
| 6.6 Main test | 11 |
| 6.7 Failure criteria | 12 |
| 7 Tool sets | 12 |
| 7.1 General | 12 |
| 7.2 Tool set A1 resistance class 1 (see Figure A.1) – Application of the tool set A1 in resistance class 1 | 12 |
| 7.3 Tool set A2 resistance class 2 (see Figure A.2) – Application of the tool set A2 in resistance class 2 | 13 |
| 7.4 Tool set A3 resistance class 3 (see Figure A.3) – Application of the tool set A3 in resistance class 3 | 14 |
| 7.5 Tool set A4 resistance class 4 (see Figure A.4) – Application of the tool set A4 in resistance class 4 | 14 |
| 7.6 Tool set A5 resistance class 5 (see Figure A.5) – Application of the tool set A5 in resistance class 5 | 15 |
| 7.7 Tool set A6 resistance class 6 (see Figure A.6) – Application of the tool set A6 in resistance class 6 | 15 |
| 8 Test report | 16 |
| Annex A (normative) Tool sets | 18 |
| A.1 Tool set A1 | 18 |
| A.2 Tool set A2 | 19 |
| A.3 Tool set A3 | 20 |
| A.4 Tool set A4 | 21 |
| A.5 Tool set A5 | 22 |

| | | |
|--|--|----|
| A.6 | Tool set A6 | 23 |
| Annex B (normative) Test sequence for manual test of resistance classes 2 to 6 | | 24 |
| B.1 | Test sequence for manual test of resistance classes 2 to 6 | 24 |
| Annex C (normative) Example of test equipment | | 25 |
| Annex D (informative) Examples of mounting arrangements | | 26 |
| D.1 | Examples of mounting arrangements for doorsets | 26 |
| D.2 | Examples of mounting arrangements for windows | 29 |
| D.3 | Examples of mounting arrangements for wing and folding shutters..... | 30 |
| D.4 | Examples of mounting arrangements for guide rails and roller shutters into the test rig | 32 |
| D.5 | Examples of mounting arrangements for grilles into the test rig..... | 35 |
| Bibliography | | 37 |

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 1630:2012](https://standards.iteh.ai/catalog/standards/sist/8cfc02da-a31b-41ed-ba97-9168584730c6/sist-en-1630-2012)

<https://standards.iteh.ai/catalog/standards/sist/8cfc02da-a31b-41ed-ba97-9168584730c6/sist-en-1630-2012>

EN 1630:2011 (E)

Foreword

This document (EN 1627:2011) has been prepared by Technical Committee CEN/TC 33 “Doors, windows, shutters, building hardware and curtain walling”, the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2011, and conflicting national standards shall be withdrawn at the latest by November 2011.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes ENV 1630:1999.

This European Standard is one of a series of standards for burglar resistant pedestrian doorsets, windows, curtain walling, grilles and shutters. The other standards in the series are:

— EN 1627:2011, *Pedestrian doorsets, windows, curtain walling, grilles and shutters — Burglar resistance — Requirements and classification*;

— EN 1628:2011, *Pedestrian doorsets, windows, curtain walling, grilles and shutters — Burglar resistance — Test method for the determination of resistance under static loading*;

— EN 1629:2011, *Pedestrian doorsets, windows, curtain walling, grilles and shutters — Burglar resistance — Test method for the determination of resistance under dynamic loading*.

<https://standards.iteh.ai/catalog/standards/sist/8cfc02da-a31b-41ed-ba97-998989898989>

This standard is a revision of, and supersedes ENV 1630:1999. The three other standards in this series are revisions of, and supersede ENV 1627, ENV 1628 and ENV 1629 respectively.

This revision incorporates grilles and curtain walling in the range of application.

The manual test described in this standard covers the areas of vulnerability not suitably assessed by the static loading and dynamic loading tests described in EN 1628:2011 and EN 1629:2011. Certain basic security requirements for the locks, furniture and cylinders are covered by the requirements detailed in Table 3 of EN 1627:2011. These security characteristics are not re-assessed in this test standard and the attack methods and test times have been limited to reflect this.

The use of the tools detailed in the various tools sets is described in this standard. This has the advantage of improving the reproducibility of the test.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This European Standard specifies a test method for the determination of resistance to manual burglary attempts in order to assess the burglar resistant characteristics of pedestrian doorsets, windows, curtain walling, grilles and shutters. It is applicable to the following means of opening: Turning, tilting, folding, turn-tilting, top or bottom hung, sliding (horizontally and vertically) and rolling as well as fixed constructions.

This European Standard does not directly cover the resistance of locks and cylinders to attack with picking tools. It also does not cover the attack of electric, electronic and electromagnetic operated burglar resistant construction products using attack methods that might defeat these characteristics.

It is acknowledged that there are two aspects to the burglar resistance performance of construction products, their normal resistance to forced operation and their ability to remain fixed to the building. Due to the limitation of reproducing the fixing methods and building construction in a laboratory environment this aspect is not fully covered by the standard. This is particularly true with products built into a building. The performance of the fixed part of the product is evaluated using a standard sub frame. It is the manufacturer's responsibility to ensure that guidance on the fixing of the product is contained in the mounting instructions and that this guidance is suitable for the burglar resistance class claimed for the product. As with the other referenced standards this specification uses a standard sub frame and the product is mounted according to the manufacturers' instructions. An example for the contents of the manufacturer's installation instructions is given in Annex A of EN 1627:2011. This test method does not evaluate the performance of the fixing to the building.

This European Standard does not apply to doors, gates and barriers, intended for installation in areas in the reach of persons, and for which the main intended uses are giving safe access for goods and vehicles accompanied or driven by persons in industrial, commercial or residential premises, as covered by EN 13241-1.

SIST EN 1630:2012

<https://standards.iteh.ai/catalog/standards/sist/8cfc02da-a31b-41ed-ba97-9168584730c6/sist-en-1630-2012>

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 356:1999, *Glass in building – Security glazing – Testing and classification of resistance against manual attack*

EN 1303:2005, *Building hardware – Cylinders for locks – Requirements and test methods*

EN 1627:2011, *Pedestrian doorsets, windows, curtain walling, grilles and shutters – Burglar resistance – Requirements and classification*

EN 1628:2011, *Pedestrian doorsets, windows, curtain walling, grilles and shutters – Burglar resistance – Test method for the determination of resistance under static loading*

EN 1629:2011, *Pedestrian doorsets, windows, curtain walling, grilles and shutters – Burglar resistance – Test method for the determination of resistance under dynamic loading*

EN 1906:2010, *Building hardware – Lever handles and knob furniture – Requirements and test methods*

EN 12209:2003, *Building hardware – Locks and latches – Mechanically operated locks, latches and locking plates – Requirements and test methods*

EN 1630:2011 (E)

EN ISO/IEC 17025:2005, *General requirements for the competence of testing and calibration laboratories*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1627:2011 and the following apply.

3.1**attack side**

side of the test specimen defined by the applicant as the side exposed to attack

3.2**test specimen**

complete, fully functioning construction product as detailed in the scope of this standard

3.3**sub-frame**

surrounding frame into which the test specimen is mounted in accordance with the manufacturer's instructions

3.4**test rig**

surrounding substantial steel frame with movable steel supports into which the sub-frames containing test specimens of various dimensions can be mounted

3.5**tool set**

set of tools allocated for use for a particular resistance class

NOTE

For details of the tool set, see Clause 7 and Annex A.

3.6**resistance time**

working time of the test person carrying out the manual burglary test (see EN 1627:2011, Table 7)

NOTE

The resistance time includes times of less than 5 s each for tool changes, e.g. exchanging a screwdriver for a crow bar.

3.7**rest time**

time taken when the test person carrying out the manual burglary test interrupts his work for a rest

3.8**tool change time**

time for the exchange or replacement of a tool or a part thereof, e.g. a defective drill, a blunt saw blade etc.

3.9**observation time**

time required for the test team to observe the test and to decide on its further execution

3.10**total test time**

combination of the resistance times, the rest times, the times for tool changes and the observation times during the main test

3.11**accessible opening**

opening permitting a test block of cross section of any of the dimensions shown below to be passed through it

| | | | | |
|------|--------------|------------------------|----------------------------|----------------|
| NOTE | Template E1: | - a rectangle of | 400 mm \pm 2 mm x 250 mm | \pm 2 mm; or |
| | Template E2: | - an ellipse of | 400 mm \pm 2 mm x 300 mm | \pm 2 mm; or |
| | Template E3: | - a circle of diameter | 350 mm \pm 2 mm | |

All templates shall be 20 mm \pm 5 mm thick.

4 Apparatus and test team**4.1 Test rig**

The test rig shall consist of a rigid steel frame with movable steel supports into which test specimens of various dimensions can be mounted, as shown in Annex C, Figure C.1. The stiffness of the rig shall be such that a 15 kN force applied to any of the defined points and normal to the plane of the frame shall not cause a deflection of more than 5 mm. The test rig shall not impede the execution of the test.

4.2 Test team**4.2.1 Personnel**

The requirements for the test team personnel shall be in accordance with EN ISO/IEC 17025:2005, 5.2.

[SIST EN 1630:2012](https://standards.iteh.ai/catalog/standards/sist/8cfc02da-a31b-41ed-ba97-9168584730c6/sist-en-1630-2012)

4.2.2 Composition of the test team

The test team shall comprise a minimum of two people.

At least two members of the test team shall be capable of performing the manual test.

At least one member of the test team shall be competent to record the data and observations in such a way that a test report can be established.

For each test in an area of attack only one test team member shall be permitted.

4.2.3 Essential capabilities of the test team members

In order to perform the manual test, test team members shall be able to demonstrate that they are:

- mentally alert and well-motivated to maintain a sustained burglary attack;
- physically able to perform the test, and are able to withstand the physical strain likely to be imposed for the duration of the test;
- free from mobility impairments and have normal vision, corrected where necessary;
- capable of reflecting current modus operandi during burglary attacks using reasonable but not excessive force reflecting the anticipated attack relevant to the resistance class.

EN 1630:2011 (E)

In addition, the test team shall be able to demonstrate detailed knowledge and understanding of:

- the design and manufacture of burglar resistant construction products including the locks, hardware and materials used;
- current modus operandi during burglary attacks;
- operation and control of test equipment;
- operation, control and maintenance of the attack tool sets;
- operation, control and maintenance of the measuring equipment;
- the handling of the tools used when performing the test for burglar resistance.

4.2.4 Training

The test team shall have the opportunity for continuous development of skills and expertise appropriate to the performance of the tests, including:

- checking and assessing of video recording of the tests by the test team;

NOTE Video records may also form the basis for demonstrating the competence of test team members.

- the exchange of knowledge and experience between testing bodies and police agencies;
- further training e.g. measuring techniques, material information, new construction products, new opening and closing techniques.

4.3 Measurement and recording devices

SIST EN 1630:2012
<https://standards.iteh.ai/catalog/standards/sist/8cfc02da-a31b-41ed-ba97-9168584730c6/sist-en-1630-2012>

4.3.1 Measuring equipment

The following equipment shall be provided:

- a) chronometer for measuring the resistance time;
- b) chronometer for measuring the total test time;
- c) equipment for determining temperature and relative humidity.

4.3.2 Video recording

The pre-test and the main test conducted on each test specimen shall be fully recorded with a video recorder. The videotape and any copies of it shall not be published nor shown publicly.

NOTE 1 The video may be used as a reference when subsequent changes are made to the product.

NOTE 2 A time reference or code should be shown in the video.

NOTE 3 When a test laboratory is asked to conduct the test and a video is recorded, the test laboratory should include restrictions on the use of the video in their terms and conditions of contract with the submitter.

4.4 Tolerances

Unless stated otherwise in this European Standard the following tolerances shall apply to the test equipment:

| | |
|---------------------|------|
| — Time | ± 1% |
| — Temperature | ± 1° |
| — Relative humidity | ± 5% |

4.5 Sub-frame

The sub frame shall simulate the support given to the product when installed into a building and shall be taken into consideration in the manufacturer's installation instructions. It shall typically consist of the following:

- a) for group 1 to group 4 products, a rectangular metal tube 120 mm x 120 mm x 5 mm or a rectangular timber frame 100 mm x 50 mm;
- b) additionally for group 3 products and group 4 products, a steel tube 40 mm x 40 mm x 3 mm and a base plate of 8 mm steel, consisting of several segments which shall be removable for the purposes of loading, if necessary.

5 Test specimen

5.1 General

The test specimen shall be a functioning product complete with its frames, hardware, guide rails, curtain, tube, roller box and accessories, as appropriate.

The test specimen shall be fixed square and plumb and without twist or bend into a sub-frame. Installation shall be carried out in accordance with the manufacturer's instructions as detailed in Clause 10 of EN 1627:2011, including the method of fixing, packing supports, sealing requirements etc, as shown in Annex D, Figures D.1 to D.18. The test specimen shall be located in the test rig at a height relative to ground, nominal the same as intended in use. i.e. doors and French windows shall be mounted at ground level and windows shall be mounted at a height of 800 mm from ground level.

At least two specimens shall be provided for testing, one for the pre-test and one for the main test.

NOTE 1 Under particular circumstances, additional specimens might be required.

NOTE 2 The specimen used in the static test carried out in accordance with EN 1628:2011 and in the dynamic test carried out in accordance with EN 1629:2011 may also be used in the pre-test, provided that any damage caused by those tests will not affect the result of the pre-test.

For the purposes of this standard, the test specimen shall be glazed according to the relevant glazing resistance class of EN 356:1999, corresponding to the resistance class of the construction product according to EN 1627:2011, as shown in Table 1. Security glazing, when used in an insulating glass unit, is normally positioned on the inside of the building. For the purpose of this test the glass pane offering the highest security level shall be positioned on the attack side of the sample.

EN 1630:2011 (E)

Table 1 — Test sample glazing requirements

| Resistance class | Resistance class of glazing according to EN 356 |
|------------------|---|
| RC 1 N | P4 A |
| RC 2 N | P4 A |
| RC 2 | P4 A |
| RC 3 | P5 A |
| RC 4 | P6 B |
| RC 5 | P7 B |
| RC 6 | P8 B |

5.2 Preparation and examination of the specimen

The temperature of the test specimen shall be maintained between 15 °C and 30 °C for a period of not less than 8 hours prior to test.

The test specimen and sub-frame mounted in the test rig shall be visually examined for damage, defects or other particular conditions of finish, etc. These shall be recorded.

Each test specimen shall be examined and the direction to disengage each locking point shall be noted.

The test specimen shall be closed and locked at the declared closing condition in accordance with the manufacturer's instructions.

All locking hardware that can be disengaged from the attack side without the use of a key or tool shall be disengaged during all tests.

NOTE This includes, for example, non-arresting latch bolts which are not engaged in the locking position.

6 Procedure

6.1 General

The test sequence shall be as given in Annex B, Figure B.1.

6.2 Test room climate

The test room temperature shall be between 15 °C and 30 °C.

The relative humidity shall be between 30 % and 70 %.

6.3 Areas of attack

6.3.1 General

For construction products in resistance classes 2 to 4 of EN 1627:2011, the glass itself shall not be directly attacked. The glazing and infilling retention system shall be attacked. For construction products in resistance classes 5 and 6 of EN 1627:2011, the glass itself and the glazing and infilling retention system shall be attacked. For construction products without key unlockable hardware on the non-attack side entry might be gained by penetrating the product and operating the hardware. This vulnerability shall be explored.