
**Varnostne shranjevalne enote - Klasifikacija in metode preskušanja odpornosti
proti ognju - Shranjevalne enote za zaščito papirja do 170 °C**

Secure storage units - Classification and methods of test for resistance to fire - Light fire
storage units

Wertbehältnisse - Klassifizierung und Methoden zur Prüfung des Widerstandes gegen
Brand - Leichte Brandschutzschränke

Unités de stockage en lieu sûr - Classification et méthodes d'essais de résistance au feu
- Meubles ignifuges premier niveau

[SIST EN 15659:2009](https://standards.iteh.ai/catalog/standards/sist/ca892970-ef91-4a75-be3c-84e1a359d1f/sist-en-15659-2009)

[https://standards.iteh.ai/catalog/standards/sist/ca892970-ef91-4a75-be3c-](https://standards.iteh.ai/catalog/standards/sist/ca892970-ef91-4a75-be3c-84e1a359d1f/sist-en-15659-2009)

[84e1a359d1f/sist-en-15659-2009](https://standards.iteh.ai/catalog/standards/sist/ca892970-ef91-4a75-be3c-84e1a359d1f/sist-en-15659-2009)

Ta slovenski standard je istoveten z: EN 15659:2009

ICS:

13.220.40	Sposobnost vžiga in obnašanje materialov in proizvodov pri gorenju	Ignitability and burning behaviour of materials and products
13.310	Varstvo pred kriminalom	Protection against crime
35.220.99	Druge naprave za shranjevanje podatkov	Other data storage devices

SIST EN 15659:2009

en,fr

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 15659:2009

<https://standards.iteh.ai/catalog/standards/sist/ca892970-ef91-4a75-be3c-84e1a359dfff/sist-en-15659-2009>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 15659

April 2009

ICS 13.220.40; 91.060.01

English Version

**Secure storage units - Classification and methods of test for
resistance to fire - Light fire storage units**

Unités de stockage en lieu sûr - Classification et méthodes
d'essais de résistance au feu - Meubles ignifuges premier
niveau

Wertbehältnisse - Klassifizierung und Methoden zur
Prüfung des Widerstandes gegen Brand - Leichte
Brandschutzschränke

This European Standard was approved by CEN on 19 March 2009.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

SIST EN 15659:2009

<https://standards.iteh.ai/catalog/standards/sist/ca892970-ef91-4a75-be3c-84e1a359dfff/sist-en-15659-2009>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Requirements, classification and locks	5
5 Test specimen, technical documentation and correlation	6
5.1 Test specimen	6
5.2 Technical documentation of the test specimen	6
5.3 Correlation of test specimens and technical documentation	7
6 Test methods.....	7
6.1 Principle	7
6.2 Test equipment	7
6.3 Preparation for test.....	8
6.4 Procedure	10
6.4.1 Correlation	10
6.4.2 Fire endurance test.....	11
6.4.3 Examination.....	12
7 Test report	12
8 Marking	12

Figures

Figure 1 — Measurement points	9
Figure 2 — Cable entry hole and sealing	10
Figure 3 — Protection of instrument cables	11

Tables

Table 1 — Protection level requirements	6
---	---

Foreword

This document (EN 15659:2009) has been prepared by Technical Committee CEN/TC 263 “Secure storage of cash, valuables and data media”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2009, and conflicting national standards shall be withdrawn at the latest by October 2009.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 15659:2009

<https://standards.iteh.ai/catalog/standards/sist/ca892970-ef91-4a75-be3c-84e1a359dfff/sist-en-15659-2009>

Introduction

The testing conditions given in this European Standard provide a basis for simulating fires to determine, in a reproducible way, the fire resistance of light fire storage units at various protection levels. The protection levels enable a comparison to be made of the resistance against fire provided by different constructions.

The threshold value for the maximum temperature increase of 150 K at every measuring point in the protection levels LFS 30 P and LFS 60 P for light fire storage units from a starting temperature of $(21 \pm 1)^\circ\text{C}$, as defined in this European Standard, refers to the relatively short-term stress due to high temperatures during a fire test. It is not normally experienced by paper media stored in light fire storage units in the normal and correct way.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 15659:2009

<https://standards.iteh.ai/catalog/standards/sist/ca892970-ef91-4a75-be3c-84e1a359dfff/sist-en-15659-2009>

1 Scope

This European Standard specifies requirements for light fire storage units providing protection against fire.

The method of test is specified to determine the ability of light fire storage units to protect paper media from the effects of fire. Two levels of fire exposure periods (LFS 30 P and LFS 60 P) are specified using the maximum temperature increase permitted within the storage space of the light fire storage unit.

Requirements are also specified for the test specimen, the technical documentation for the test specimen, correlation of the test specimen with the technical documentation, preparation for type testing and test procedures.

A scheme to classify the light fire storage units from the test results is also given (see Table 1).

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1:1999, *Fire resistance tests — Part 1: General requirements*

EN 60584-1, *Thermocouples — Part 1: Reference tables (IEC 60584-1:1995)*.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

light fire storage unit

storage unit designed to protect paper media, except for paper grades where data loss occurs at temperatures below 172°C, as well as valuables against the effects of temperatures up to 172°C

NOTE A light fire storage unit can have doors, drawers, lids, connections and fittings.

3.2

compartment

part of a light fire storage unit which can be closed with a separate door, lid or cover

NOTE A compartment formed by inserting a shelf board is not a compartment within the meaning of this standard.

3.3

lock

device which verifies an entered code and performs a blocking function on the boltwork or the door

4 Requirements, classification and locks

4.1 Light fire storage units shall provide protection against the effects of fire (see Clause 6) and be classified as specified in Table 1.

Table 1 — Protection level requirements

Protection level		Maximum temperature increase
30 min	60 min	
LFS 30 P	LFS 60 P	150 K
NOTE 1 Where LFS is the symbol applied for light fire storage units.		
NOTE 2 The numerical values in the protection level are the duration of fire exposure during the type test in minutes.		
NOTE 3 P represents protection of data on paper, excluding those paper grades which lose data below 172°C.		

4.2 Light fire storage units shall be fitted with a lock.

5 Test specimen, technical documentation and correlation

5.1 Test specimen

Of several models of a series (with one door, two doors, drawers, etc.) having the same design, protection and construction features (type and thickness of construction and protective materials, rabbet geometry, etc.) as well as the same base (with a tolerance of $\pm 15\%$ each applicable to the internal dimensions of width and depth), the models with the smallest and largest internal height resp. the lowest and highest number of drawers shall be tested.

Light fire storage units with double doors shall be regarded as a separate model range.

Where a variety of locking options is available, the test specimen used in the type test shall be coordinated with the testing laboratory.

Two identical light fire storage units shall be available: one for the fire endurance test, the other for verifying correlation of the filling material with the technical documentation. The testing laboratory shall decide which test specimen will be used for the type test. The test specimen shall be modified at its base for installing the measuring instrumentation (see 6.3.1 and Figure 2) and may have, but need not have a plinth.

5.2 Technical documentation of the test specimen

Detailed technical documentation about the range and test specimen (drawings, specifications of materials, installation and processing advice) shall be submitted to the testing laboratory before the type test. The drawings shall give specifications as to height, width and depth of the test specimens, materials and their thicknesses, dimensions of rabbet edges, locking system, welds including the method of their execution, seals, etc. The mass of the plinth shall be given.

Samples and detailed specifications of all heat protection materials and seals used in the test specimens shall accompany the test specimens.

The date(s) on which the test specimens were filled with fire protection materials shall be given.

NOTE 1 With reference to all heat protection materials, the technical documentation should include: a) quality control parameters, and b) details of the performance characteristics, or c) details of the constituent materials and processing methods.

NOTE 2 In connection with the type test, the testing laboratory should mark three sets of the technical documentation with signature, stamp and date. One set is sent to the applicant. One set is added to the monitoring documentation for certification and quality assurance. One set is kept in the testing files of the test laboratory.

5.3 Correlation of test specimens and technical documentation

The test specimens and the supplied technical documentation must correlate.

As to mass, the two test specimens shall not differ by more than 10 %.

In series production, the wall, ceiling and door thicknesses must not be below the specified minimum limit of the type-tested thickness by more than 3 %.

6 Test methods

6.1 Principle

The fire endurance of the test specimen is assessed by heating in a furnace.

During the type test the temperature in the interior of the test specimen is measured.

6.2 Test equipment

6.2.1 The furnace which must be capable of providing the uniform heating conditions specified in this standard, and constructed so that the four vertical walls of the test specimen can each be exposed to the same heating conditions with no direct flame impingement onto the test specimen.

The distance between the interior walls of the furnace and the surface of the test specimen shall be ≥ 750 mm. The furnace conditions shall conform to EN 1363-1. To meet these conditions, the setting of the neutral pressure level shall be made in accordance with 6.2.2 and the measurement of the temperature in the interior of the furnace shall be made with instrumentation in accordance with 6.2.3.

6.2.2 The furnace shall be operated such that the neutral pressure level is reached after 5 min of firing, measured at ± 5 Pa 1,000 mm above the furnace base. Test specimens with an external height of $> 1,000$ mm shall be placed on the furnace base during the type test. Test specimens with an external height of $\leq 1,000$ mm shall be positioned on a plinth of brick with a height of 500 mm. For pressure measurements, pressure measuring heads in accordance with 4.5.2 of EN 1363-1:1999 shall be used.

NOTE In order to ensure consistent heating conditions, the width of the plinth area around the projected cross-sectional area of the test specimen should not exceed 200 mm.

6.2.3 Thermocouples of type K (NiCr-Ni) with a measurement uncertainty in accordance with EN 60584-1 for measuring the furnace temperature. The furnace thermocouples shall be plate thermometers according to 4.5.1.1 of EN 1363-1:1999.

6.2.4 Thermocouples consisting of 0.5 mm diameter wires of type K (NiCr-Ni) or type J (Fe-CuNi) with a measurement uncertainty in accordance with EN 60584-1 for measuring the air and surface temperatures in the test specimen. The measurement results shall be recorded at intervals not greater than 1 min. The contact measurement points shall be assembled in accordance with 4.5.1.2 and 4.5.1.4 of EN 1363-1:1999, respectively.

6.2.5 Timing device, capable of running continuously throughout the test period.

6.2.6 Equipment for weighing test specimens, with an error limit of ± 3 %.