

SLOVENSKI STANDARD oSIST prEN 13313:2009

01-junij-2009

<`UX]`bY`bUdfUj Y`]b`hcd`chbY` fdU_Y`!`Ghfc_cj bU`i gdcgcV`^YbcghcgYV^U! 8 cdc`b]`b]`YYa Ybh

Refrigerating systems and heat pumps - Competence of personnel - Complementary element

Kälteanlagen und Wärmepumpen - Sachkunde von Personal

Systèmes de réfrigération et pompes à chaleur - Compétence du personnel

Ta slovenski standard je istoveten z: prEN 13313

<u>SIST EN 13313:2012</u>

ICS:

27.080 V[] |[\$ ^ A \ \ |] æ \ \ Heat pumps

27.200 Hladilna tehnologija Refrigerating technology

oSIST prEN 13313:2009 en,fr,de

oSIST prEN 13313:2009

iTeh Standards (https://standards.iteh.ai) Document Preview

SIST EN 13313:2012

EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

DRAFT prEN 13313

April 2009

ICS 27.080; 27.200

Will supersede EN 13313:2001

English Version

Refrigerating systems and heat pumps - Competence of personnel - Complementary element

Systèmes de réfrigération et pompes à chaleur -Compétence du personnel

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 182.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning: This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.

11tps://standards.iteh.ai/catalog/standards/sist/8d6d08c5-7e12-4e9a-b6cb-91a9fe8cc19f/sist-en-13313-2012



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Con	tents	Page
Forew	vord	3
Introduction		
1	Scope	5
2	Normative references	5
3	Terms and definitions	5
4	Competences	7
4.1	General	
4.2	Competence level	8
4.3	Requirements for assessment and maintenance of competence	8
4.3.1	General requirements	8
4.3.2	Competence assessment	8
4.3.3	Maintenance of competence	8
Annex	x A (normative) Assessment of competences	9
A.1	General	
A.2	Assessment	
A.2.1		
	Overview	
Annex	x B (informative)	18
Annex	x C (informative) Electricity	19
Biblio	graphy	20
	3. * F. · · · · · · · · · · · · · · · · · ·	-

SIST EN 13313:2012

Foreword

This document (prEN 13313:2009) has been prepared by Technical Committee CEN/TC 182 "Refrigerating systems and heat pumps", the secretariat of which is held by DIN.

This document is currently submitted to the CEN Enquiry.

This document will supersede EN 13313:2001.

iTeh Standards (https://standards.iteh.ai) Document Preview

SIST EN 13313:2012

Introduction

Refrigerating systems, if not properly constructed, installed, operated and maintained, can be of danger to the health and safety of persons and detrimental to the environment.

It is therefore essential that personnel dealing with such systems are competent to carry out the activity or activities listed in this standard. These activities cover the particular sectors in which they may operate from original design to final dismantling and disposal. As job descriptions can vary from country to country and from company to company this standard specifies the activities to be carried out. Job descriptions should specify this activities.

This standard defines the activities related the refrigerating circuit.

iTeh Standards (https://standards.iteh.ai) Document Preview

SIST EN 13313:2012

1 Scope

This European Standard defines the activities related to refrigerating circuits and the associated competence profiles and establishes procedures for assessing the competence of persons who carry out these activities.

NOTE: As a refrigeration circuit is considered not to incorporate electrical and electronical systems activities in this area are not part of this standard. For competences on electrical and electronical systems see EN 50110.

This European Standard does not apply to persons carrying out work on self contained refrigerating systems as defined in EN 378-1 from the initial design of the product to the complete manufacture of the product provided the process is controlled and the methods used are checked by an organisation or individual responsible for the compliance with statutory requirements of health, safety and environment.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 378-1	Refrigerating	systems	and	heat	pumps	_	Safety	and
	environmental	requireme	ents _	_ Part	1 · R	asic	requirem	ents

environmental requirements – Part 1: Basic requirements,

classification and selection criteria

EN 378-2 Refrigerating systems and heat pumps – Safety and

environmental requirements - Part 2: Design, construction,

testing, marking and documentation

EN 378-3 Refrigerating systems and heat pumps – Safety and

environmental requirements - Part 3: Installation site and personal

protection

EN 378-4 desired all catalog star Refrigerating systems and heat pumps — Safety and 13-2012

environmental requirements – Part 4: Operation, maintenance,

repair and recovery

EN ISO/IEC 17024 Conformity assessment - General requirements for bodies

operating certification of persons

EN 50110 Operation of electrical installations (National Annexes)

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

assessment

process by which the evidence generated, gathered and provided about a person is judged to determine competence

3.2

approved organisation (awarding body)

organisation which is recognised to assess competence and to award certificates (a proof of competence) recognizing the health, safety, environmental and energy conservation competence of persons working on refrigerating systems and heat pumps

NOTE General criteria for awarding bodies can be found in EN-ISO/IEC 17024.

3.3

competence

ability to perform safely and satisfactorily the activities within an occupation

NOTE With reference to this standard to be competent means to have the knowledge and/or skill to perform the task(s) under consideration, so that a level according to this European Standard is achieved and simultaneously to possess the necessary insight into the relevant problems to understand why the task should be carried out in such a way.

3.4

qualification

evidence of a certain level professional competence see POINT 4.2 and specified in Annex A

3.5

certification

procedure used to demonstrate the qualification of personnel at a level and leading to the issue of a certificate

3.6

certificate

document issued under the rules of the assessment system defined in this annex indicating that the named person is competent to deal with applicable health, safety, environmental protection and energy conservation requirements for refrigerating systems and heat pumps

3.7

designing

collecting all date required for making a appropriate refrigerating circuit. Making the conceptual and detailed plan of the refrigerating circuit (e.g. dimensioning, calculation, component selection, refrigerant piping layout and sizing)

3.8

pre-assembling

fabricating parts and sub-assemblies of a refrigeration circuit in a workshop or on site

3.9

installation

joining two or more pieces of equipment or circuits designed to contain refrigerant, with a view to assembling a refrigeration, air-conditioning or heat pump system in the location where it will be operated. Installation excludes the action by which a system already assembled is plugged in before being put in operation. It excludes all the operations carried out at the manufacturing site

3.10

putting into operation

integrity inspection and bringing into work the refrigeration system for the first time or after significant changes

3.11

commissioning

all activities needed for ensuring that the system is performing according the predefined conditions after putting the system into operation

3.12

operating

running the refrigerating circuit in a routine manner ensuring that the system works within the conditions required in the user manual

3.13

in-service inspection

all activities needed to check if the system complies to predefined requirements (e.g. functionality, temperature or capacity checks, quality checks of joints and welding, existence of corrosion)

3.14

leakage checking

identifying if there is a leak of refrigerant from the refrigerating circuit and if yes, identification of the exact location of the leak and report the results

3.15

general maintenance

keeping or restoring a system to a state from which the desired operation can be provided without breaking into the refrigerating circuit

3.16

circuit maintenance

keeping or restoring a system to a state from which the desired operation can be provided by breaking into the refrigerating circuit

3.17

decommisioning

taking a circuit out of operation for a longer period without breaking into the circuit

3.18

removing of refrigerant

taking the refrigerant out of a refrigerating circuit

3.19

dismantling

breaking the refrigerating circuit down into pieces

3.20

basic appreciation

The level of expertise required to discuss main elements of the skill with others. 91e8cc19f/sist-en-13313-2012

3.21

working knowledge

The level of expertise required for direct involvement in decisions and actions

3.22

fully operational

The level of expertise required to perform personally the majority of the activities

3.23

leading edge

The level of expertise required for significant development

4 Competences

4.1 General

A person shall be deemed competent if it can be demonstrated that they are capable of carrying out the activities.

4.2 Competence level

The person shall demonstrate a level of predefined competence as defined in 3.20, 3.21, 3.22, 3.23 of theoretical and/or practical ability as necessary for the activity in question as set out in annex A.

4.3 Requirements for assessment and maintenance of competence

4.3.1 General requirements

The competence of persons who work on refrigerating systems shall be checked by an independent certification body according to the EN ISO/IEC 17024 and the documents as connected to these competence profiles.

4.3.2 Competence assessment

The competence of a person shall be assessed preferably by an approved organisation.

The certification of competence shall be as required by national regulations. If no national regulations or procedures exist, the overview of assessment set out in annex A can be used.

NOTE Some aspects of a person's competence may need to be reassessed on a regular basis.

4.3.3 Maintenance of competence

Persons shall maintain that their competence, as appropriate by declaration with approved evidence, is according the overview set out in annex A.

Document Preview

SIST EN 13313:2012