

SLOVENSKI STANDARD SIST EN 877:2001/A1:2007/AC:2008

01-april-2008

Cevi, fitingi in pribor iz litega železa za hišne vodne odtoke - Zahteve, postopki preskušanja in zagotavljanje kakovosti

Cast iron pipes and fittings, their joints and accessories for the evacuation of water from buildings - Requirements, test methods and quality assurance

Rohre und Formstücke aus Gusseisen, deren Verbindungen und Zubehör zur Entwässerung von Gebäuden Anforderungen, Prüverfahren und Qualitätssicherung

Tuyaux et raccords en fonte, leurs assemblages et accessoires destinés à l'évacuation des bâtiments - Prescriptions, méthodes d'essai et assurance qualité

https://standards.iteh.ai/catalog/standards/sist/eb924f60-8241-483b-9b83-

Ta slovenski standard je istoveten z: EN 877:2001-a1-2007-ac-2008

ICS:

23.040.10 Železne in jeklene cevi Iron and steel pipes

23.040.40 Kovinski fitingi Metal fittings

91.140.80 Drenažni sistemi Drainage systems

SIST EN 877:2001/A1:2007/AC:2008 en,fr SIST EN 877:2001/A1:2007/AC:2008

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST EN 877:2001/A1:2007/AC:2008</u> https://standards.iteh.ai/catalog/standards/sist/eb924f60-8241-483b-9b83c1d2d0f415ef/sist-en-877-2001-a1-2007-ac-2008

EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN 877:1999/A1:2006/AC

January 2008 Janvier 2008 Januar 2008

ICS 23.040.10; 23.040.40

English version Version Française Deutsche Fassung

Cast iron pipes and fittings, their joints and accessories for the evacuation of water from buildings - Requirements, test methods and quality assurance

Tuyaux et raccords en fonte, leurs assemblages et accessoires destinés à l'évacuation des bâtiments - Prescriptions, méthodes d'essai et assurance qualité Rohre und Formstücke aus Gusseisen, deren Verbindungen und Zubehör zur Entwässerung von Gebäuden -Anforderungen, Prüverfahren und Qualitätssicherung

This corrigendum becomes effective on 30 January 2008 for incorporation in the three official language versions of the EN. (standards.iteh.ai)

Ce corrigendum prendra effet le 30 janvier 2008 pour incorporation dans les trois versions linguistiques officielles de la ENSIST EN 877:2001/A1:2007/AC:2008

https://standards.iteh.ai/catalog/standards/sist/eb924f60-8241-483b-9b83-

Die Berichtigung tritt am 30. Januar 2008 zur Einarbeitung in die drei offiziellen Sprachfassungen der EN in Kraft.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

3 Definitions

Add

"3.13 range of products

Group of products produced by one manufacturer for which the test results for one or more characteristics from any one product within the range are valid for all other products within this range.".

4.1.3 Reaction to fire

In the second dash, replace the words "assembled products" with "a range" and delete the comma after the bracket to read: "

— a range (including coated pipes, coated fittings and couplings) shall be tested according to EN 13823 (SBI), using the mounting adaptations given in Annex H, and shall satisfy the requirements of classification criteria and additional classifications listed in EN 13501-1 for the intended class of reaction to fire."

4.6.3 External coatings

Replace the words "the products assembled as a discharge system" with "the range" and "PCS system ext. coating" with "PCS range ext. coating" to read: "

(standards.iteh.ai)

... <u>SIST EN 877:2001/A1:2007/AC:2008</u> https://standards.iteh.ai/catalog/standards/sist/eb924f60-8241-483b-9b83-

For a classification of the range within classes E to B (see EN 13501-1) table on "classes on reaction to fire on performance for construction products excluding floorings"), each coating shall conform to the following requirements when tested in accordance to 5.7.3.3:

 Ignitability: requirements of classification criteria and additional classifications listed in EN 13501-1 specific to the class.

For an A2 classification of the range (see EN 13501-1, table on "classes on reaction to fire on performance for construction products excluding floorings"), the gross calorific potential of the external coatings, noted PCS range ext. coating, shall conform to the requirements of EN 13501-1 on external components when tested and calculated in accordance with 5.7.3.3:

- gross calorific potential of external coatings, PCS range ext. coating:
 - if external coatings are substantial components, PCS $_{range\ ext.\ coating} \le 3\ MJ/kg;$
 - if external coatings are non-substantial components, PCS range ext. coating ≤ 4 MJ/m².".

5.7.3.3 Reaction to fire – external coatings

After the dash Gross caloric potential, delete "for the coating" to read:

"For pipes and fittings where the manufacturer is claiming a reaction to fire class A2, each external coating shall be tested according to EN ISO 1716 in order to obtain its gross calorific potential value (PCS).".

In last paragraph, replace the words "the products assembled as a discharge system" and "the assembled products" with "the range" and "PCS system ext. coating" with "PCS range ext. coating" to read:

To classify the range and be representative of final use, the PCS of external coatings for the range, noted PCS _{range ext. coating}, shall be calculated. The method of calculation is detailed in Annex G.".

D.2 Initial type testing

Replace the word "conformance" with "conformity" to read:

"Samples of prototypes (pipes, fittings, accessories and joints) for each range of DN (see Table 7) shall pass all the type tests listed in Tables 9 and 10 to demonstrate conformity with Clause 4, before production commences.".

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST EN 877:2001/A1:2007/AC:2008</u> https://standards.iteh.ai/catalog/standards/sist/eb924f60-8241-483b-9b83c1d2d0f415ef/sist-en-877-2001-a1-2007-ac-2008

And in "Table D.1 — Type tests for pipes, fittings and accessories"

For the item to be tested "Reaction to fire", replace twice "system" with "range" to read: "

Reaction to fire			
– Range	1 per range	5.7.3.3/Annex H	4.1.3/4.6.3

Annex G

(informative)

Replace "the assembled products" with "the range" and replace twice "PCS system ext. coating" with "PCS range ext. coating" to read:

"Method of calculation of gross calorific potential of external coatings for the range, noted PCS _{range ext. coating}

PCS range ext. coating = $(0.8 \times PCS \text{ pipes ext. coating}) + (0.2 \times PCS \text{ fittings ext. coating})$ ".

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST (normative) 2007/AC 2008

https://standards.iteh.ai/catalog/standards/sist/eb924f60-8241-483b-9b83-

In the title, delete "system" and replace "assembled products" with "aproducts range" to read:

"Reaction to fire test (SBI adaptation for testing a products range)"

Figures H.1 and H.2, replace "system" with "range" and "discharge systems" with "ranges" to read: "

Spigots and couplings range

Spigots and sockets range

Key

- 1 vertical part axis
- 2 lower end of coupling level
- 3 bottom of socket level

Figure H.1 — Dimensions for mountings of cast iron ranges

Figure H.2 — Position of brackets on mountings of cast iron ranges".

4

Annex ZA

(informative)

Clauses of the European Standard addressing essential requirements or other provisions of EU Directives

ZA.2.1 System of attestation of conformity

Add reference to 2001/596/EC and complete the Tables ZA.2 and ZA.3a, ZA.3b, to read:

"The system(s) of attestation of conformity of cast iron pipes and fittings, their joints and accessories for the evacuation of water from buildings indicated in Table ZA.1, as given in Annex III of the mandate M/131 for pipes, tanks and ancillaries not in contact with water intended for human consumption (see also Decision details 99/472/EC; dated 1999/07/17 and 2001/596/EC dated 2001/01/08), is shown in Table ZA.2 for the indicated intended use(s) and relevant level(s) or class(es):

Table ZA.2 — System of attestation of conformity

Product(s)	Intended use(s)	Level(s) or class(es)	Attestation of conformity system(s)
Cast iron pipes and fittings, their joints and accessories for the case of the	wastewater and surface waters(including rain)01/A1:	D PREVIEW iteh.ai) 2007/AC:2008 ist/eb924f60-8241-483b-9b83	System 4
evacuation of water from buildings.	subject to reaction to fire regulations, used for the transport/disposal/storage of water not intended for human consumption.	1-a1-2007-ac-2008 A1(²),A2(²),B(²),C(²),D,E (A1 to E)(³),F	System 3 System 4

⁽¹) Products/materials for which a clearly identifiable stage in the production process results in an improvement of the reaction to fire classification (e.g. an addition of fire retardants or a limiting of organic material). **Products covered by this standard do not fall into this class.**

System 3: See CPD Annex III.2 (ii), Second possibility

System 4: See CPD Annex III.2 (ii), Third possibility

⁽²⁾ Products/materials not covered by footnote 1

⁽³) Products/materials that do not require to be tested for reaction to fire (e.g. Products/materials of Classes A1 according to Commission Decision 96/603/EC.

Table ZA.3.a — Assignment of evaluation of conformity tasks for cast iron pipes and fittings, their joints and accessories for the evacuation of water from buildings under system 3

	Tasks	Content of the task	Evaluation of conformity clauses to apply
Tasks under the responsibility of the manufacturer	Factory production control (FPC)	Parameters related to all characteristics of Table ZA.1	D.3
	Initial type testing by a notified test laboratory	Reaction to fire classes $A1(^{2}),A2(^{2}),B(^{2}),C(^{2}),D,E$ $(A2 to E)(^{3})$	4.1.3 D.2
	Initial type testing by the manufacturer	All characteristics of Table ZA.1 including declaration of Reaction to fire class A1 or class F	D.2

Table ZA.3.b — Assignment of evaluation of conformity tasks for cast iron pipes and fittings, their joints and accessories for the evacuation of water from buildings under system 4

	Tasks	standorde of the taskai)	Evaluation of conformity clauses to apply
Tasks under the responsibility of the manufacturer	(F.P.C) https://standards.id	Parameters related to all characteristics of Table ZA:1ndards/sist/eb924f60-8241-48 All characteristics of Table ZA:1_ac-2008 including declaration for reaction to fire class A:1 Reaction to fire class F	Annex D, Evaluation of Sconformity

ZA.2.2 Declaration of conformity

Add a dash for the name and address of the notified laboratory(ies), if applicable, to read:

- "... (e.g. provisions for use under certain conditions etc.);
- name and address of the notified laboratory(ies), if applicable;
- name of, and position held by, the person empowered to sign the declaration on behalf of the manufacturer or his authorised representative...".

ZA.3 CE marking and labelling

In sixth dash, add "range to which it belongs" to read: "

 description of the product: range to which it belongs, generic name, material, dimensions, intended use and place of installation;".