



SLOVENSKI STANDARD

kSIST prEN 15001-1:2009

01-marec-2009

D`]bg_]j cXj!`D`]bg_Y`bUdY`Uj Y`n`XY`cj b]a `hU`ca `bUX`\$ž `VUF`nU]bXi glf]`g_c
i dcfUVc `]b`bUX`) `VUF`nU]bXi glf]`g_c `]b`bY]bXi glf]`g_c i dcfUVc `!`%XY. `DcXfcVbY
Z b_`W]cbU`bY`nU h]j Y`nU`bU f]c]j Ub`Yža UH]f]U`Yž[fUXb`cžbUXncf`]b`dfYg_i ýUb`Y

Gas Infrastructure - Gas installation pipework with an operating pressure greater than 0,5 bar for industrial installations and greater than 5 bar for industrial and non-industrial installations - Part 1: Detailed functional requirements for design, materials, construction, inspection and testing

Gasinfrastruktur - Gas-Leitungsanlagen mit einem Betriebsdruck größer 0,5 bar für industrielle Installationen und größer 5 bar für industrielle und nicht-industrielle Installationen - Teil 1: Detaillierte funktionale Anforderungen an Planung, Material, Bau, Inspektion und Prüfung

Systèmes d'alimentation en gaz - Canalisations d'installations de gaz avec une pression de service supérieure à 0,5 bar pour les installations industrielles et supérieures à 5 bar pour les installations industrielles et non industrielles (domestiques et commerciales) - Partie 1 : Exigences fonctionnelles détaillées relative à la conception, aux matériaux, à la construction, à l'inspection et aux essais

Ta slovenski standard je istoveten z: prEN 15001-1

ICS:

91.140.40 Sistemi za oskrbo s plinom Gas supply systems

kSIST prEN 15001-1:2009

en

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

FINAL DRAFT
prEN 15001-1

January 2009

ICS

English Version

Gas Infrastructure - Gas installation pipework with an operating pressure greater than 0,5 bar for industrial installations and greater than 5 bar for industrial and non-industrial installations - Part 1: Detailed functional requirements for design, materials, construction, inspection and testing

Gasinfrastruktur - Gas-Leitungsanlagen mit einem Betriebsdruck größer 0,5 bar für industrielle Installationen und größer 5 bar für industrielle und nicht-industrielle Installationen - Teil 1: Detaillierte funktionale Anforderungen an Planung, Material, Bau, Inspektion und Prüfung

This draft European Standard is submitted to CEN members for unique acceptance procedure. It has been drawn up by the Technical Committee CEN/TC 234.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

Page

Foreword.....	4
1 Scope	5
2 Normative references	7
3 Terms and definitions	12
3.1 Definitions relating to pressure.....	12
3.2 Definitions relating to the gas installation	13
3.3 Definition relating to means of isolation	14
3.4 Definitions relating to jointing methods.....	14
3.5 Definitions relating to components	15
3.6 Definitions relating to tests	16
3.7 Definition relating to testing and inspection	16
3.8 Definitions relating to assembly processes for metallic materials	16
3.9 Definitions relating to pressure regulating and metering	17
4 General.....	17
4.1 Quality system	17
4.2 Selection of materials.....	18
4.3 Protection against hazards.....	18
4.4 Accommodation and location of gas pressure regulating and metering systems, gas pressure compressors and gas mixing systems	19
5 Materials	20
5.1 Standards and specifications for pipes and pipe fittings	20
5.2 Ancillaries.....	24
5.3 Gas pressure regulating and safety systems.....	25
6 Design of pipework.....	26
6.1 General.....	26
6.2 Layout	27
6.3 Dimensioning	28
6.4 Pressure and wall thickness.....	28
6.5 Safety engineering.....	35
6.6 Detail engineering.....	39
6.7 Hot tapping carbon steel pipe	51
7 Design of pressure control systems.....	52
7.1 General.....	52
7.2 Pressure regulating system.....	53
7.3 Instrumentation.....	53
7.4 Permanent bypasses	54
7.5 Construction requirements.....	54
7.6 Low gas temperature.....	56
7.7 Gas compressors.....	57
7.8 Safety systems.....	57
8 Construction.....	61
8.1 Identification of the installation.....	61
8.2 External hazards	62
8.3 Gas pipework passing through exterior walls.....	62
8.4 Identification of pipework	64
8.5 Specifications and requirements for joints.....	65
8.6 Joint suitability.....	69
8.7 Connections	70

8.8	Corrosion protection.....	71
8.9	Handling and installation of pipework	78
8.10	Bending of pipes	80
8.11	Welding of supports and anchor points to carbon steel pipework.....	81
8.12	Installation of pressure regulating systems	82
9	Documentation, inspection and testing	83
9.1	General	83
9.2	Documentation	84
9.3	Inspection.....	84
9.4	Testing.....	87
Annex A (informative) Example schematic diagrams of installation options for gas pressure regulating systems.....		91
Annex B (informative) Examples of methods for testing.....		93
B.1	General	93
B.2	Strength test on metallic pipework.....	93
B.3	Tightness test on metallic pipework	95
B.4	Strength and tightness test on PE pipework.....	98
Annex C (informative) Flammable gases mixing systems.....		101
C.1	Reverse flow	101
C.2	Control of mixture composition.....	101
C.3	Matching pressures of components for mixing	103
Annex D (informative) Examples of supports		104
Annex E (normative) Materials		111
E.1	General	111
E.2	Materials with a demonstrated safe history of application in this type of equipment.....	112
Annex ZA (informative) Relationship between this European Standard and the Essential Requirements of EU Directive 97/23/EC.....		115
Bibliography.....		117

Foreword

This document (prEN 15001-1:2009) has been prepared by Technical Committee CEN/TC 234 “Gas infrastructure”, the secretariat of which is held by DIN.

This document is currently submitted to the Unique Acceptance Procedure.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive 97/23/EC, see informative Annex ZA, which is an integral part of this document.

Annexes A to D are informative.

The normative Annex E of this document lists some suitable materials for pipework, in addition to the materials listed in Clause 5.

This standard includes requirements concerning current design practice and reflects the state of the art at the time of publication. It provides clear solutions for users of the standard. Other design solutions and construction materials, as well as new developments, may be used if equal or greater safety than that required by this EN can be demonstrated or established.

There is a complete suite of functional standards prepared by CEN/TC 234 “Gas infrastructure” to cover all parts of the gas supply system from the input of gas to the transmission system up to the inlet connection of the gas appliances, whether for residential, commercial or industrial purposes.

In preparing this standard, a basic understanding of gas supply by the user has been assumed.

Gas supply systems are complex and the importance on safety of their construction and use has led to the development of very detailed codes of practice and operating manuals in the member countries. These detailed statements embrace recognised standards of gas engineering and the specific requirements imposed by the legal structures of the member countries.

1 Scope

This standard specifies detailed functional requirements for the design, selection of materials, construction, inspection and testing of

- industrial gas installation pipework and assemblies with an operating pressure greater than 0,5 bar, and
- non-industrial gas installation pipework (residential and commercial) with an operating pressure greater than 5 bar in buildings,

starting from the outlet of the network operator's point of delivery up to the inlet connection to the gas appliance; normally the inlet isolation valve. This standard also covers the inlet connection to the gas appliance comprising of the pipework that does not fall within the scope of the appliance standard.

NOTE The use of the term installation and pipework is interchangeable.

This standard applies to gas installations operating at ambient temperatures between - 20 °C and 40 °C and operating pressures up to and including 60 bar. For operating conditions outside these limitations, reference should additionally be made to EN 13480 for metallic pipework.

For industrial gas installations up to and including 0,5 bar and for non-industrial (residential and commercial) gas installations up to and including 5 bar in buildings, EN 1775 applies.

For gas installations that do not fall within the scope of EN 1775 or other European Standards, this standard applies.

In this standard, the term "gas" refers to combustible gases, which are gaseous at 15 °C and 1 013 mbar absolute atmospheric pressure (normal conditions). These gases are commonly referred to as manufactured gas, natural gas or Liquefied Petroleum Gas (LPG). They are also referred to as first, second or third family gases (see Table 1 of EN 437:2003). The given values are considered as normal conditions for all volumes given in this standard.

LPG storage vessels (including all ancillaries fitted directly to storage vessels) are excluded. Also excluded are LPG installations and sections of LPG installations operating at vapour pressure in the liquid state (e.g. between the storage vessel and any pressure regulator).

In this standard, all pressures are gauge pressures unless otherwise stated.

This standard has been harmonised to address the essential safety requirements of the Pressure Equipment Directive (PED, 97/23/EC) relevant for the joining of gas installation pipework (assemblies) falling within the scope of the PED. These are listed in Annex ZA. However, "this Directive does not cover the assembly of pressure equipment on the site and under the responsibility of the user, as in the case of industrial installations" (PED, Preamble, 5th recital, last paragraph).

Although in this respect, the standard takes into account the essential safety requirements of the PED, no inference can be drawn from this as to whether or not the installation or parts of the installation falls within the scope of the PED. Reference should be made to the PED and national legislation.

This European Standard specifies common basic principles for gas supply systems. Users of this European Standard should be aware that more detailed national standards and/or code of practice may exist in the CEN member countries.

This European Standard is intended to be applied in association with these national standards and/or codes of practice setting out the above-mentioned basic principles.

prEN 15001-1:2009 (E)

In the event of conflicts in terms of more restrictive requirements in national legislation/regulation with the requirements of this standard, the national legislation/regulation shall take precedence as illustrated in CR 13737.

This provision does not apply to requirements that are harmonised to directive 97/23/EC (see Annex ZA).

This CR 13737 gives:

- clarification of all legislations/regulations applicable in a country;
- if appropriate, more restrictive national requirements thereof;
- a national contact point for the latest information.

Functional requirements for commissioning, operation and maintenance of industrial gas installations and assemblies with an operating pressure greater than 0,5 bar and of gas installations greater than 5 bar in buildings and areas intended for non-industrial installations greater than 5 bar are described in EN 15001-2.

Generally, additional safety precautions may be necessary where non-odorized gas is used. For non industrial purposes, the gas should be odorized.