



SLOVENSKI STANDARD SIST EN 161:2011

01-september-2011

Nadomešča:
SIST EN 161:2007

Samodejni zaporni ventili za plinske gorilnike in plinske aparate

Automatic shut-off valves for gas burners and gas appliances

Automatische Absperrventile für Gasbrenner und Gasgeräte

Robinets automatiques de sectionnement pour brûleurs à gaz et appareils à gaz

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Ta slovenski standard je istoveten z: **SIST EN 161:2011**

<https://standards.iteh.ai/catalog/standards/sist/191395b8-96e5-4ade-bcf6-b21829a7ee54/sist-en-161-2011>

ICS:

23.060.20	Zapirni ventili (kroglasti in pipe)	Ball and plug valves
27.060.20	Plinski gorilniki	Gas fuel burners

SIST EN 161:2011

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 161:2011

<https://standards.iteh.ai/catalog/standards/sist/191395b8-96e5-4ade-bcf6-b21829a7ce54/sist-en-161-2011>

EUROPEAN STANDARD

EN 161

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2011

ICS 23.060.40

Supersedes EN 161:2007

English Version

Automatic shut-off valves for gas burners and gas appliances

Robinets automatiques de sectionnement pour brûleurs à gaz et appareils à gaz

Automatische Absperrventile für Gasbrenner und Gasgeräte

This European Standard was approved by CEN on 20 February 2011.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

SIST EN 161:2011

<https://standards.iteh.ai/catalog/standards/sist/191395b8-96e5-4ade-bcf6-b21829a7ce54/sist-en-161-2011>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

	Page
Foreword.....	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	5
4 Classification.....	6
5 Units of measurement and test conditions	7
6 Construction requirements.....	7
7 Performance	11
8 EMC/Electrical requirements	19
9 Marking, installation and operating instructions	21
Annex A (informative) Gas connections in common use in the various countries.....	23
Annex B (informative) Leak-tightness test – volumetric method.....	24
Annex C (informative) Leak-tightness test – pressure loss method.....	25
Annex D (normative) Conversion of pressure loss into leakage rate.....	26
Annex E (normative) Electrical/electronic component fault modes	27
Annex F (normative) Additional requirements for safety accessories and pressure accessories as defined in EU Directive 97/23/EC.....	28
Annex G (normative) Materials for pressurized parts	29
Annex H (informative) Additional materials for pressurized parts.....	30
Annex I (normative) Requirements for controls used in DC supplied gas burners and gas burning appliances	31
Annex ZA (informative) Relationship between this European Standard and the Essential Requirements of EU Directive 2009/142/EC relating to appliances burning gaseous fuels	32
Bibliography	34
Tables	
Table 1 — Test pressure	12
Table 2 — Sealing force requirements	16
Table 3 — Operating cycles	18
Table 4 — Operating cycles for automatic shut-off valves for cookers according to EN 30-1-4:2002, 5.3.7.1.	18
Table ZA.1 — Correspondence between this European Standard and Directive 2009/142/EC relating to appliances burning gaseous fuels	32

Foreword

This document (EN 161:2011) has been prepared by Technical Committee CEN/TC 58 "Safety and control devices for burners and appliances burning gaseous or liquid fuels", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2011, and conflicting national standards shall be withdrawn at the latest by March 2014.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 161:2007.

This document is intended to be used in conjunction with EN 13611:2007. This document refers to clauses of EN 13611:2007 or adapts clauses by stating "with the following modification", "with the following addition", "is replaced by the following" or "is not applicable" in the corresponding clause. This European Standard adds clauses or sub-clauses to the structure of EN 13611:2007 which are particular to this European Standard i.e. sub-clauses or annexes, which are additional to those in EN 13611:2007, are numbered starting from 101 or are designated as Annex AA, BB, CC etc. It should be noted that these clauses and sub-clauses are not indicated as an addition.

It should be noted that the following significant editorial changes compared to the previous edition have been incorporated in this European Standard:

- a) alignment to EN 13611:2007; [SIST EN 161:2011](https://standards.iteh.ai/catalog/standards/sist/191395b8-96e5-4ade-bcf6-b31818770621/sist-en-161-2011)
- b) normative references: ISO 4400 and ISO 6952 are changed to EN 175301-803;
- c) terms and definitions are aligned to EN 13611:2007;
- d) sub-clause 6.101 has been moved to sub-clause 8.11.102;
- e) installation and operating instructions are integrated in one sub-clause;
- f) changes in Annex ZA regarding 1.2, 1.2.2, 1.2.3, 1.3, 3.1.1, 3.3, 3.6, 3.7, 3.8, 3.11, 3.12, 3.2.1 and in addition Annex II and III were deleted.

SIL classification according to EN 61508 cannot be claimed based upon compliance with this standard. Valves with SIL classification do not meet automatically the requirements of this standard.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

EN 161:2011 (E)**1 Scope**

This European Standard specifies the safety, construction and performance requirements for automatic shut-off valves for use with gas burners, gas appliances and similar use, hereafter referred to as 'valves'.

This European Standard is applicable to valves with declared maximum inlet pressures up to and including 500 kPa (5 bar) of nominal connection sizes up to and including DN 250 for use with one or more fuel gases in accordance with EN 437.

This European Standard is applicable to electrically operated valves and to valves actuated by fluids where the control valves for these fluids are actuated electrically, but not to any external electrical devices for switching the control signal or actuating energy.

An assessment method for valve designs is given by this European Standard.

This European Standard is also applicable to valves where the flow rate is controlled by external electrical signals, either in discrete steps or proportional to the applied signal.

This European Standard is also applicable to valves fitted with closed position indicator switches.

NOTE Provisions for final product inspection and testing by the manufacturer are not specified.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 30 (all parts), *Domestic cooking appliances burning gas*

EN 298, *Automatic gas burner control systems for gas burners and gas burning appliances with or without fans*

EN 13611:2007, *Safety and control devices for gas burners and gas burning appliances — General requirements*

EN 13906-1, *Cylindrical helical springs made from round wire and bar — Calculation and design — Part 1: Compression springs*

EN 13906-2, *Cylindrical helical springs made from round wire and bar — Calculation and design — Part 2: Extension springs*

EN 60529, *Degrees of protection provided by enclosures (IP code) (IEC 60529:1989)*

EN 60730-1:2000, *Automatic electrical controls for household and similar use — Part 1: General requirements (IEC 60730-1:1999, modified)*

EN 61058-1, *Switches for appliances — Part 1: General requirements (IEC 61058-1:2000 modified + A1:2001 (Equivalent))*

EN 175301-803, *Detail Specification: Rectangular connectors — Flat contacts, 0,8 mm thickness, locking screw not detachable*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 13611:2007 and the following apply.

3.101

automatic shut-off valve

valve which opens when energized and closes automatically when de-energized

3.102

actuating mechanism

part of the valve which moves the closure member

3.103

valve with step control

valve which controls the flow rate in steps

3.104

valve with modulating control

valve which controls the flow rate continuously between two limits in response to external electrical signals

3.105

closed position indicator switch

switch fitted to a valve which indicates when the closure member is in the closed position

3.106

actuating energy

required energy for the actuating mechanism to move the closure member to the open position

NOTE The actuating energy can have an external source (electrical, pneumatic or hydraulic) and can be transformed inside the valve.

[SIST EN 161:2011](https://standards.iteh.ai/catalog/standards/sist/191395b8-96e5-4ade-bc8b-b21829a7ce54/sist-en-161-2011)

3.107

opening force

force required to move the closure member to the open position

3.108

closing force

force available to close the valve, independent of any force provided by fuel gas pressure

3.109

sealing force

force acting on the valve seat when the closure member is in the closed position, independent of any force provided by fuel gas pressure

3.110

frictional force

largest force required to move the actuating mechanism and the closure member from the open position to the closed position with the closure spring removed, independent of any force provided by fuel gas pressure

3.111

actuating pressure

hydraulic or pneumatic pressure supplied to the actuating mechanism of the valve

3.112

opening time

time interval between energizing the valve and the attainment of the maximum or other defined flow rate

EN 161:2011 (E)**3.113****closing time**

time interval between de-energizing the valve and the closure member attaining the closed position

3.114**delay time**

time interval between energizing the valve and the start of flow

3.115**control valve**

valve which controls the fluid (e. g. compressed air) supplied to the actuating mechanism

3.116**rated voltage**

voltage declared by the manufacturer at which the valve may be operated

3.117**rated current**

current declared by the manufacturer at which the valve may be operated

3.118**balanced valve**

valve with a balanced closure member where the inlet pressure acts on the closure member in the opening and closing direction

NOTE The closure member may close more than one opening.

ITIH STANDARD PREVIEW
(standards.iteh.ai)

4 Classification

SIST EN 161:2011

4.1 Classes of control <https://standards.iteh.ai/catalog/standards/sist/191395b8-96e5-4ade-bc6b-b21829a7ce54/sist-en-161-2011>

EN 13611:2007 is replaced by the following:

— Class A, B and C valves

Valves where the sealing force is not decreased by the gas inlet pressure. They are classified A, B or C according to the sealing force requirements of 7.105. Balanced valves according to this standard are class A valves.

— Class D valves

Valves which are not subject for requirements for the sealing force and fixed closing time.

NOTE Class D valves are intended to be used for control functions only.

— Class J valves

Disc-on-seat valves where the sealing force is not decreased by the gas inlet pressure and which meet the requirements of 7.105.

4.2 Groups of control

Shall be according to EN 13611:2007, 4.2.

4.3 Classes of control functions

Shall be according to EN 13611:2007, 4.3.

5 Units of measurement and test conditions

Shall be according to EN 13611:2007, Clause 5.

6 Construction requirements

6.1 General

Shall be according to EN 13611:2007, 6.1.

6.2 Mechanical parts of the control

6.2.1 Appearance

Shall be according to EN 13611:2007, 6.2.1.

6.2.2 Holes

Shall be according to EN 13611:2007, 6.2.2.

6.2.3 Breather holes

Shall be according to EN 13611:2007, 6.2.3.

6.2.4 Test for leakage of breather holes

Shall be according to EN 13611:2007, 6.2.4.

6.2.5 Screwed fastenings

Shall be according to EN 13611:2007, 6.2.5.

6.2.6 Jointing

Shall be according to EN 13611:2007, 6.2.6.

6.2.7 Moving parts

Shall be according to EN 13611:2007, 6.2.7.

6.2.8 Sealing caps

Shall be according to EN 13611:2007, 6.2.8.

6.2.9 Dismantling and reassembly

Shall be according to EN 13611:2007, 6.2.9.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 161:2011

Shall be according to EN 13611:2007, 6.2.3.
<https://standards.iteh.ai/catalog/standards/sist/191395b8-96e5-4ade-bcf6-b21829a7ce54/sist-en-161-2011>

EN 161:2011 (E)**6.2.101 Design**

There shall be no exposed shafts or operating levers which could adversely affect the ability of valves to close.

6.2.102 Closed position indicator switch

Closed position indicator switches, where fitted, shall not impair the correct operation of valves. Adjusters shall be sealed to indicate interference. Any drift of the switch and actuating mechanism from its setting shall not impair correct valve operation.

6.2.103 Valve with modulating control

Flow rates of valves with modulating control shall be adjustable over the full range declared by the manufacturer. If the adjustment of one flow rate affects the setting of any other flow rate, this shall be clearly indicated in the manufacturer's instructions for setting up. The setting of any flow rate shall require the use of mechanical or electrical tools and shall be designed to discourage unauthorized adjustment.

NOTE For air-gas ratio controls see EN 12067-1 and -2.

6.2.104 Controls assembled to a valve

Other controls assembled to a valve shall not interfere with its shut-off function.

6.2.105 Balanced valves

The closure member of a balanced valve shall have a resulting force in the closing direction where the sealing force is not decreased by the gas inlet pressure.

6.2.106 Closing and sealing

<https://standards.iteh.ai/catalog/standards/sist/191395b8-96e5-4ade-bcf6-b21829a7ce54/sist-en-161-2011>

6.2.106.1 Closing and/or sealing by means of springs

If springs are used for closing and/or sealing the valve, they shall be designed according to EN 13906-1 or EN 13906-2 for static and dynamic loading.

6.2.106.2 Other means for closing and/or sealing**6.2.106.2.1 General**

This clause defines a method for the assessment of other means for closing and sealing in automatic shut-off valves.

By this clause the term "class of control function A, B or C" is **not** related to the sealing force classes but to the class of control function as described in 4.3.

Sealing force of valves shall be classified according to 4.1.

The basic risks of fire and explosion in a gas appliance as a result of uncontrolled gas flow requires a control function class C system for the gas shut-off function. This is based on a comparison, made between automatic burner controller and gas shut-off function, the class of control function of each of them being considered equal.

Although this European Standard is not based on a fault assessment approach as specified in EN 13611:2007, 6.6, the combination of two automatic shut-off valves is considered equal to a control function class C. This assumption is based on the construction and performance requirements of this European Standard.

6.2.106.2.2 New designs for closing and/or sealing

New designs for closing and/or sealing shall fulfil at least the requirements of a control function class B. In all cases the gas shut-off function shall be a control function class C.

NOTE For further information see EN 14459.

During the testing, the valve shall fulfil the performance requirements of Clause 7.

New designs may consist of a combination of closure members, electronic controller, sensing elements, actuators, lockout and reset.

The manufacturer shall declare the other means for closing and/or sealing.

For the assessment of the new design the requirements of this European Standard shall be used in combination with EN 13611:2007, 6.6. If this leads to aspects that are not described in this European Standard, the manufacturer shall supply a failure mode analysis on the new design.

This analysis shall describe the specific failure modes for the type of technology used in relation to the following basic safety requirements:

- a) closing function at power interruption;
- b) leak tightness;
- c) sealing force (ability to withstand backpressure, to be checked by testing or calculation);
- d) closing force > friction force; (standards.iteh.ai)
- e) closing time including the influence to the Burner Control (EN 298);
- f) no uncontrolled opening of the automatic shut-off valve.

As a result of this failure mode analysis, additional constructional requirements shall be fulfilled and/or additional faults compared to EN 13611:2007, Annex E shall be included into the fault assessment.

The outcome of the analysis shall provide a set of conditions under which the new design can be used in an automatic shut-off valve. These conditions involve construction requirements, safety requirements, performance requirements and test methods.

The fault reaction time shall be declared by the manufacturer.

Failure of mechanical parts adversely affecting the performance requirements of this European Standard is considered as an abnormal situation and can therefore be considered as a first fault according to the test method in EN 13611:2007, 6.6.

However, if mechanical parts are designed according to the constructional requirements of Clause 6 of this European Standard, failure of these parts is not considered.

6.3 Materials

6.3.1 General material requirements

Shall be according to EN 13611:2007, 6.3.1.

6.3.2 Housing

Shall be according to EN 13611:2007, 6.3.2.

EN 161:2011 (E)**6.3.3 Test for leakage of housing after removal of non-metallic parts**

Shall be according to EN 13611:2007, 6.3.3.

6.3.4 Zinc alloys

Shall be according to EN 13611:2007, 6.3.4.

6.3.5 Springs providing closing and/or sealing force

Shall be according to EN 13611:2007, 6.3.5.

6.3.6 Resistance to corrosion and surface protection

Shall be according to EN 13611:2007, 6.3.6.

6.3.7 Impregnation

Shall be according to EN 13611:2007, 6.3.7.

6.3.8 Seals for glands for moving parts

Shall be according to EN 13611:2007, 6.3.8.

6.3.101 Closure members

Closure members of valves above DN 25 shall either have a mechanical support (e. g. metallic) to withstand the sealing force or shall be made of metal.

This requirement also applies to:

- all valves with a maximum inlet pressure above 15 kPa (150 mbar);
- parts transmitting the closing force.

The strength of the connection between closure members of a balanced valve shall be at least five multiplied by the maximum inlet pressure multiplied by the total opening area of the closure members.

6.4 Gas connections**6.4.1 Making connections**

Shall be according to EN 13611:2007, 6.4.1.

6.4.2 Connection sizes

Shall be according to EN 13611:2007, 6.4.2.

6.4.3 Threads

Shall be according to EN 13611:2007, 6.4.3.

6.4.4 Union joints

Shall be according to EN 13611:2007, 6.4.4.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 161:2011](https://standards.iteh.ai/catalog/standards/sist/191395b8-96e5-4ade-bcf6-b21829a7ce54/sist-en-161-2011)

<https://standards.iteh.ai/catalog/standards/sist/191395b8-96e5-4ade-bcf6-b21829a7ce54/sist-en-161-2011>