

## SLOVENSKI STANDARD SIST EN 13752:2009

01-maj-2009

Nadomešča:

**SIST EN 13752:2003** 

#### Izdelki, ki se uporabljajo za pripravo pitne vode - Manganov dioksid

Products used for treatment of water intended for human consumption - Manganese dioxide

Produkte zur Aufbereitung von Wasser für den menschlichen Gebrauch - Mangandioxid i Teh STANDARD PREVIEW

Produits utilisés pour le traitement de l'éau destinée à la consommation humaine -Dioxyde de manganèse

SIST EN 13752:2009

https://standards.iteh.ai/catalog/standards/sist/eaf6bc3b-a50f-4994-98ff-

Ta slovenski standard je istoveten z 862d9/EN:13752:2009

#### ICS:

13.060.20 Pitna voda Drinking water

71.100.80 Kemikalije za čiščenje vode Chemicals for purification of

water

SIST EN 13752:2009 en,fr,de

**SIST EN 13752:2009** 

# iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 13752:2009

https://standards.iteh.ai/catalog/standards/sist/eaf6bc3b-a50f-4994-98ff-9180ea6862d9/sist-en-13752-2009

**EUROPEAN STANDARD** 

EN 13752

NORME EUROPÉENNE

**EUROPÄISCHE NORM** 

March 2009

ICS 71.100.80

Supersedes EN 13752:2003

#### **English Version**

## Products used for treatment of water intended for human consumption - Manganese dioxide

Produits utilisés pour le traitement de l'eau destinée à la consommation humaine - Dioxyde de manganèse

Produkte zur Aufbereitung von Wasser für den menschlichen Gebrauch - Mangandioxid

This European Standard was approved by CEN on 1 February 2009.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

SIST EN 13752:2009

https://standards.iteh.ai/catalog/standards/sist/eaf6bc3b-a50f-4994-98ff-9180ea6862d9/sist-en-13752-2009



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

### **Contents**

Forew	vord	3
1	Scope	5
2	Normative references	5
3	Terms, definitions and symbols	
4 4.1 4.2	DescriptionIdentification	5
5 5.1 5.2 5.3	Physical propertiesAppearanceParticle size distribution	6
6	Chemical properties	7
7	Specific properties	7
8 8.1 8.2	Test methods	7 7
9 9.1 9.2 9.3 9.4 9.5	Analysis	9 10 10
	x A (informative) General information on manganese dioxide	
Annex B (normative) General rules relating for safety		
Bibliography		

#### **Foreword**

This document (EN 13752:2009) has been prepared by Technical Committee CEN/TC 164 "Water supply", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2009, and conflicting national standards shall be withdrawn at the latest by September 2009.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 13752:2003.

Differences between this edition and EN 13752:2003 are editorial to harmonize the text with other standards in this series.

Annex A is informative and Annex B is normative.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, No way, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

<u>SIST EN 13752:2009</u> https://standards.iteh.ai/catalog/standards/sist/eaf6bc3b-a50f-4994-98ff-9180ea6862d9/sist-en-13752-2009

#### Introduction

In respect of potential adverse effects on the quality of water intended for human consumption, caused by the product covered by this standard:

- a) this standard provides no information as to whether the product may be used without restriction in any of the Member States of the EU or EFTA;
- b) it should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or the characteristics of this product remain in force.

NOTE Conformity with this standard does not confer or imply acceptance or approval of the product in any of the Member States of the EU or EFTA. The use of the product covered by this European Standard is subject to regulation or control by National Authorities.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST EN 13752:2009</u> https://standards.iteh.ai/catalog/standards/sist/eaf6bc3b-a50f-4994-98ff-9180ea6862d9/sist-en-13752-2009

#### Scope

This European Standard is applicable to manganese dioxide used for treatment of water intended for human consumption. It describes the characteristics of manganese dioxide and specifies the requirements and the corresponding test methods for manganese dioxide. It gives information on its use in water treatment.

This standard is not applicable to manganese dioxide with purity ranging from 85 % to 90 % and bulk density loose greater than 1850 kg/m<sup>3</sup>.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12901:1999, Products used for treatment of water intended for human consumption - Inorganic supporting and filtering materials - Definitions

EN 12902, Products used for treatment of water intended for human consumption - Inorganic supporting and filtering materials - Methods of test

EN ISO 3696, Water for analytical laboratory use - Specification and test methods (ISO 3696:1987)

ISO 385, Laboratory glassware - Burettes

standards.iteh.ai)

ISO 6333, Water quality - Determination of manganese - Formaldoxime spectrometric method

SIST EN 13752:2009

https://standards.iteh.ai/catalog/standards/sist/eaf6bc3b-a50f-4994-98ff-

Terms, definitions and symbols ea6862d9/sist-en-13752-2009 3

For the purposes of this document, the terms, definitions and symbols given in EN 12901:1999 apply.

#### **Description**

#### Identification

#### 4.1.1 Chemical name

Manganese dioxide.

#### 4.1.2 Synonym or common names

Manganese(IV) oxide, pyrolusite.

#### 4.1.3 Chemical formula

 $MnO_2$ .

Manganese dioxide used as a catalytic filtering medium is a natural ore, usually pyrolusite. Manganese dioxide ores differ widely in their chemical composition depending on their origin. Most are composed of manganese dioxide together with silica, alumina, iron oxide and numerous other elements present in varying proportions.

#### 4.1.4 CAS Registry number 1)

Manganese dioxide: 1313-13-9.

#### 4.1.5 EINECS reference 2)

Manganese oxides: 215-202-6.

#### 4.2 Commercial form

Manganese dioxide is a granular material usually available in two size ranges: 0,355 mm to 0,850 mm and 0,50 mm to 1,00 mm.

#### 5 Physical properties

#### 5.1 Appearance

The product is a granular material varying in colour from dark brown to dark grey to black, depending upon its origin. It consists of amorphous grains which can be rounded or sub-angular.

The product shall be generally homogeneous and shall be visibly free of extraneous matter.

### 5.2 Particle size distribution eh STANDARD PREVIEW

The particle size distribution shall be described by either ds. iteh.ai

a) SIST EN 13752:2009

- effective size: https://standards.iteb.ai/catalog/standards/sist/eaf6bc3b-a50f-4994-98ff- $(a_{10})$  with a maximum deviation of  $\pm$  5%;

— uniformity coefficient: (U) less than 1,5;

— minimum size:  $(d_1)$  with a limit deviation of  $\pm$  5 %;

NOTE 1 The particle size can decrease during transportation and handling.

or, particle size range and mass fraction of oversize and undersize particles according to application.

The maximum contents of oversize and undersize shall be a mass fraction of 5 % for application of the product in multimedia filters and a mass fraction of 10 % for use in single media filters. See A.2.3 for examples of available particle sizes that are used.

NOTE 2 Other values can be necessary for certain applications.

#### 5.3 Density

#### 5.3.1 Bulk density loose

The bulk density loose shall be in the range of 1 750 kg/m<sup>3</sup> to 1 850 kg/m<sup>3</sup>.

<sup>1)</sup> Chemical Abstracts Service Registry Number.

<sup>&</sup>lt;sup>2</sup>) European Inventory of Existing Commercial Chemical Substances.

#### 5.3.2 Bulk density packed

The bulk density packed shall be in the range of 1 950 kg/m<sup>3</sup> to 2 050 kg/m<sup>3</sup>.

#### 6 Chemical properties

For the composition of the commercial product, see A.2.1.

- NOTE 1 After filling, washing and commissioning of a filter system producing drinking water, manganese dioxide should not increase the concentrations of chemical parameters above the regulated values (see [1]).
- NOTE 2 Water extractable substances, determined in accordance with the method for granular materials given in EN 12902, can be used to estimate the leaching of the chemicals specified in EN 12902.
- NOTE 3 Users of this product should check the national regulations in order to clarify whether it is of appropriate purity for treatment of water intended for human consumption, taking into account raw water quality, contents of other impurities and additives used in the products not stated in the product standard.

#### 7 Specific properties

The oxidation capacity of manganese dioxide shall be at least 500 bed volumes when tested according to the method described in 8.2.4.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

## 8 Test methods

Sampling

#### SIST EN 13752:2009

Prepare the laboratory sample(s) required by the relevant procedure described in EN 12902.

#### 8.2 Analysis

#### 8.2.1 Particle size distribution

The particle size distribution shall be determined on samples taken at the point of manufacture using the method of test given in EN 12902.

#### 8.2.2 Bulk density loose

The bulk density loose shall be determined in accordance with EN 12902.

#### 8.2.3 Bulk density packed

The bulk density packed shall be determined in accordance with EN 12902.

#### 8.2.4 Oxidation capacity

#### 8.2.4.1 Principle

A solution of manganese sulphate is passed through a bed of "regenerated" manganese dioxide. Portions of the effluent are analysed for manganese and the cumulative volume, until breakthrough of manganese, is determined.