

---

---

**Road vehicles — Compressed natural gas  
(CNG) fuel system components —**

**Part 14:  
Excess flow valve**

*Véhicules routiers — Composants des systèmes de combustible gaz  
naturel comprimé (GNC) —  
Partie 14: Valve de limitation de débit*

[ISO 15500-14:2002](https://standards.iteh.ai/catalog/standards/sist/6e10603f-9b1c-4b95-8670-c35b244e4e8a/iso-15500-14-2002)

[https://standards.iteh.ai/catalog/standards/sist/6e10603f-9b1c-4b95-8670-  
c35b244e4e8a/iso-15500-14-2002](https://standards.iteh.ai/catalog/standards/sist/6e10603f-9b1c-4b95-8670-c35b244e4e8a/iso-15500-14-2002)



**PDF disclaimer**

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[ISO 15500-14:2002](https://standards.iteh.ai/catalog/standards/sist/6e10603f-9b1c-4b95-8670-c35b244e4e8a/iso-15500-14-2002)

<https://standards.iteh.ai/catalog/standards/sist/6e10603f-9b1c-4b95-8670-c35b244e4e8a/iso-15500-14-2002>

© ISO 2002

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.ch](mailto:copyright@iso.ch)  
Web [www.iso.ch](http://www.iso.ch)

Printed in Switzerland

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 3.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this part of ISO 15500 may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

International Standard ISO 15500-14 was prepared by Technical Committee ISO/TC 22, *Road vehicles*, Subcommittee SC 25, *Road vehicles using natural gas*.

ISO 15500 consists of the following parts, under the general title *Road vehicles — Compressed natural gas (CNG) fuel system components*:

- Part 1: *General requirements and definitions*
- Part 2: *Performance and general test methods*
- Part 3: *Check valve*
- Part 4: *Manual valve*
- Part 5: *Manual cylinder valve*
- Part 6: *Automatic valve*
- Part 7: *Gas injector*
- Part 8: *Pressure indicator*
- Part 9: *Pressure regulator*
- Part 10: *Gas-flow adjuster*
- Part 11: *Gas/air mixer*
- Part 12: *Pressure relief valve (PRV)*
- Part 13: *Pressure relief device (PRD)*
- Part 14: *Excess flow valve*
- Part 15: *Gas-tight housing and ventilation hose*
- Part 16: *Rigid fuel line*
- Part 17: *Flexible fuel line*
- Part 18: *Filter*
- Part 19: *Fittings*

iTeH STANDARD PREVIEW  
(standards.iteh.ai)  
ISO 15500-14:2002  
<https://standards.iteh.ai/catalog/standards/sist/6e10603f-9b1c-4b95-8670-c35b244e4e8a/iso-15500-14-2002>

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

ISO 15500-14:2002

<https://standards.iteh.ai/catalog/standards/sist/6e10603f-9b1c-4b95-8670-c35b244e4e8a/iso-15500-14-2002>

# Road vehicles — Compressed natural gas (CNG) fuel system components —

## Part 14:

### Excess flow valve

#### 1 Scope

This part of ISO 15500 specifies tests and requirements for the excess flow valve, a compressed natural gas fuel system component intended for use on the types of motor vehicles defined in ISO 3833.

This part of ISO 15500 is applicable to vehicles using natural gas in accordance with ISO 15403 (mono-fuel, bi-fuel or dual-fuel applications). It is not applicable to the following:

- a) liquefied natural gas (LNG) fuel system components located upstream of, and including, the vaporizer;
- b) fuel containers;
- c) stationary gas engines;
- d) container mounting hardware;
- e) electronic fuel management;
- f) refuelling receptacles.

iTeh STANDARD PREVIEW  
(standards.iteh.ai)

ISO 15500-14:2002

<https://standards.iteh.ai/catalog/standards/sist/6e10603f-9b1c-4b95-8670-c35b244e4e8a/iso-15500-14-2002>

NOTE 1 It is recognized that miscellaneous components not specifically covered herein can be examined to meet the criteria of this part of ISO 15500 and tested according to the appropriate functional tests.

NOTE 2 All references to pressure in this part of ISO 15500 are to be considered gauge pressures unless otherwise specified.

NOTE 3 This part of ISO 15500 is based upon a service pressure for natural gas as fuel of 20 MPa [200 bar] settled at 15 °C. Other service pressures can be accommodated by adjusting the pressure by the appropriate factor (ratio). For example, a 25 MPa (250 bar) service pressure system will require pressures to be multiplied by 1,25.

NOTE 4 1 bar = 0,1 MPa = 10<sup>5</sup> Pa; 1 MPa = 1 N/mm<sup>2</sup>.

#### 2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of ISO 15500. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this part of ISO 15500 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of ISO and IEC maintain registers of currently valid International Standards.

ISO 3833:1977, *Road vehicles — Types — Terms and definitions*

ISO 15403, *Natural gas — Designation of the quality of natural gas for use as a compressed fuel for vehicles*

ISO 15500-1, *Road vehicles — Compressed natural gas (CNG) fuel system components — Part 1: General requirements and definitions*

ISO 15500-2, *Road vehicles — Compressed natural gas (CNG) fuel system components — Part 2: Performance and general test methods*

### 3 Terms and definitions

For the purposes of this part of ISO 15500, the terms and definitions given in ISO 15500-1 and the following apply.

#### 3.1

##### **internal excess flow valve**

excess flow valve installed inside the cylinder or cylinder valve

#### 3.2

##### **external excess flow valve**

excess flow valve installed outside the cylinder or cylinder valve

#### 3.3

##### **shut-off type excess flow valve**

excess flow valve that stops flow when in the closed position

#### 3.4

##### **flow-limiter type excess flow valve**

excess flow valve that limits flow when activated

NOTE The device resets automatically when the excess flow condition is no longer present.

#### 3.5

##### **activation**

differential pressure flow or other condition specified by the manufacturer at which the excess flow valve is activated

STANDARD PREVIEW  
(standards.iteh.ai)  
<https://standards.iteh.ai/catalog/standards/sist/6e10603f-9b1c-4b95-8670-c35b244e4e8a/iso-15500-14-2002>

### 4 Marking

Marking of the component shall provide sufficient information to allow the following to be traced:

- a) the manufacturer's or agent's name, trademark or symbol;
- b) the model designation (part number);
- c) the service pressure or pressure and temperature range.

The following additional markings are recommended:

- d) the direction of flow (when necessary for correct installation);
- e) the type of fuel;
- f) electrical ratings (if applicable);
- g) the symbol of the certification agency;
- h) the type approval number;
- i) the serial number or data code;
- j) reference to this part of ISO 15500.

NOTE This information can be provided by a suitable identification code on at least one part of the component when it consists of more than one part.

## 5 Construction and assembly

The excess flow valve shall comply with the applicable provisions of ISO 15500-1 and ISO 15500-2, and with the tests specified in clause 6 of this part of ISO 15500.

## 6 Tests

### 6.1 Applicability

There are many types of excess flow valves available. This part of ISO 15500 provides requirements for two different designs: internal and external excess flow valves. A valve of either design could be one of two different types: shut-off or flow-limiter. As excess flow valve designs vary, so will the tests required.

The function of an excess flow valve can be achieved in other ways. For example, instead of using a mechanical device, an electronic system can be adopted to ensure the closing or limiting of the gas flow from the cylinder in an accident.

The tests required to be carried out are indicated in Table 1.

**Table 1 — Tests applicable**

| Test method                      | Applicable | Test procedure as required in ISO 15500-2 | Specific test requirements of this part of ISO 15500 |
|----------------------------------|------------|---|--|
| Hydrostatic strength             | X          | X   | X (see 6.2)  |
| Leakage                          | X          | X   | X (see 6.3)  |
| Excess torque resistance         | X          | X   | X (see 6.4)  |
| Bending moment                   | X          | X   | X (see 6.5)  |
| Continued operation              | X          | X   | X (see 6.6)  |
| Corrosion resistance             | X          | X   |  |
| Oxygen ageing                    | X          | X   |  |
| Non-metallic synthetic immersion | X          | X   |  |
| Vibration resistance             | X          | X   |  |
| Brass material compatibility     | X          | X   |  |
| Operation                        | X          |   | X (see 6.7)  |

### 6.2 Hydrostatic strength

The purpose of this test is to establish the strength of the housing.

Test the excess flow valve according to the procedure for testing hydrostatic strength specified in ISO 15500-2. For an internal excess flow valve, the test pressure shall be 80 MPa [800 bar]; for an external excess flow valve, the test pressure shall be 100 MPa [1 000 bar].

### 6.3 Leakage

The internal leakage test shall be conducted on shut-off type excess flow valves.

Test the excess flow valve at the temperatures and pressures given in Table 2.

Table 2 — Test temperatures and pressures

| Temperature<br>°C | First test pressure<br>MPa [bar] | Second test pressure<br>MPa [bar] |
|-------------------|----------------------------------|-----------------------------------|
| –40               | 15 [150]                         | Operational pressure              |
| 20                | Operational pressure             | 30 [300]                          |
| 85                | Operational pressure             |                                   |

#### 6.4 Excess torque resistance

The excess torque resistance test shall be conducted only on external excess flow valves.

See ISO 15500-2.

#### 6.5 Bending moment

The bending moment test shall be conducted only on external excess flow valves.

See ISO 15500-2.

#### 6.6 Continued operation

Cycle the excess flow valve 20 times at 20 MPa [200 bar] differential pressure. One cycle shall consist of one opening and one closing. Upon completion of the test, the valve shall comply with 6.3 and 6.7.

#### 6.7 Operation

Measure the flow of the excess flow valve when it activates. Perform the test using the activation conditions stated by the manufacturer; the measured flow shall meet the manufacturer's specified flow.



**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

ISO 15500-14:2002

<https://standards.iteh.ai/catalog/standards/sist/6e10603f-9b1c-4b95-8670-c35b244e4e8a/iso-15500-14-2002>