

SLOVENSKI STANDARD SIST HD 621 S1:1998

01-februar-1998

Medium voltage impregnated paper insulated distribution cables

Medium voltage impregnated paper insulated distribution cables

Energieverteilungskabel mit getränkter Papierisolierung für Mittelspannung

Câbles de distribution moyenne tension isolés au papier imprégné

Ta slovenski standard je istoveten z: HD 621 S1:1996

SIST HD 621 S1:1998

https://standards.iteh.ai/catalog/standards/sist/447d1f21-1c0b-4b7e-af82-27379c324ec6/sist-hd-621-s1-1998

ICS:

29.035.10 Papirni in kartonski izolacijski Paper and board insulating

materials materials

29.060.20 Kabli Cables

SIST HD 621 S1:1998 en

SIST HD 621 S1:1998

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST HD 621 S1:1998

https://standards.iteh.ai/catalog/standards/sist/447d1f21-1c0b-4b7e-af82-27379c324ec6/sist-hd-621-s1-1998

SIST HD 621 S1:1998

HARMONIZATION DOCUMENT DOCUMENT D'HARMONISATION **HARMONISIERUNGSDOKUMENT**

HD 621 S1

October 1996

ICS 29.040.20; 29.060.20

Descriptors: Electric cable, insulated cable, composition, dimension, construction characteristics, mechanical characteristics, test,

marking, impregnated paper

English version

Medium voltage impregnated paper insulated distribution cables

Câbles de distribution moyenne tension isolés au papier imprégné

Energieverteilungskabel mit getränkter Papierisolierung für Mittelspannung

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST HD 621 S1:1998

https://standards.iteh.ai/catalog/standards/sist/447d1f21-1c0b-4b7e-af82-27379c324ec6/sist-hd-621-s1-1998

This Harmonization Document was approved by CENELEC on 1996-03-05. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document on a national level.

Up-to-date lists and bibliographical references concerning such national implementation may be obtained on application to the Central Secretariat or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Page 0-2 HD 621 S1:1996

FOREWORD

This Harmonisation Document was prepared by WG9 of CENELEC Technical Committee TC20, Electric Cables. It was agreed by TC20 at its Helsinki meeting (May 1994) to be submitted for formal vote by National Committees.

The document contains the following Parts, arranged according to the main constructional features of the cables covered:

Part 1 -General requirements

Part 2 -Additional test methods

Part 3 -Impregnated paper insulated cables-single core, also pre-assembled

Part 4 -Impregnated paper insulated cables - three core

Each of Parts 3 and 4 are further divided into particular sections and, by decision of the Technical Board (D68/047) National Committees need at present only implement in their national language those sections having national applicability. The obligation remains however to announce the full HD in public by titles and numbers, and also to withdraw any conflicting national standards.

Page numbering reflects the arrangement into Parts and particular sections, e.g. Page 4-C-3 is page 3 of particular section C of Part 4.

References to other HDs, ENs and international standards are given in the particular parts or sections.

The draft was submitted to the CENELEC members for formal vote in August 1995 and was approved by CENELEC as HD 621 S1 pn 1996-03-05.NDARD PREVIEW

(dow)

1997-03-01

(standards.iteh.ai) The following dates were fixed:

-	latest date by which the existence of the HD S1:1998. has to be announced at national level g standards/sist/447d1f21.	-1c0b (dba) -af82-	1996-09-01
-	27379c324ec6/sist-hd-621-s1-1998 latest date by which the HD has to be implemented at national level by publication of a harmonised national standard or by endorsement	(dop)	1997-03-01
-	latest date by which the national standards conflicting with the HD have to be withdrawn	(dow)	1997-03-01

Page 0-3 HD 621 S1:1996

CONTENTS

PART	1	General requirements
PART	2	Additional test methods
PART	3	Impregnated paper insulated cable-single core, also pre-assembled
	3-A 3-B 3-C 3-E 3-F 3-G 3-I 3-J-1	Single core draining or non-draining paper insulated cable - unarmoured; with or without thermoplastic sheath (Type 3A) Single core cables with paper insulation, non-draining Impregnated paper insulated cables - single core cables Single core cables 12/20kV and 18/30kV Single core cables, also pre-assembled Cables with paper insulation - draining - unarmoured - PVC or PE sheathed - single core Cables with PE sheath Single core and SL type paper insulated cables with lead sheath (up to and including 12,7/22kV) Single core and SL type paper insulated cables with lead sheath (19/33kV)
PART	4 4-A 4-B	Impregnated paper insulated cables - three core Multicore draining or non-draining paper insulated cable - belted or screened cores - one or three metallic sheaths - armoured or unarmoured - thermoplastic sheath or not. Multicore cables with paper insulation, non draining TVTRW
	4-C 4-D 4-E 4-F	Impregnated paper insulated cable - belted H and SL type cables. Belted multicore cables with polypropylene yarn serving, or PVC or polyethylene sheath Armoured three-core cables with lead sheaths 12/20kV and 18/30kV and three-core cables 12/15kV non-radial field Multicore cables (Belted cables: three screened cores one lead sheath; three metallic sheathed cores - one outer covering) sixt-hd-621-s1-1998
	4-G-1 4-G-2 4-H-1	Impregnated paper insulated cable - three core draining paper insulated cable - screened cores, one metallic sheath - armoured or unarmoured serving, PE or PVC sheath Impregnated paper insulated cable - three core draining paper insulated cable - belted, one metallic sheath - armoured or unarmoured serving, PE or PVC sheath Three-core belted and screened cables, with lead sheath and steel tape armour
	4-H-2 4-I	Three-core SL steel armoured cables Cables with one lead sheath (Type 4I-1) and with three lead sheaths (Type 4I-2) and with sheaths of PE
	4-J-1 4-J-2 4-J-3 4-K	Three core cables with lead sheath (19/33kV) Three core cables with lead sheath, up to and including 12,7/22kV Three core cables with aluminium sheath Armoured three core cables with lead sheaths and a rated voltage 23/40kV

Page 0-4 HD 621 S1:1996

iTeh STANDARD PREVIEW

(standards.iteh.ai)

"BLANK PAGE"

https://standards.iteh.ai/catalog/standards/sist/447d1f21-1c0b-4b7e-af82-27379c324ec6/sist-hd-621-s1-1998

SIST HD 621 S1:1998

Page 1-1 HD 621 S1:1996 Part 1

HD 621 S1:1996

MEDIUM VOLTAGE IMPREGNATED PAPER INSULATED DISTRIBUTION CABLES

PART 1 - GENERAL REQUIREMENTS

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST HD 621 S1:1998

https://standards.iteh.ai/catalog/standards/sist/447d1f21-1c0b-4b7e-af82-27379c324ec6/sist-hd-621-s1-1998

Page 1-2 HD 621 S1:1996 Part 1

CONTENTS

			Page	
1.	General			
	1.1 Scope 1.2 Object		4	
	1.2 Object		4	
2.	Definitions			
		elating to insulating and	4	
	sheathing made 2.2 Definitions re	elating to the tests		
	2.3 Rated voltag	e	4 5	
3.	Marking			
	3.1 Indication of	origin	<u>.</u>	
	3.2 Additional m		5	
		Ceh STANDARD PREVIEW	6	
	3.4 Legibility	eli STANDARD FREVIEW	6	
	3.5 Common ma	rking (standards.iteh.ai)	6	
		ame CENELEC	6 6	
4.			6	
5.	Construction of cables 27379c324ec6/sist-hd-621-s1-1998			
	5.1 Conductors			
	5.2 Insulation		6 7	
	5.3 Screening of	cores	7	
	5.4 Assembly of		7	
	5.5 Fillers and bir		7	
	5.6 Metallic shea			
	5.7 Inner coverin		8 8 8	
	5.8 Inner sheath	•	8	
	5.9 Armouring (if		9	
	5.10 Serving (if an	•	9	
	5.11 Outer sheath	(if any)	9	
6.	Completed cables		10	
7.	Sealing and packing		10	
8.	Current carrying capacity		10	
9.	Guide to use and selection of cables			
Tables			10	
			11	

Page 1-3 HD 621 S1:1996 Part 1

REFERENCES

Part 1 of HD 621 incorporates by dated or undated reference, provisions from other publications. These references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to Part 1 of HD 621 only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies.

EN 60811	Common test methods for insulating and sheathing materials of electric cables
HD 383	Conductors of insulated cables (Endorsing IEC 228 and 228A)
HD 405	Tests on electric cables under fire conditions
HD 605	Electric cables: Additional test methods
IEC 55-1	Paper-insulated metal-sheathed cables for rated voltages up to 18/30kV (with copper or aluminium conductors and excluding gas-pressure and oil-filled cables). Part 1: Tests.
IEC 229	Tests on cable oversheaths which have a special protective function and are applied by extrusion
IEC 287	Calculation of the continuous current rating of cables (100% load factor)

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST HD 621 S1:1998</u> https://standards.iteh.ai/catalog/standards/sist/447d1f21-1c0b-4b7e-af82-27379c324ec6/sist-hd-621-s1-1998 Page 1-4 HD 621 S1:1996 Part 1

1. General

1.1 Scope

HD 621 applies to impregnated paper insulated cables for rated voltages Uo/U(Um) from 3,6/6(7,2)kV up to 20,8/36(42)kV used in power distribution systems.

This part (Part 1) specifies the general requirements applicable to these cables, unless otherwise specified in the particular sections of this HD.

Test methods specified are given in HD 605, EN 60811, HD 383 and HD 405 and in IEC 55-1 and IEC 229.

Part 2 covers all those test methods which are specific to paper insulated cables, and not included in HD 605.

The particular types of cables are specified in Parts 3 and 4.

1.2 Object

The objects of this Harmonisation Document are:

- to standardise cables that are safe and reliable when properly used, in relation to the technical requirements of the system of which they form a part;
- to state the characteristics and manufacturing requirements which have a direct or indirect bearing on safety;

SIST HD 621 S1:1998
hand/tonspecify/methods/for/checking/conformity/With/those requirements.
27379c324ec6/sist-hd-621-s1-1998

2. Definitions

2.1 Definitions relating to insulating and sheathing materials

The insulation covered by this HD is paper, made from tapes, impregnated with suitable draining or non-draining compound. A suitable metallic sheath (lead or aluminium) is applied over the individual cores (single or separately lead sheathed cores) or over the assembly of the insulated cores (3-core belted or screened cables). The cable may be protected by an armouring and relevant serving and/or an outer sheath.

2.2 Definitions relating to the tests

Note: Tests classified as sample (S) or routine (R) maybe required as part of any type approval schemes.

2.2.1 Type tests (Symbol T)

Tests required to be made before supplying a type of cable covered by this HD on a general commercial basis in order to demonstrate satisfactory performance characteristics to meet the intended application. These tests are of such a nature that, after they have been made, they need not be repeated unless changes are made in the cable material, design or type of manufacturing process which might change the performance characteristics.

Page 1-5 HD 621 S1:1996 Part 1

2.2.2 Sample tests (Symbol S)

Tests made on samples of completed cable, or components taken from a completed cable adequate to verify that the finished product meets the design specifications.

2.2.3 Routine tests (Symbol R)

Tests made on all production cable lengths to demonstrate their integrity.

2.2.4 Tests after installation

Installation tests are made to demonstrate the integrity of the cable and its accessories as installed.

2.3 Rated voltage

The rated voltage of a cable is the reference voltage for which the cable is designed, and which serves to define the electrical tests.

The rated voltage is expressed by the combination of the following values Uo/U (Um) expressed in kV.

Uo is the rms value between any insulated conductor and earth (metal covering of the cable).

(standards.iteh.ai)

U is the rms value between any two phase-conductors of a multicore cable or of a system of single core cable.

SIST HD 621 S1:1998

https://standards.iteh.ai/catalog/standards/sist/447d1f21-1c0b-4b7e-af82-

Um is the maximum rms value of the highest system voltage for which the equipment may be used.

The standard rated voltages Uo/U (Um) of the cables in this HD are as follows:

```
Uo/U (Um) = 3,6/6 (7,2) - 3,8/6,6 (7,2) - 6/10 (12) - 6,6/11 (12) - 7/12 (14,5) - 8,7/15 (17,5) - 12/20 (24) - 12,7/22 (24) - 15/20 (24) - 15/26 (30,5) - 18/30 (36) - 19/33(36) - 20,8/36 (42) - kV rms
```

In an alternating current system, the rated voltage of a cable shall be at least equal to the nominal voltage of the system for which it is intended. If used in DC systems, the maximum voltage has to be specified in the particular sections.

3. Marking

3.1 Indication of origin

Cables shall be provided with an identification of origin consisting of the marking of the manufacturer's name or trademark, or (if legally protected) identified number by one of the three following alternative methods:

- (a) printed tape within the cable;
- (b) printing on the insulation of at least one core;
- (c) printing, indenting or embossing on the sheath.

Page 1-6 HD 621 S1:1996 Part 1

3.1.1 Continuity of marks

The distance between the end of one complete set of marks and the beginning of the next is specified in the particular sections.

3.2 Additional marking

Additional marking requirements may be specified in the particular sections.

3.3 Durability

Printed markings shall be durable.

3.4 Legibility

All markings shall be legible. Printed markings shall be in contrasting colours.

3.5 Common marking

Under consideration.

3.6 Use of the name CENELECYDARD PREVIEW

The name CENELEC in full or abbreviated, shall not be directly marked on, or in, the cables.

4. Core identification

SIST HD 621 S1:1998

If required, the cores shall be identified by numbers, or by other schemes detailed in the particular sections of this HD.

5. Construction of cables

Compliance with the requirements specified in sub-clauses 5.1 to 5.11 and in the particular sections of this HD shall be checked by inspection and by measurement according to the test methods listed in the particular sections.

5.1 Conductors

5.1.1 Material

Conductors shall be either plain annealed copper or plain aluminium in accordance with HD 383 and with the requirements specified in the particular sections of this HD.

Conductors shall be stranded either circular or shaped, or (for aluminium only) solid.

Page 1-7 HD 621 S1:1996 Part 1

5.1.2 Electrical resistance

The resistance of each conductor shall be in accordance with the requirements in HD 383 for the given class of conductor.

5.2 Insulation

5.2.1 Material

Insulation shall be made of paper tapes, helically applied around the conductor and impregnated with suitable draining or non draining compound.

Test requirements for the insulation are specified in the particular sections.

5.2.2 Thickness

Insulation thickness values for the core and the belt insulation are specified in the particular sections for each cable type, size and voltage.

The mean value of the insulation thickness shall be not less than the nominal value specified in the particular sections of this HD.

The minimum measured value shall not be less than the minimum value specified in the particular sections of this HD. PREVIEW

Compliance shall be checked by the test method given in part 2.

5.2.3 Additional characteristics, if any \$11998

https://standards.iteh.ai/catalog/standards/sist/447d1f21-1c0b-4b7e-af82-These are specified in the particular sections.

5.2.4 Belted cables

In a belted cable a further thickness of insulating paper shall be applied around the assembled unscreened cores.

5.3 Screening of cores

Screening of cores, when required, shall consist of an insulation screening with or without a conductor screening, as specified in the particular sections of this HD. The screening shall consist of a semi-conducting and/or a metallised paper tape, as given in the particular sections of this HD.

5.4 Assembly of cores

In multicore cables, the cores shall be laid up helically or with another suitable method.

5.5 Fillers and binder tape

For each type of cable, the particular sections detail whether that cable includes fillers or not.

A centre filler may be used in multicore cables, and the assembly of cores and fillers may be held together by a binder tape.

Page 1-8 HD 621 S1:1996 Part 1

5.5.1 Materials

The fillers and binder tapes, if any, shall be composed of a suitable material. When fillers or binder tapes are applied, there shall be no harmful interactions between their constituents and the insulation and/or the sheath.

5.5.2 Application

Fillers in multicore cables shall be laid up together with the cores to form a round and compact cable.

5.6 Metallic sheath

The metallic sheath shall be applied as a common sheath over the laid up cores including the belt insulation (if any) or separately over individual cores.

It is commonly made of lead, lead alloy or aluminium; requirements are given in the particular sections.

5.7 Inner covering (bedding)

The inner covering may be extruded or lapped (e.g. bitumen impregnated paper tapes) over the metallic sheaths.

5.7.1 Material STANDARD PREVIEW

The material used for inner coverings shall be compatible with the cable components with which it is in contact, and shall be selected by reference to the maximum conductor temperature of the cable in normal operation.

https://standards.iteh.ai/catalog/standards/sist/447d1f21-1c0b-4b7e-af82-

5.7.2 Thickness 27379c324ec6/sist-hd-621-s1-1998

Unless otherwise specified for the particular type, the thickness of lapped beddings need not be checked by measurement.

The thickness of extruded inner covering for each type of cable shall be specified in the particular sections.

Compliance shall be checked by the test specified in the particular sections.

5.8 Inner sheath (if any)

An inner sheath may be specified in the particular sections.

5.8.1 Material

The material used for the extruded inner sheath shall be compatible with the cable components with which it is in contact, and shall be selected by reference to the maximum conductor temperature of the cable in normal operation.

The test requirements are specified in tables 4A and 4B unless stated otherwise in the particular sections.

5.8.2 Application

The inner sheath shall be extruded in a single layer as specified in the particular sections.

Page 1-9 HD 621 S1:1996 Part 1

5.8.3 Thickness

The thickness of the extruded inner sheath shall be as detailed in the particular sections.

5.9 Armouring (if any)

The following types of armourings may be applied as specified in particular sections:

- (a) steel round wire or flat wire armouring;
- (b) steel tape armouring;
- (c) non magnetic armouring.

Detailed constructions of armourings are given in the particular sections.

5.10 Serving (if any)

Over the armouring a suitable serving made of fibrous material is applied; requirements for the applications as well as for the materials are given in the particular sections.

5.11 Outer sheath (if any)

5.11.1 Material

The outer sheath shall be applied as specified in the particular sections and shall be of an extruded synthetic material suitable for the maximum conductor temperature in normal operation and of the type detailed in the particular sections.

The test requirements for these compounds are specified in Tables 4A and 4B unless stated otherwise in the particular sections.

5.11.2 Thickness

5.11.2.1 Sheath applied over a smooth surface

For a sheath applied on a smooth cylindrical surface, such as a metallic sheath, unless otherwise specified, the mean value of the thickness of the outer sheath shall be not less than the specified value for each type and size of cable in the particular sections.

However, the thickness at any place may be less than the specified value provided that the difference does not exceed $0.1 \, \text{mm} + 15\%$ of the specified value.

Compliance shall be checked by the test methods given in HD 605, sub-clause 2.1.2.

5.11.2.2 Sheath applied over an uneven surface

For a sheath applied on an irregular cylindrical surface, such as a corrugated metallic sheath or a sheath applied directly over an armour, unless otherwise specified the minimum thickness measured at any point of the outer sheath shall not fall below the specified value given in the particular sections by more than $0.2 \, \text{mm} + 20\%$ of the specified value.

Compliance shall be checked by the test methods given in HD 605.