

INTERNATIONAL STANDARD

IEC 60364-5-54

Second edition
2002-06

BASIC SAFETY PUBLICATION

Electrical installations of buildings –

Part 5-54:

Selection and erection of electrical equipment – Earthing arrangements, protective conductors and protective bonding conductors

(<https://standards.iteh.ai>)
Document Preview

[IEC 60364-5-54:2002](https://standards.iteh.ai/standards/iec/60364-5-54:2002)

<https://standards.iteh.ai/standards/iec/60364-5-54:2002>

*This **English-language** version is derived from the original **bilingual** publication by leaving out all French-language pages. Missing page numbers correspond to the French-language pages.*



Reference number
IEC 60364-5-54:2002(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (www.iec.ch/searchpub) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (www.iec.ch/online_news/justpub) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch

Tel: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

IEC 60364-5-54

Second edition
2002-06

BASIC SAFETY PUBLICATION

Electrical installations of buildings –

Part 5-54:

Selection and erection of electrical equipment – Earthing arrangements, protective conductors and protective bonding conductors

(<https://standards.iteh.ai>)
Document Preview

<https://standards.iteh.ai/standards/iec/60364-5-54:2002>

<https://standards.iteh.ai/standards/iec/60364-5-54:2002>

© IEC 2002 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

S

For price, see current catalogue

CONTENTS

| | |
|--|----|
| FOREWORD..... | 5 |
| INTRODUCTION..... | 9 |
| 541 General..... | 11 |
| 541.1 Scope | 11 |
| 541.2 Normative references | 11 |
| 541.3 Definitions..... | 13 |
| 542 Earthing arrangements..... | 15 |
| 542.1 General requirements..... | 15 |
| 542.2 Earth electrodes..... | 15 |
| 542.3 Earthing conductors | 19 |
| 542.4 Main earthing terminal..... | 21 |
| 543 Protective conductors..... | 21 |
| 543.1 Minimum cross-sectional areas..... | 21 |
| 543.2 Types of protective conductors | 25 |
| 543.3 Electrical continuity of protective conductors..... | 27 |
| 543.4 PEN conductors | 27 |
| 543.6 Arrangement of protective conductors..... | 29 |
| 543.7 Reinforced protective conductors for protective conductor currents exceeding 10 mA..... | 29 |
| 544 Protective bonding conductors (equipotential bonding conductors)..... | 29 |
| 544.1 Protective bonding conductors for the connection to the main earthing terminal..... | 29 |
| 544.2 Protective bonding conductors for supplementary bonding | 29 |
| Annex A (normative) Method for deriving the factor k in 543.1.2 (see also IEC 60724 and IEC 60949)..... | 31 |
| Annex B (informative) Illustration of earthing arrangements, protective conductors and protective bonding conductors..... | 37 |
| Bibliography..... | 41 |
| Table 54.1 – Minimum size requirements for earth electrodes of commonly used material from the point of view of corrosion and mechanical strength where embedded in the soil for commonly used material..... | 17 |
| Table 54.2 – Minimum cross-sectional areas of earthing conductors buried in the soil..... | 19 |
| Table 54.3 – Minimum cross-sectional area of protective conductors | 23 |
| Table A.54.1 – Value of the parameters for different materials..... | 31 |
| Table A.54.2 – Values of k for insulated protective conductors not incorporated in cables, and not bunched with other cables | 33 |
| Table A.54.3 – Values of k for bare protective conductors in contact with cable covering but not bunched with other cables | 33 |
| Table A.54.4 – Values of k for protective conductors as a core incorporated in a cable, or bunched with other cables or insulated conductors | 33 |
| Table A.54.5 – Values of k for protective conductors as a metallic layer of a cable e.g. armour, metallic sheath, concentric conductor, etc..... | 35 |
| Table A.54.6 – Value of k for bare conductors where there is no risk of damage to any neighbouring material by the temperature indicated..... | 35 |

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL INSTALLATIONS OF BUILDINGS –**Part 5-54: Selection and erection of electrical equipment –
Earthing arrangements, protective conductors
and protective bonding conductors**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60364-5-54 has been prepared by IEC technical committee 64, Electrical installations and protection against electric shock.

This second edition replaces the first edition, published in 1980, its amendment 1 (1982), as well as some clauses of IEC 60364-5-548, published in 1996, and its amendment (1998), and constitutes a technical revision.

The text of this standard is based on the following documents:

| FDIS | Report on voting |
|--------------|------------------|
| 64/1231/FDIS | 64/1249/RVD |

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

It has the status of a basic safety publication in accordance with IEC Guide 104.

This publication has been drafted, as close as possible, in accordance with the ISO/IEC Directives, Part 3.

Annex A forms an integral part of this standard.

Annex B is for information only.

The committee has decided that the contents of this publication will remain unchanged until 2007. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

Withdrawing

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60364-5-54:2002](https://standards.iteh.ai/standards/iec/60364-5-54:2002)

<https://standards.iteh.ai/standards/iec/60364-5-54:2002>

INTRODUCTION

Clause numbering is sequential, preceded by the number of this part (e.g. 541). Numbering of figures and tables takes the number of this part followed by a sequential number, i.e. Table 54.1, 54.2, etc. Numbering of figures and tables in annexes takes the letter of the annex, followed by the number of the part, followed by a sequential number, e.g. A.54.1, A.54.2, etc.

Withhold

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

<https://standards.iteh.ai/standards/iec/fac/62b8-dbfd-4b7c-91e5-0d3388832475/iec-60364-5-54-2002>

ELECTRICAL INSTALLATIONS OF BUILDINGS –

Part 5-54: Selection and erection of electrical equipment – Earthing arrangements, protective conductors and protective bonding conductors

541 General

541.1 Scope

This part of IEC 60364 addresses the earthing arrangements, protective conductors and protective bonding conductors in order to satisfy the safety of the electrical installation.

541.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(195), *International Electrotechnical Vocabulary (IEV) – Part 195: Earthing and protection against electric shock*

IEC 60287-1-1, *Electric cables – Calculation of the current rating – Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General*

IEC 60364-4-41, *Electrical installations of buildings – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-4-43, *Electrical installations of buildings – Part 4-43: Protection for safety – Protection against overcurrent*

IEC 60364-4-44, *Electrical installations of buildings – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*

IEC 60364-5-52, *Electrical installations of buildings – Part 5-52: Selection and erection of electrical equipment – Wiring systems*

IEC 60724, *Short-circuit temperature limits of electric cables with rated voltages of 1 kV ($U_m = 1,2$ kV) and 3 kV ($U_m = 3,6$ kV)*

IEC 60853-2, *Calculation of the cyclic and emergency current rating of cables – Part 2: Cyclic rating of cables greater than 18/30 (36) kV and emergency ratings for cables of all voltages*

IEC 60909-0, *Short-circuit currents in three-phase a.c. systems – Part 0: Calculation of currents*

IEC 60949, *Calculation of thermally permissible short-circuit currents, taking into account non-adiabatic heating effects*

IEC 61024-1, *Protection of structures against lightning – Part 1: General principles*

IEC 61140, *Protection against electric shock – Common aspects for installation and equipment*

IEC Guide 104, *The preparation of safety publications and the use of basic safety publications and group safety publications*

541.3 Definitions

For the purposes of this part of IEC 60364, the definitions of IEC 61140, together with the following definitions taken from IEC 60050(195), apply.

Definitions used for earthing arrangements, protective conductors and protective bonding conductors are illustrated in annex B and listed here as follows:

541.3.1

exposed-conductive-part

conductive part of equipment which can be touched and which is not normally live, but which can become live when basic insulation fails

[IEV 195-06-10]

541.3.2

main earthing terminal

(main earthing busbar)

terminal or busbar which is part of the earthing arrangement of an installation enabling the electric connection of a number of conductors for earthing purposes

[IEV 195-02-33]

541.3.3

earth electrode

conductive part, which may be embedded in a specific conductive medium, e.g. concrete or coke, in electric contact with the earth

[IEV 195-02-01]

541.3.4

protective conductor

conductor provided for purposes of safety, for example protection against electric shock

[IEV 195-02-09]

541.3.5

protective bonding conductor

protective conductor provided for protective-equipotential-bonding

[IEV 195-02-10]

541.3.6 earthing conductor

conductor which provides a conductive path, or part of the conductive path, between a given point in a system or in an installation or in equipment and an earth electrode

[IEV 195-02-03]

NOTE For the purposes of this part of IEC 60364, an earthing conductor is the conductor which connects the earth electrode to a point in the equipotential bonding system, usually the main earthing terminal.

541.3.7 extraneous-conductive-part

conductive part not forming part of the electrical installation and liable to introduce an electric potential, generally the electric potential of a local earth

[IEV 195-06-11]

542 Earthing arrangements

542.1 General requirements

542.1.1 The earthing arrangements may be used jointly or separately for protective and functional purposes according to the requirements of the electrical installation. The requirements for protective purposes shall always take precedence.

542.1.2 Where provided, earth electrodes within an installation shall be connected to the main earthing terminal using an earthing conductor.

542.1.3 Consideration shall be given to the earthing arrangements which are used in high-voltage and low-voltage systems (see IEC 60364-4-44, clause 442).

542.1.4 The requirements for earthing arrangements are intended to provide a connection to earth:

- which is reliable and suitable for the protective requirements of the installation;
- which can carry earth fault currents and protective conductor currents to earth without danger from thermal, thermo-mechanical and electromechanical stresses and from electric shock arising from these currents;
- which, if relevant, is also suitable for functional requirements.

542.2 Earth electrodes

542.2.1 Materials and dimensions of the earth electrodes shall be selected to withstand corrosion and to have adequate mechanical strength.

For commonly used materials, the common minimum sizes from the point of view of corrosion and mechanical strength for earth electrodes where embedded in the soil are given in table 54.1.

NOTE If a lightning protection system (LPS) is present, the IEC 61024-1 applies.