SLOVENSKI STANDARD
SIST EN ISO 29462:2013

01-september-2013

Terensko preskušanje splošnih prezračevalnih filtrirnih naprav in sistemov na kraju samem (kraju vgradnje) glede učinkovitosti odstranjevanja delcev po njihovi velikosti in glede upornosti proti zračnemu toku (ISO 29462:2013)

Field testing of general ventilation filtration devices and systems for in situ removal efficiency by particle size and resistance to airflow (ISO 29462:2013)

Betriebserprobung von Filtereinrichtungen und -systemen für die allgemeine Lüftung hinsichtlich ihrer Abscheideeffizienz im eingebautem Zustand bezogen auf die Partikelgröße und den Druckverlust (ISO 29462:2013)

Essais in-situ de filtres et systèmes de ventilation générale pour la mesure de l'efficacité en fonction de la taille des particules et de la perte de charge (ISO 29462:2013)

Ta slovenski standard je istoveten z: EN ISO 29462:2013

ICS:

13.040.20	Kakovost okoljskega zraka	Ambient atmospheres
23.120	Zračniki. Vetrniki. Klimatske naprave	Ventilators. Fans. Air-conditioners
91.140.30	Prezračevalni in klimatski sistemi	Ventilation and air-conditioning

SIST EN ISO 29462:2013 en,fr

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN ISO 29462

March 2013

ICS 91.140.30

English Version

Field testing of general ventilation filtration devices and systems for in situ removal efficiency by particle size and resistance to airflow (ISO 29462:2013)

Essais in situ de filtres et systèmes de ventilation générale pour la mesure de l'efficacité en fonction de la taille des particules et de la perte de charge (ISO 29462:2013)

Betriebserprobung von Filtereinrichtungen und -systemen für die allgemeine Lüftung hinsichtlich ihrer Abscheideeffizienz im eingebautem Zustand bezogen auf die Partikelgröße und den Druckverlust (ISO 29462:2013)

This European Standard was approved by CEN on 1 March 2013.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Ref. No. EN ISO 29462:2013: E

Contents

Page

Foreword

This document (EN ISO 29462:2013) has been prepared by Technical Committee ISO/TC 142 "Cleaning equipment for air and other gases" in collaboration with Technical Committee CEN/TC 195 “Air filters for general air cleaning” the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2013, and conflicting national standards shall be withdrawn at the latest by September 2013.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Endorsement notice

The text of ISO 29462:2013 has been approved by CEN as EN ISO 29462:2013 without any modification.

INTERNATIONAL STANDARD

ISO 29462

First edition
2013-03-15

Field testing of general ventilation filtration devices and systems for in situ removal efficiency by particle size and resistance to airflow

Essais in situ de filtres et systèmes de ventilation générale pour la mesure de l'efficacité en fonction de la taille des particules et de la perte de charge

Reference number
ISO 29462:2013(E)

COPYRIGHT PROTECTED DOCUMENT

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 29462 was prepared by Technical Committee ISO/TC 142, *Cleaning equipment for air and other gases*.

Introduction

The purpose of this International Standard is to provide a test procedure for evaluating the in-situ performances of general ventilation filtration devices and systems. Although any filter with a filtration efficiency at or above 99% or at or below 30% when measured at 0,4 µm could theoretically be tested using this International Standard, it may be difficult to achieve statically acceptable results for these type of filtration devices.

Supply air to the Heating, Ventilation and Air-Conditioning (HVAC) system contains viable and non-viable particles of a broad size range. Over time these particles will cause problems for fans, heat exchangers and other system parts, decreasing their function and increasing energy consumption and maintenance. For health issues, the fine particles (<2,5 µm) are the most detrimental.

Particles in the 0,3 µm to 5,0 µm size range are typically measured by particle counters that can determine the concentration of particles in specific size ranges. These instruments are commercially available and will determine particle size along with the concentration level by several techniques (e.g., light scattering, electrical mobility separation, or aerodynamic drag). Devices based on light scattering are currently the most convenient and commonly used instruments for this type of measurement and are therefore the type of device used within this International Standard.

Particles in the size range 1,0 µm to 5,0 µm are present in low numbers (less than 1%, by count) in outdoor and supply air and have higher sampling-system losses. Results in the range >1,0 µm will therefore have lower accuracy and so the results should be interpreted with respect to this.

During in-situ measurement conditions, the optical properties of the particles may differ from the optical properties of the particles used for calibrating the particle counter and testing it in the laboratory. Thus the particle counter could size the particles differently but count the overall number of particles correctly.

By adding an extra reference filter, the effect of varying measuring conditions can be reduced. Additionally, using this enhanced test method, the results can be used to correct the measured efficiencies in relation to the efficiency of the reference filter measured in laboratory using a standardized test aerosol.

The results from using the standard method or the enhanced method will give both users and manufacturers a better knowledge of actual filter and installation properties.

It is important to note that field measurements generally result in larger uncertainties in the results compared to laboratory measurements. Field measurements may produce uncertainty from temporal and spatial variability in particle concentrations, from limitations on sampling locations due to air handling unit configurations, and from the use of field instrumentation. These factors may result in lower accuracy and precision in the calculated fractional efficiencies compared to laboratory measurements. This International Standard is intended to provide a practical method in which the accuracy and precision of the result are maximized (and the precision of the result quantified) by recommending appropriate sampling locations, sample quantities, and instrumentation. This International Standard is not intended to serve as a filter performance rating method. The results obtained from the test method described in this International Standard do not replace those obtained through tests conducted in the laboratory.

Field testing of general ventilation filtration devices and systems for in situ removal efficiency by particle size and resistance to airflow

1 Scope

This International Standard describes a procedure for measuring the performance of general ventilation air cleaning devices in their end use installed configuration. The performance measurements include removal efficiency by particle size and the resistance to airflow. The procedures for test include the definition and reporting of the system airflow.

The procedure describes a method of counting ambient air particles of 0,3 µm to 5,0 µm upstream and downstream of the in-place air cleaner(s) in a functioning air handling system. The procedure describes the reduction of particle counter data to calculate removal efficiency by particle size.

Since filter installations vary dramatically in design and shape, a protocol for evaluating the suitability of a site for filter evaluation and for system evaluation is included. When the evaluated site conditions meet the minimum criteria established for system evaluation, the performance evaluation of the system can also be performed according to this procedure.

This International Standard also describes performance specifications for the testing equipment and defines procedures for calculating and reporting the results. This International Standard is not intended for measuring performance of portable or movable room air cleaners or for evaluation of filter installations with and expected filtration efficiency at or above 99 % or at or below 30 % when measured at 0,4 µm.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 7726, *Ergonomics of the thermal environment — Instruments for measuring physical quantities*

ISO 14644-3, *Cleanrooms and associated controlled environments — Part 3: Test methods*

ISO 21501-4, *Determination of particle size distribution — Single particle light interaction methods — Part 4: Light scattering airborne particle counter for clean spaces*

3 Terms, definitions, and abbreviations

3.1 Terms and definitions

For the purpose of this document, the following terms and definitions apply.

3.1.1
air filter bypass
unfiltered air that has passed through the AHU filter installation but remained unfiltered because it bypassed the installed air filters

3.1.2
air velocity
rate of air movement at the filter

Note 1 to entry: It is expressed in m/s (fpm) to three significant figures.

3.1.3
allowable measurable concentration of the particle counter
fifty percent of the maximum measurable concentration as stated by the manufacturer of the particle counter

3.1.4
coefficient of variation
CV
standard deviation of a group of measurements divided by the mean

3.1.5
diluter
dilution system
system for reducing the sampled concentration to avoid coincidence error in the particle counter

3.1.6
filter efficiency
removal efficiency of a filter as determined by this International Standard, where upstream and downstream particle count measurements are taken close to the filter being tested

3.1.7
filter installation
filtration devices and systems such as a single filter or a group of filters mounted together with the same inlet and outlet of air

3.1.8
general ventilation
process of moving air from outside the space, recirculated air, or a combination of these into or about a space or removing it from the space

3.1.9
isoaxial sampling
sampling in which the flow in the sampler inlet is moving in the same direction as the flow being sampled

3.1.10
isokinetic sampling
technique for air sampling such that the probe inlet air velocity is the same as the velocity of the air surrounding the sampling point

[Source: ISO 29464:2011; 3.1.144]

3.1.11
particle counter
device for detecting and counting numbers of discrete airborne particles present in a sample of air

[Source: ISO 29464:2011; 3.1.27]

3.1.12
particle size range
defined particle counter channel

3.1.13
reference filter
small dry media-type filter that has been laboratory tested for removal efficiency by particle size

3.1.14
removal efficiency by particle size
ratio of the number of particles retained by the filter to the number of particles measured upstream of the filter for a given particle-size range

3.1.15
resistance to airflow
loss of static pressure caused by the filter and filter loading which is measured with the filter operating at the measured air velocity

Note 1 to entry: It is expressed in Pa (in WG) to two significant figures.

3.1.16
system efficiency
removal efficiency of a filter system where upstream and downstream particle count measurements may be across several filter banks or other system components

3.2 Abbreviations

AHU Air Handling Unit

CV Coefficient of Variation

HEPA High Efficiency Particle Air (as per ISO 29463-1)

HVAC Heating, Ventilating and Air-Conditioning

MERV Minimum Efficiency Reporting Value

OPC Optical Particle Counter

RH Relative Humidity

ULPA Ultra Low Penetration Air

VAV Variable Air Volume

VFD Variable Frequency Drive

4 Test equipment and setup

4.1 Particle counter

The particle counter should be capable of measuring particles in the size range 0,3 µm — 5,0 µm, in a minimum of four ranges with a minimum of two ranges below 1,0 µm (for example: 0,3 µm — 0,5 µm, 0,5 µm — 1,0 µm, 1,0 µm — 2,0 µm and 2,0 µm — 5,0 µm). For maintenance and calibration of the particle counter, see 4.9

4.2 Diluter

A dilution system capable of diluting the aerosol concentration so the particle concentration level is within the acceptable concentration limit may be used. Choose a suitable dilution ratio so that the measured concentration of particles is well within the allowable measurable concentration limits of the particle counter so as to achieve good statistical data (see 9.1.2). If a dilution system is used, it is to be used for both upstream and downstream sampling. The dilution system shall not change air flow to the particle counter.