

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 16144:2012

<https://standards.iteh.ai/catalog/standards/sist/fe60ac03-caeb-4f26-8272-cb2ba94450f4/sist-en-16144-2012>

EUROPEAN STANDARD

EN 16144

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2012

ICS 75.160.20

English Version

Liquid petroleum products - Determination of ignition delay and derived cetane number (DCN) of middle distillate fuels - Fixed range injection period, constant volume combustion chamber method

Produits pétroliers liquides - Détermination du délai d'inflammation et de l'indice de cétane dérivé (ICD) des distillats moyens - Méthode avec période d'injection fixe et chambre de combustion à volume constant

Flüssige Mineralölzeugnisse - Bestimmung des Zündverzugs und der abgeleiteten Cetanzahl (ACZ) von Mitteldestillatkraftstoffen - Verfahren mit festen Einspritzzeiten in einer Verbrennungskammer konstanten Volumens

This European Standard was approved by CEN on 28 January 2012.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Principle.....	6
5 Reagents and materials	6
6 Apparatus	7
7 Sampling.....	9
8 Apparatus assembly and installation	9
9 Preparation of apparatus	9
9.1 System start-up and warm-up	9
9.2 Standard operating conditions.....	10
9.3 Standard test conditions.....	10
10 Calibration, verification and quality control	11
10.1 General.....	11
10.2 Calibration	11
10.3 Apparatus verification	11
10.4 Quality control (QC).....	12
11 Test procedure	12
12 Calculation.....	13
13 Expression of results	13
14 Precision.....	14
14.1 General.....	14
14.2 Repeatability.....	14
14.3 Reproducibility.....	15
15 Test report	15
Annex A (normative) Combustion analyzer description.....	16
Annex B (normative) Operational details in support to the standard test procedure	18
Bibliography	21

Foreword

This document (EN 16144:2012) has been prepared by Technical Committee CEN/TC 19 "Gaseous and liquid fuels, lubricants and related products of petroleum, synthetic and biological origin", the secretariat of which is held by NEN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2012, and conflicting national standards shall be withdrawn at the latest by September 2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 16144:2012](#)

<https://standards.iteh.ai/catalog/standards/sist/fe60ae03-caeb-4f26-8272-cb2ba94450f4/sist-en-16144-2012>

Introduction

This document is derived from joint standardization work in the Energy Institute and ASTM International. It is based on IP 567/09 [1] published by the Energy Institute and technically equivalent with ASTM D7170 [2].

The described method is an alternative quantitative determination of the cetane number of middle distillate fuels intended for use in compression ignition engines. Correlation studies between this method and EN ISO 5165:1998 [3] have been done and the results of this are incorporated in this European Standard.

The basis of this method is the derived cetane number correlation equation as given in Clause 12. The ongoing validation of the equation is monitored and evaluated through the existing monthly American and European fuel exchange programs. The validation data will be reviewed by CEN/TC 19 with a frequency of at least every two years. As a result of the review, CEN/TC 19 may make the decision to, if necessary, modify the existing equation/correlation or develop a new one. As part of this review, the sample types will be examined, and if certain types are underrepresented, further steps may be taken to evaluate how they perform.

For the moment the basics of one type of apparatus are described. Once more correlation data on different types of derived cetane number testing equipment is available, CEN/TC 19 will consider revising this European Standard.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 16144:2012](https://standards.iteh.ai/catalog/standards/sist/fe60ae03-caeb-4f26-8272-cb2ba94450f4/sist-en-16144-2012)

<https://standards.iteh.ai/catalog/standards/sist/fe60ae03-caeb-4f26-8272-cb2ba94450f4/sist-en-16144-2012>

1 Scope

This European Standard specifies a test method for the quantitative determination of ignition delay of middle distillate fuels intended for use in compression ignition engines. The method utilizes a constant volume combustion chamber designed for operation by compression ignition, and employing direct injection of fuel into compressed air that is controlled to a specified pressure and temperature. An equation is given to calculate the derived cetane number (DCN) from the ignition delay measurement.

This method is applicable to diesel fuels, including those containing FAME. The method is also applicable to middle distillate fuels of non-petroleum origin, although users applying this standard are warned that the relationship between ignition characteristics and engine performance in unconventional fuels is not yet fully understood. The standard covers the ignition delay range from 2,9 ms to 5,0 ms (60 DCN to 35 DCN).

NOTE For the purpose of this European Standard, the expression "% (V/V)" is used to represent the volume fraction (φ), and "% (m/m)" the mass fraction (ω).

WARNING — The use of this standard may involve hazardous materials, operations and equipment. This standard does not purport to address all of the safety problems associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 3170, *Petroleum liquids — Manual sampling (ISO 3170)*

<https://standards.iteh.ai/catalog/standards/sist/fe60ae03-caeb-4f26-8272->

EN ISO 3171, *Petroleum liquids — Automatic pipeline sampling (ISO 3171)*

EN ISO 3696, *Water for analytical laboratory use — Specification and test methods (ISO 3696)*

ISO 1998-2, *Petroleum industry — Terminology — Part 2: Properties and tests*

ISO 4010, *Diesel engines — Calibrating nozzle, delay pintle type*

DIN 73372, *Fuel injection nozzles, size T and U*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 1998-2 and the following apply.

3.1

cetane number

CN

measure of the ignition performance of a fuel in a standardized engine test on a scale defined by reference fuels

Note 1 to entry: It is expressed as the percentage by volume of hexadecane (cetane) in a reference blend having the same ignition delay as the fuel for analysis. The higher the cetane number, the shorter the ignition delay.

Note 2 to entry: ISO 1998-2 expresses it as "number on a conventional scale, indicating the ignition quality of a diesel fuel under standardized conditions", but for this document the definition as given is chosen.

EN 16144:2012 (E)**3.2****ignition delay****ID**

period of time, in milliseconds, between the start of fuel injection and the start of combustion

Note 1 to entry: In the context of this standard, this period is determined by movement and pressure sensors in the instrument.

3.3**derived cetane number****DCN**

calculated value using an equation that correlates a combustion analyser ignition delay result to the cetane number

3.4**accepted reference value****ARV**

value agreed upon as a reference for comparison

Note 1 to entry: The value is derived as (1) a theoretical or established value, based in scientific principles, (2) an assigned value, based on experimental work of some national or international organization, or (3) a consensus value, based on collaborative experimental work under the auspices of a scientific or engineering group.

3.5**quality control sample**

stable and homogenous material(s) similar in nature to the materials under test, properly stored to ensure integrity, and available in sufficient quantity for repeated long-term testing

3.6**calibration reference fluid**

stable and homogenous fluid used to calibrate the performance of the combustion analyzer

<https://standards.iteh.ai/catalog/standards/sist/fe60ae03-caeb-4f26-8272-cb2ba94450f4/sist-en-16144-2012>

3.7**verification reference fluid**

stable and homogenous fluid used to verify the performance of the combustion analyzer

4 Principle

A test portion of the material under test is injected into a heated temperature-controlled constant volume combustion chamber which has previously been charged with compressed air. Sensors detect the start of injection and the start of combustion for each single-shot cycle. A complete test sequence consists of two preliminary combustion cycles to ensure apparatus equilibrium and 25 subsequent test cycles to obtain ignition delay values. The average ignition delay (ID) of these 25 cycles is inserted into an equation to obtain the derived cetane number (DCN). The DCN obtained by this procedure is an estimate of the cetane number (CN) obtained from the conventional large-scale engine test EN ISO 5165 [3].

5 Reagents and materials

5.1 Water, unless otherwise specified, meeting the requirements of grade 3 of EN ISO 3696.

5.2 Coolant system fluid, 50:50 volumetric mixture of commercial grade ethylene glycol-type radiator antifreeze with water (5.1).

NOTE This mixture meets the boiling point requirements and gives adequate protection of the coolant system against corrosion and mineral scale that can alter heat transfer and rating results. See the manufacturer's manual for the correct ethylene glycol-type antifreeze quality.

5.3 Calibration reference fluid, heptane of a purity of minimum 99,5 % (*m/m*) to be used as the designated 3,15 ms accepted ignition delay reference value material.

NOTE If the initial purity is not known and during a long-time stored reference fluid, it is advised to check the purity in accordance with IP 537 [4].

5.4 Verification reference fluid, methylcyclo-hexane of a purity of minimum 99,0 % (*m/m*) to be used as the designated 10,1 ms ignition delay accepted reference value material.

NOTE 1 If the initial purity is not known and during a long-time stored reference fluid, it is advised to check the purity in accordance with IP 537 [4].

NOTE 2 Experience has found some MCH meeting the purity specification but not meeting the Ignition Delay requirements (typically 1 ms to 1,5 ms shorter). It is recommended that new material be qualified prior to use.

5.5 Quality control sample, stable and homogenous material(s), similar in nature to the materials under test (see 3.5)

5.6 Charge air, of oxygen content 20,9 % (V/V) \pm 1,0 % (V/V), containing less than 0,5 $\mu\text{g/g}$ carbon monoxide, less than 1,0 $\mu\text{g/g}$ carbon dioxide, less than 5 $\mu\text{g/g}$ water, less than 0,1 $\mu\text{g/g}$ oxides of nitrogen, less than 0,1 $\mu\text{g/g}$ sulfur dioxide, and containing less than 0,1 $\mu\text{g/g}$ total hydrocarbons.

NOTE This grade air is typically referred to as Continuous Emissions Monitoring (CEM) grade air.

6 Apparatus

iTeh STANDARD PREVIEW

6.1. Combustion analyzer

(standards.iteh.ai)

6.1.1. General


SIST EN 16144:2012

The apparatus is described in more detail in Annex A. For the installation and set-up procedures, and for detailed system description, refer to the manufacturer's manual.

The standard system consists of a heated combustion chamber (6.1.2) with fluid cooling of designated areas, external chamber inlet and exhaust valves and associated piping, a pneumatically-driven fuel injection pump, a fuel delivery system, a recirculating coolant system, solenoids, sensors, controls and connection fittings for the compressed gas utilities. Figure 1 gives a schematic outline of the analyser.

6.1.2 Combustion chamber, a steel combustion chamber of capacity 0,60 l \pm 0,03 l. Annex A gives further details.

6.2 Filter medium, Type I, Class A filter paper (see ASTM E832 [5]) or nominal pore size 3 μm to 5 μm filter media of glass fibre, polytetrafluorethylene (PTFE) or nylon, of a size appropriate to the apparatus being used for sample filtration (see 7.5).



Key

Digital signals

- V1: actuator air valve
- V2: sample fuel reservoir valve
- V3: sample waste flush valve
- V4: charge air valve
- V5: exhaust valve
- P0: injector actuator air pressure switch gauge (manual)
- 3: injector nozzle motion sensor
- 10: control power to chamber heating

Mechanical system

- 1. pneumatic air supply
- 2. fuel sample reservoir
- 3. nozzle motion sensor
- 4. actuator
- 5. fuel pump
- 6. nozzle cooling jacket
- 7. sample waste flush valve
- 8. circulator coolant system
- 9. sample waste drain
- 10. electrical heater elements
- 11. heat shield

Analogue signals

- P1: chamber static pressure sensor
- P2: chamber dynamic pressure sensor
- T1: fuel injection pump temperature
- T2: injection nozzle cooling jacket temperature
- T3: coolant reservoir temperature (manual adjustment)
- T4: chamber inner wall temperature
- T5: chamber charge air temperature
- T6: chamber pressure sensor temperature

- 12. charge air supply
- 13. safety valve
- 14. exhaust ventilation
- 15. filter
- 16. electronic card data acquisition and control
- L1. charge air line
- L2. exhaust
- L3. fuel injector pressure line
- L4. fuel supply/flush line
- L5. pneumatic lines
- L6. coolant water

Figure 1 — Schematic overview of combustion analyser

7 Sampling

7.1 Unless otherwise specified, obtain samples in accordance with the procedures given in EN ISO 3170 or EN ISO 3171.

7.2 Collect and store samples in an opaque container to minimize exposure to UV emissions that can induce chemical reactions, which may affect ignition delay measurements. If the sample is not to be analyzed within 24 h, retain in a dark, cool/cold environment, and preferably under an inert gas.

NOTE 1 Exposure of petroleum fuels to UV wavelengths of less than 550 nm for even a short period of time has been shown to affect ignition delay [6].

NOTE 2 The formation of peroxides and radicals, which affect the ignition delay, is minimized when the sample is stored in the dark, under a nitrogen blanket and in a cold (below 10 °C) environment.

7.3 Bring the laboratory sample to 18 °C to 32 °C before testing.

7.4 Inspect the sample for wax precipitation. If precipitants are present, bring the test sample to a temperature of at least 14 °C above the expected cloud point of the material being tested, taking care not to lose any lower boiling range components. Agitate the sample to return precipitants back in to the solution, ensuring the sample is homogeneous before proceeding.

7.5 Sample may be filtered through a Type I, Class A filter at room temperature and pressure before testing (see ASTM E832 [5]), or through a nominal (3 to 5) µm porosity filter element using a syringe, to prepare a test portion of at least 220 ml. Immediately collect the filtered test portion in an opaque container.

WARNING — If a glass syringe is used to filter the sample, ensure that the filter capsule is correctly located on the syringe fitting. Do not apply excessive force to the plunger as this could result in the glass syringe shattering. It is recommended that protective gloves are worn during the filtering operation.

SIST EN 16144:2012

[https://standards.iteh.ai/catalog/standards/sist/fe60ae03-caeb-4f26-8272-](https://standards.iteh.ai/catalog/standards/sist/fe60ae03-caeb-4f26-8272-cb2ba94450f4/sist-en-16144-2012)

[cb2ba94450f4/sist-en-16144-2012](https://standards.iteh.ai/catalog/standards/sist/fe60ae03-caeb-4f26-8272-cb2ba94450f4/sist-en-16144-2012)

8 Apparatus assembly and installation

The apparatus requires placement on a level floor with facilities for the hook-up of all utilities and engineering and technical support. The user shall ensure compliance with all local and national regulations and codes. The apparatus assembly and installation are described in more detail in Annex A, respectively Annex B.

9 Preparation of apparatus

9.1 System start-up and warm-up

9.1.1 For more details refer to the manufacturer's manual.

9.1.2 Switch on power to the combustion analyzer, the external cooling bath and the computer.

9.1.3 Warm up the system.

9.1.4 Set the injection actuator air pressure (P_0) to 0,75 MPa ± 0,05 MPa.

9.1.5 Set the coolant reservoir temperature (T_3) to achieve an injector coolant passage temperature (T_2) of 30 °C ± 0,5 °C. T_2 is recorded by the computer. A temperature outside the range given during a 25 combustion cycle measurement indicates a possible malfunctioning of the cooling system.