



SLOVENSKI STANDARD

SIST ISO 4064-2:2002

01-junij-2002

Merjenje pretoka vode v zaprtih vodih - Merila za hladno vodo - 2. del: Zahteve za vgradnjo in izbira

Measurement of water flow in closed conduits -- Meters for cold potable water -- Part 2: Installation requirements and selection

iTeh STANDARD PREVIEW

Mesurage de débit d'eau dans les conduites fermées -- Compteurs d'eau potable froide -
- Partie 2: Conditions d'installation et choix

[SIST ISO 4064-2:2002](https://standards.iteh.ai/catalog/standards/sist/e298f161-aa8d-47ee-b710-5d101a2d00d/sist-iso-4064-2-2002)

Ta slovenski standard je istoveten z: **ISO 4064-2:2001**

ICS:

91.140.60 Sistemi za oskrbo z vodo Water supply systems

SIST ISO 4064-2:2002

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST ISO 4064-2:2002

<https://standards.iteh.ai/catalog/standards/sist/e298f461-aa8d-47ee-b710-3d101fa2d00d/sist-iso-4064-2-2002>

INTERNATIONAL STANDARD

ISO
4064-2

Second edition
2001-06-01

Measurement of water flow in closed conduits — Meters for cold potable water — Part 2: Installation requirements and selection

*Mesurage de débit d'eau dans les conduites fermées — Compteurs d'eau
potable froide —
Partie 2: Conditions d'installation et choix*

[SIST ISO 4064-2:2002](https://standards.iteh.ai/catalog/standards/sist/e298f461-aa8d-47ee-b710-3d101fa2d00d/sist-iso-4064-2-2002)

<https://standards.iteh.ai/catalog/standards/sist/e298f461-aa8d-47ee-b710-3d101fa2d00d/sist-iso-4064-2-2002>



Reference number
ISO 4064-2:2001(E)

© ISO 2001

ISO 4064-2:2001(E)**PDF disclaimer**

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST ISO 4064-2:2002

<https://standards.iteh.ai/catalog/standards/sist/e298f461-aa8d-47ee-b710-3d101fa2d00d/sist-iso-4064-2-2002>

© ISO 2001

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.ch
Web www.iso.ch

Printed in Switzerland

Contents

Page

Foreword.....	iv
1 Scope	1
2 Normative reference	1
3 Terms and definitions	1
4 Examples of use of meters operating in parallel and multiple meter operation	2
5 Criteria for the selection of water meters.....	2
5.1 General considerations.....	2
5.2 Meters operating in parallel or in group.....	2
6 Associated fittings.....	3
6.1 Upstream side	3
6.2 Downstream side	3
6.3 Meters operating in parallel or in groups.....	3
7 Installation	3
7.1 General requirements.....	3
7.2 Installation requirements.....	4
7.3 Meters operating in parallel or in group.....	4
8 Special requirements governing the installation of Woltmann meters and single jet meters	5
8.1 General considerations.....	5
8.2 Types of disturbance.....	5
8.3 Methods to eliminate disturbances.....	5
9 First operation of new or repaired water meters.....	6
9.1 General considerations.....	6
9.2 Meters operating in parallel or in group.....	6
Bibliography	7

ISO 4064-2:2001(E)**Foreword**

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 3.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this part of ISO 4064 may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

International Standard ISO 4064-2 was prepared by Technical Committee ISO/TC 30, *Measurement of fluid flow in closed conduits*, Subcommittee SC 7, *Volume methods including water meters*.

This second edition cancels and replaces the first edition (ISO 4064-2:1978) which has been technically revised.

ISO 4064 consists of the following parts, under the general title *Measurement of water flow in closed conduits — Meters for cold potable water*.

- *Part 1: Specifications* [SIST ISO 4064-2:2002](https://standards.iteh.ai/catalog/standards/sist/e298f461-aa8d-47ee-b710-3d101fa2d00d/sist-iso-4064-2-2002)
- *Part 2: Installation requirements and selection* <https://standards.iteh.ai/catalog/standards/sist/e298f461-aa8d-47ee-b710-3d101fa2d00d/sist-iso-4064-2-2002>
- *Part 3: Test methods and equipment*

Measurement of water flow in closed conduits — Meters for cold potable water —

Part 2: Installation requirements and selection

1 Scope

This part of ISO 4064 specifies criteria for the selection of water meters, associated fittings, installation, special requirements for some meters and the first operation of new or repaired meters to ensure accurate constant measurement and reliable reading of the meter.

This part of ISO 4064 deals only with single water meter installations and is also applicable to single meters operating either in parallel or grouped together in one location. It is not applicable to “combination” meters, for which specifications are given in ISO 7858-1.

Where legal national requirements exist, they will in all cases take precedence over the specifications in this part of ISO 4064.

ISO 4064-1 deals with terminology, technical and dimensional characteristics, metrological characteristics and pressure loss.

ISO 4064-3 deals with test methods and equipment.

2 Normative reference

The following normative document contains provisions which, through reference in this text, constitute provisions of this part of ISO 4064. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this part of ISO 4064 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 4064-1:1993, *Measurement of water flow in closed conduits — Meters for cold potable water — Part 1: Specifications*.

3 Terms and definitions

For the purposes of this part of ISO 4064, the following terms and definitions apply.

3.1

parallel operation

operation of two or more meters grouped together and connected to a common source and a common delivery

ISO 4064-2:2001(E)**3.2****multiple meter operation**

operation of several meters grouped together where their inlets are connected to a common source, or their outlets to a common delivery, but not both at same time

4 Examples of use of meters operating in parallel and multiple meter operation

Water meters may be operated in parallel where the installation of one large meter to meet the maximum water demand or to cover the required flowrate range is impractical.

Water meters may be installed in parallel where “stand by” meters are necessary to ensure continuity of delivery and flow measurement in the case of filter blockage or water meter breakdown.

Meters are grouped in multiple operation for ease of access, service and reading, where it is necessary to split a water supply into a number of branches, e.g. in a block of flats, or where it is necessary to unite a number of metered tributary flows into a common main, as in a water treatment plant.

5 Criteria for the selection of water meters**5.1 General considerations**

The type, metrological class and sizes of water meters are determined according to the operating conditions of the installation, particularly taking into account the following:

- the available supply pressure;
- physical and chemical characteristics of the water;
- acceptable pressure loss across the meter;
- the expected flowrates: the flowrates q_{\min} , q_p , q_s of the meter (as defined in clause 3 of ISO 4064-1:1993) shall be compatible with the expected flowrate conditions of the installations;
- the suitability of the meter type for the intended installation conditions.

5.2 Meters operating in parallel or in group

5.2.1 For meters operating in parallel, means shall be provided so that the unavailability of one or more meters of a group shall not cause the remaining meters to operate at a flowrate in excess of their individual limit of operation.

5.2.2 In order to ensure that water meters of different types will operate satisfactorily in parallel, the individual characteristics of meters operating in parallel shall be compatible, e.g. by grouping them according to pressure loss, flowrate range and maximum working pressure. However, the installation conditions (see 5.2.3) for each type shall be respected.

5.2.3 For meters operating in parallel and multiple meter operation, the possibilities of interaction between one meter or meter type and another to the detriment of their life and accuracy, e.g. pressure surges and vibration, shall be considered.

6 Associated fittings

6.1 Upstream side

The water meter installation shall include the following accessories as applicable:

- a) a stopcock or valve, preferably with the direction of the valve operation indicated;
- b) for Woltmann meters and single jet meters, a full-bore valve;
- c) a flow-straightening device and/or a straight length of pipe fitted between the valve and the meter;
- d) a strainer fitted between the stop valve and the meter and, in the case of a Woltmann or single jet type meter, upstream of the straight length or the straightening device;
- e) means of sealing the connection of the water meter to the water supply line in order to detect any unauthorized removal of the water meter.

6.2 Downstream side

The water meter installation shall include the following accessories as applicable.

- a) an adjustable length device to allow for easy installation and removal of the water meter. This device is specially recommended for meters having $q_p \geq 15 \text{ m}^3/\text{h}$;
- b) a device including a drain valve which may be used for pressure monitoring, sterilization and water sampling;
- c) a stopcock or a valve for meters having $q_p > 2,5 \text{ m}^3/\text{h}$; this valve shall be operated in the same sense as the upstream valve. For Woltmann meters and single jet meters, a full-bore valve is recommended;
- d) a check valve, except for bi-directional flow applications.

6.3 Meters operating in parallel or in groups

The installation of water meters operating in parallel or in a group shall also consider the following requirements.

- a) a means for isolating the flow through each individual water meter shall be provided. In this respect, the provisions concerning the requirements for isolation of the water meter installation shall apply to each individual meter;
- b) a filter with an isolating valve upstream may be included in the common supply. During operation of the water meter, the upstream isolating valve shall be kept fully open.

7 Installation

7.1 General requirements

7.1.1 Every water meter, single or in a group, shall be easily accessible for reading (without, e.g. the use of mirror or ladder), for fitting, for maintenance, for removal and for *in situ* dismantling of the mechanism if required.

In addition, for water meters of mass in excess of 25 kg, clear access to the installation site to allow the water meter to be brought to, or removed from, its working position, and adequate space around the working position for the installation of lifting gear, shall be provided.