



Standard Practice for Clearance Examinations Following Lead Hazard Reduction Activities in Single-Family Dwellings and Child-Occupied Facilities¹

This standard is issued under the fixed designation E 2271; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice combines visual assessment for the presence of deteriorated paint, surface dust, painted debris, and paint chips with environmental sampling of surface dust to determine whether a lead hazard exists at the time of sample collection, following abatement, other lead-hazard reduction activities, or building maintenance or modification activities.

1.2 This practice addresses clearance examination of single-family residential dwellings and child-occupied facilities.

1.3 This practice also addresses clearance examinations that may include soil sampling, for example when soil abatement has been performed.

1.4 This practice includes a procedure for determining whether regulatory requirements for lead clearance levels for dust and, where warranted, soil have been met, and, consequently whether a clearance area, passes or fails a clearance examination.

NOTE 1—This practice is consistent with that portion of “clearance” described in 40 CFR Part 745 for abatement, and in 24 CFR 35 for lead-hazard reduction activities other than abatement.

1.5 The values stated in SI units are to be regarded as the standard.

1.6 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:²

D 4840 Guide for Sampling Chain-of-Custody Procedures

D 5124 Practice for Testing and Use of a Random Number Generator in Lumber and Wood Products Simulation
E 631 Terminology of Building Constructions
E 1480 Terminology of Facility Management (Building-Related)
E 1605 Terminology Relating to Lead in Buildings
E 1727 Practice for Field Collection of Soil Samples for Lead Determination by Atomic Spectrometry Techniques
E 1728 Practice for Field Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination
E 1792 Specification for Wipe Sampling Materials for Lead in Surface Dust
E 1864 Practice for Evaluating Quality Systems of Organizations Engaged in Conducting Facility and Hazard Assessments for Lead in Paint, Dust, Airborne Particulate, and Soil In and Around Buildings and Related Structures
E 2239 Practice for Record Keeping and Record Preservation for Lead Hazard Activities
E 2255 Practice for Conducting Visual Assessments for Lead Hazards in Buildings

2.2 U.S. Regulations:

24 CFR (Code of Federal Regulations) 35, Department of Housing and Urban Development (HUD), Requirements for Notification, Evaluation and Reduction of Lead-Based Paint Hazards in Federally Owned Residential Property and Housing Receiving Federal Assistance³
40 CFR 745, Environmental Protection Agency (EPA), Lead-Based Paint Poisoning Prevention in Certain Residential Structures (especially subparts D, L and Q)³

2.3 Governmental Agency Guidance:

Guidelines for the Evaluation and Control of Lead-Based Paint Hazards in Housing, HUD-1539-LBP, June 1995, revised September 1997 (“HUD Guidelines”)⁴

¹ This practice is under the jurisdiction of ASTM Committee E06 on Performance of Buildings and is the direct responsibility of Subcommittee E06.23 on Lead Hazards Associated With Buildings.

Current edition approved April 1, 2004. Published April 2004. Originally approved in 2003. Last previous edition approved in 2003 as E 2271 – 03.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard’s Document Summary page on the ASTM website.

³ Available from U.S. Government Printing Office Superintendent of Documents, 732 N. Capitol St., NW, Mail Stop: SDE, Washington, DC 20401. Also available from <http://www.gpo.gov/nara/cfr/index.html>.

⁴ Available from HUD USER, P.O. Box 6091, Rockville, MD 20849.

National Lead Laboratory Accreditation Program (NLLAP)⁵

3. Terminology

3.1 *Definitions*—For definitions of terms related to this practice that do not appear in this section, refer to Terminologies E 631, E 1605, and E 1480.

3.2 *Definitions of Terms Specific to This Standard:*

3.2.1 *clearance area, n*—work area and additional spaces outside the work area where lead contamination may have occurred during lead hazard control and other building maintenance or modification activities.

3.2.1.1 *Discussion*—The spaces outside the work area may include rooms connected to the work area, egress routes, waste storage areas, and grounds adjoining exterior work areas.

3.2.2 *lead hazard reduction, n*—any measure that results in a lessening of the number or extent, or both, of lead hazards.

3.2.3 *surface dust, n*—particulate matter on a surface.

3.2.3.1 *Discussion*—For lead hazard activities, the particulate matter may be transported to the surface by various means such as through the air or by tracking or be produced by deterioration of the surface.

3.2.4 *work area, n*—the interior or exterior space where lead hazard control or other building maintenance or modification activities are performed.

3.2.4.1 *Discussion*—The interior work space may include (1) a portion of a room, an entire room, or room equivalent, or (2) portions of multiple rooms, multiple rooms or room equivalents, dependent upon the extent or location, or both, of the lead hazard control activity. The exterior work space may include (1) a portion of a building façade or an entire building façade and (2) bare soil.

4. Significance and Use

4.1 A clearance examination of abatement areas and areas associated with other lead-hazard control activities in single-family residential dwellings and child-occupied facilities is performed to determine that the clearance area is adequately safe for reoccupancy.

4.2 It is the responsibility of the user of this standard to assure that all regulatory, contractual, and personnel requirements are met prior to conduct of a clearance examination. At a minimum, users of this standard shall be trained in its use and in safe practices for its conduct.

4.3 This practice is one of a set of standards developed for lead hazard management activities. The visual assessment procedures required in this standard are found in Practice E 2255 and the record keeping requirements are found in Practice E 2239.

4.4 Although this practice was primarily developed for residential dwellings and child occupied facilities, this practice is also applicable to nonresidential buildings and related structures, as may be needed, by agreement between the client and the individual conducting the clearance examination.

4.5 This practice may be used by owners and property managers, including owner-occupants, and others responsible

for maintaining facilities. It may also be used by lead hazard management consultants, construction contractors, labor groups, real estate and financial professionals, insurance organizations, legislators, regulators, and legal professionals.

5. General Requirements

5.1 *Applicable Regulations*—The clearance examination shall be conducted in accordance with all regulations promulgated by authorities having jurisdiction. Applicable regulations are those that are currently in force in jurisdictions where the clearance examination is conducted.

5.2 *Personnel Qualifications*—All persons conducting or participating in the clearance examination shall be qualified in accordance with regulations promulgated by authorities having jurisdiction.

NOTE 2—For example, in the United States of America, see 40 CFR Part 745 Subpart L, 24 CFR Part 35.

5.3 *Reporting Schedule*—Before arriving at the property, determine with the client the schedule for reporting the results of the clearance examination. Specify in hours or days when the clearance summary and clearance report are due to the client. Consider in the reporting schedule the following: when the last sample for the clearance examination is to be collected; when the results of testing are to be available; and, whether and how reoccupancy, additional construction, or maintenance work, or other factors affect the schedule.

5.4 *Dust Wipe Sampling Materials*—Use only dust wipes that meet Specification E 1792 to collect samples of surface dust.

5.5 *Dust Sampling Procedure*—Collect surface dust wipe samples in accordance with Practice E 1728. Record the unique location description, unique sample identifier, the dimensions of the area sampled, and all other sample collection information on the Paint/Dust/Debris Data Form (given in Practice E 2255).

5.6 *Soil Sampling Procedure*—When required, collect soil samples in accordance with Practice E 1727. Record the unique location description, unique sample identifier, and all other sample collection information on the Ground Data Form (given in Practice E 2255).

5.7 *Laboratory Selection:*

5.7.1 Use only laboratories that hold the necessary accreditations, certifications, and recognitions needed to conduct lead testing services required by regulations promulgated by authorities having jurisdiction.

NOTE 3—For example, in the United States of America, laboratories are recognized for analysis of lead in soil or dust wipe samples, or both, as applicable, by the U.S. Environmental Protection Agency (EPA) through the National Lead Laboratory Accreditation Program (NLLAP).

6. Activities Conducted Prior to Visual Assessment and Sample Collection

6.1 *Define the Clearance Area:*

6.1.1 Determine the clearance area with the client or client's designee.

6.1.1.1 If the location of the interior work area in which the lead hazard reduction or other building maintenance or modification activity was performed is unknown, the clearance

⁵ <http://www.epa.gov/opptintr/lead/index.html>

examiner shall assume that the clearance area is the entire interior of the dwelling.

6.1.1.2 If the exterior work area upon which hazard reduction or other building maintenance or modification activity was performed is unknown, the clearance examiner shall assume that the clearance area is the entire exterior property.

6.2 *Secure Contract*—A contract shall be secured and include:

6.2.1 Signed releases permitting entry to the property and for conducting the clearance examination, as may be needed, prior to attempting entry to the property,

6.2.2 Permission to acquire and review available property construction records and any other records appropriate to the conduct of the clearance examination,

6.2.3 Permission to collect samples,

6.2.4 Description of the work area, and

6.2.5 Description of the clearance area.

6.3 *Prepare Floor and Site Plan(s)*:

6.3.1 Prepare a floor plan (interior) or property site plan (exterior), or both, to cover all work and associated areas, as applicable, in accordance with Practice E 2255. Each plan shall be used to record clearance examination activities including:

6.3.1.1 Location of the clearance area,

6.3.1.2 Locations from which samples of soil or surface dust, or both, were collected prior to a lead hazard or other building maintenance or modification activity (see Note 4),

NOTE 4—These samples of soil or surface dust, or both, may have been collected to document lead levels prior to the conduct of abatement, other lead hazard activities, and other building maintenance or modification activities.

6.3.1.3 Area(s) used for the storage of debris and waste,

6.3.1.4 Route(s) used by workers to walk from the work area to the exterior of the building,

6.3.1.5 Locations(s) where deteriorated paint, surface dust, paint chips, and painted or unpainted debris (if any) had been observed within the work area during visual examination(s), and performed prior to the lead hazard reduction or other building maintenance or modification activity.

6.4 *Clearance Examination Initiation*:

6.4.1 Verify with the client or client's designee, that the lead hazard reduction or other building maintenance or modification activity has been completed before initiating the visual assessment.

6.4.2 Wait at least 1 h after cleaning has been completed before initiating the visual assessment to allow airborne dust to settle.

7. Protocol for Interior Visual Assessment

7.1 Conduct visual assessments of all areas in accordance with Practice E 2255.

7.1.1 *Spaces Outside the Work Area*—Assess each space outside the work area but within the clearance area.

7.1.1.1 *Storage Areas*—Assess each room connected to the work area for the presence of surface dust and painted debris. If no surface dust or painted debris is observed, the room connected to the work area passes visual assessment. Any observation of surface dust or painted debris constitutes failure.

7.1.1.2 *Rooms Connected to the Work Area*—Assess each storage area, if any, where painted debris or other lead hazard reduction or other building maintenance or modification waste has been stored. If no painted debris or other lead hazard reduction or building maintenance or modification waste is observed, the storage area passes visual assessment. Any observation of painted debris or lead hazard reduction waste constitutes failure.

7.1.1.3 *Egress Routes*—Assess egress routes for the presence of surface dust and painted debris. If no surface dust or painted debris is observed in an egress route, the egress route passes visual assessment. Any observation of surface dust or painted debris constitutes failure.

7.1.2 *Work Area*—Assess the work area for the presence of deteriorated paint, surface dust, and painted debris. Any observation of deteriorated paint, surface dust, or painted debris indicates that the work area has failed visual assessment. If no deteriorated paint, surface dust, or painted debris is observed, the work area passes visual assessment.

7.2 If any part of the clearance area does not pass visual assessment, advise the client or the client's designee, or both, that corrective action, such as recleaning of the area or removal of debris and waste, or both, are required prior to performance of another visual examination.

7.3 If the clearance area passes visual assessment, proceed to collect samples of surface dust as described in Section 8.

8. Protocol for Interior Settled Dust Sampling

8.1 Collect a wipe sample of surface dust for each sampling location described in 8.2 through 8.6 in accordance with Practice E 1728.

8.2 Record on the floor plan locations from which dust wipe samples are collected.

8.3 *Floor and Windows within the Work Area*—Select either Procedure A or Procedure B to determine sampling locations for collecting floor and window dust-wipe samples within the work area. See Note 5.

NOTE 5—Surfaces affected as a consequence of a failed clearance analysis result depend on the whether Procedure A or Procedure B was used to sample the work area. In the case of Procedure A, a failed clearance analysis result means that only the floor or window surface represented by this result fails clearance. In Procedure B, because a few floor and window sampling sites are intended to represent all floors and window surfaces within the work area respectively, a failed clearance analysis result means all floor or window surfaces represented by the sample except for those for which acceptable dust-lead levels were obtained fail clearance. See 11.1.2.1.

8.3.1 In procedure A, independent of the number of rooms in the clearance area, floor sampling locations are identified in every portion of a room, entire room, or room equivalent and every window. The result of a dust wipe analysis applies only to the surface that was sampled.

8.3.2 In procedure B, depending on the number or rooms in the clearance area, floor sampling locations are identified in all or at least four portions of a room, entire rooms, or room equivalents and one window in each portion of a room, entire room or room equivalent. In most cases, the result of a dust wipe analysis applies to all the surfaces that are represented by the sample.

8.4 Procedure A:

8.4.1 Work Area Floors:

8.4.1.1 Select at least one sampling location from the floor of each portion of a room, entire room, or room equivalent in the work area.

(a) For portions of rooms, entire rooms, or room equivalents smaller than 50 m² (500 ft²), select one sampling location based either on professional judgment or according to the procedure described in Annex A1.

(b) For portions of rooms, entire rooms, or room equivalents larger than 50 m² (500 ft²), divide the floor into two or more equal parts of 50 m² (500 ft²) or less. Select one sampling location in each part based either on professional judgment or according to the Annex A1 procedure.

8.4.2 Windows in the Work Area:

8.4.2.1 *No Window Within the Work Area*—Record that there is no window in the work area.

8.4.2.2 *One Window in a Portion of a Room, Entire Room, or Room Equivalent*—Identify two sampling locations; one as the entire interior sill and the other as the entire trough. If the trough surface is unavailable (for example, window nailed shut), record so (no trough sample is taken).

8.4.2.3 *More Than One Window Within the Work Area*—Select window sill(s) or trough(s), or both, as sampling locations based on professional judgment such that either the interior sill or trough, or both, of each window is sampled, or

(a) Stand at the entrance used to enter the room and flip a coin. HEADS selects the first window to the right; TAILS selects the first window to the left.

(b) For the window selected, flip a coin. HEADS means that the entire interior sill is the sample location; TAILS means that the trough is the sample location.

(c) Continue in the direction determined in (a), selecting sampling locations on all windows in the work area, alternating between sills and troughs.

(d) For those windows in which the troughs are selected but unavailable to sample, collect an interior sill sample.

8.5 Procedure B:

8.5.1 Work Area Floors:

8.5.1.1 *No More Than Four Portions of Rooms, Four Entire Rooms, or Four Room Equivalents*—Select at least one floor sampling location in each portion of a room, entire room, or room equivalent according to 8.4.1.1(a) or 8.4.1.1(b).

8.5.1.2 *More than Four Portions of Rooms, at Least Four Entire Rooms, or Four Room Equivalents, or a Combination*—Use either (a) or (b) to select four portions of rooms, four rooms, or four room equivalents and record the option used.

(a) Using professional judgement, select the portions of rooms, entire rooms, or room equivalents most likely to be frequented by children.

(b) Select portions of rooms, entire rooms, or rooms equivalents using a random selection process, such as the one described in Annex A2.

8.5.1.3 Determine at least one floor sampling location in each portion of room, entire room, or room equivalent selected according to 8.4.1.1(a) or 8.4.1.1(b).

8.5.2 *Windows*—For all portions of rooms, entire rooms, or room equivalents in which a floor sampling location was selected according to either 8.5.1.1 or 8.5.1.2 and having a window, determine a minimum of two sampling locations of which one is an interior sill and the second is a trough using either 8.5.1.1 or 8.5.1.2.

8.5.2.1 Select one window based either on professional judgment, or using a random procedure such as the one in Annex A2. One sampling location is the interior sill and the other the trough.

8.5.2.2 Select sampling locations for two or more windows based on either professional judgment or using a random procedure such as the one in Annex A2. The interior sill of one window is a sampling location and the trough of another window is a sampling location, alternating between sill and trough until all windows are sampled.

8.5.2.3 If the trough is inaccessible, select another window.

8.6 Floors Outside the Work Area:

8.6.1 Rooms Connected to the Work Area:

8.6.1.1 Using professional judgement, identify a minimum of one sampling location in either a portion of the room outside of the work area, or in rooms connected to the work area by a doorway, or both. See Note 6.

NOTE 6—Dust samples are collected outside the work area to assure that leaded dust has not migrated from the work area to adjacent areas.

8.6.2 *Painted Debris and Lead Hazard Reduction Waste Storage Areas*—Select a sampling location based on either professional judgment or the procedure from Annex A1 on the floor of each interior location where painted debris or lead hazard reduction waste, or both, was stored, if any.

8.6.3 *Egress Routes*—Determine one or more sampling location(s) approximately halfway along each route that was used by workers to walk from the work area(s) and, if within the building, lead hazard reduction waste storage area(s), to the exterior of the building.

9. Protocol for Exterior Visual Assessment and Sampling

9.1 *Visual Assessment*—Conduct a visual assessment of the exterior clearance area in accordance with Practice E 2255.

9.2 For lead hazard reduction activities performed on the exterior surface of the building, include the ground areas beneath the faces of the building surface subjected to the lead hazard reduction activity or other building maintenance or modification activity and the adjoining faces up to the distance of within one half the height of the work area or up to the property line, whichever is smaller. See Note 7.

9.2.1 Exterior clearance areas pass visual assessment when no deteriorated paint is observed, and the ground is free of painted debris, including paint chips and lead hazard reduction waste.

9.2.1.1 If visual assessment is not passed, advise the client or the client's designee.

9.2.1.2 If visual assessment is passed, conduct soil sampling (if required).

9.3 Soil Sampling:

9.3.1 Soil sampling is required following soil replacement or as specified in contractual agreements, or both.

9.3.2 When required, collect the soil samples according to Practice E 1727. Examples of locations where soil samples may be collected include:

9.3.2.1 The dripline,

9.3.2.2 Replacement soil,

9.3.2.3 Bare soil areas located beneath the exterior surface abated, and

9.3.2.4 Bare soil beneath the two adjoining exterior building faces.

9.3.3 Record on the site plan all locations where soil samples are collected.

NOTE 7—Bare soil beneath the two adjoining exterior building surfaces on the property is sampled because paint contamination from the exterior surface upon which hazard reduction activities were performed may spread and be deposited on the adjoining horizontal surfaces.

10. Sample Processing

10.1 Assure that each sample container is labeled with a unique sample identifier.

10.2 Initiate a chain of custody record in accordance with Guide D 4840 for collected surface dust and soil samples. The chain of custody form shall include:

10.2.1 Unique sample identifiers,

10.2.2 Date of collection,

10.2.3 The dimensions of the areas from which dust-wipe samples were collected, and,

10.2.4 The dates of assumption and relinquishment of custody for each person who collected the samples and for each person or company/organization that obtains custody of any or all of the samples, at least the name(s) of the person(s).

10.3 Submit all samples to a laboratory recognized for lead analysis as promulgated by authorities having jurisdiction.

10.3.1 Request that the laboratory provide a copy of their certificate that recognizes that the laboratory meets the regulatory requirements of the authorities having jurisdiction. Verify that the laboratory's scope of accreditation includes the testing to be performed.

10.3.2 Request that the laboratory provide other information developed by the laboratory as specified in their quality system (for example, such as required in the United States of America by the EPA NLLAP Laboratory Quality System Requirements (LQSR)).

10.3.3 Establish an acceptable laboratory turnaround time based on the requirements for scheduling re-occupancy, additional construction or maintenance work, or both, work schedule or other criteria.

10.4 Request that the laboratory report receipt of the samples collected during the clearance examination:

10.4.1 When pre-lead hazard reduction samples were collected, verify the storage security of such samples.

10.5 *Dust-Wipe Samples*—Request that the laboratory provide:

10.5.1 Mass (micrograms, μg) of lead found in the sample,

10.5.2 The calculated mass of lead per unit area sampled (micrograms of lead per square metre or square foot ($\mu\text{g}/\text{m}^2$ or $\mu\text{g}/\text{ft}^2$));

10.5.3 Method reporting limit (MRL or RL) in mass (μg) of lead per sample.

10.6 *Soil Samples*—Request the laboratory report:

10.6.1 Micrograms of lead per gram of soil ($\mu\text{g}/\text{g}$), milligrams of lead per kilogram of soil ($\mu\text{g}/\text{kg}$), or parts per million (ppm p) for soil; and,

10.6.2 Method reporting limit (MRL or RL) in micrograms of lead per gram of soil ($\mu\text{g}/\text{g}$), milligrams of lead per kilogram of soil (Mg/kg), or parts per million (ppm) for soil.

11. Decision Making for Dust-Wipe Samples

11.1 Upon receipt of the analysis report from the laboratory, transfer the dust-wipe sample analysis results to the Clearance Summary Form (Annex A3). Compare the sample analysis results to applicable regulatory clearance level(s).

11.1.1 *Sample Analysis Result Less than Clearance Level*—If the lead content of a sample is less than the clearance level, or another more stringent level as set forth by contractual agreement, the surface or surfaces represented by that sample pass clearance.

11.1.2 *Sample Analysis Result Equal to or Greater than Clearance Level*—If the lead content of a sample is equal to or greater than the clearance level specified by applicable regulation or, or another more stringent level as set forth by contractual agreement, the surface or surfaces represented by that sample fail clearance. See Note 8.

11.1.2.1 *Work Area Surfaces:*

(a) *Procedure A Collection*—For a sample failing clearance collected using Procedure A (see 8.3.1), the portion of room, entire room, or room equivalent in which the sample was taken fails clearance. The result of a window sample is applicable to the sill and trough of the window where the sample was taken.

(b) *Procedure B Collection*—For a sample failing clearance collected using Procedure B (see 8.3.2), all floor surfaces in the work area except for those floor surfaces for which passing clearance results were obtained fail clearance. The result of a window sample is applicable to all windows (both sills and troughs surfaces) in the work area except for those windows for which passing clearance results for both the interior sill and trough were obtained.

11.1.2.2 *Floors Outside Work Area:*

(a) *Portion-of-Room Work Area*—For samples failing clearance, the result applies to the entire floor of the portion of the room outside the work area.

(b) *Rooms Connected by a Doorway to Work Area*—For those samples failing clearance, the result applies to the floor of the entire room from which the sample was collected.

(c) *Painted Debris and Lead Hazard Reduction Waste Storage Area*—For those samples failing clearance, the result applies to the total floor surface of the room from which the sample was collected.

(d) *Egress Route*—For samples failing clearance, the result applies to the entire floor of the entire egress route.

NOTE 8—For any area that fails clearance examination, the cleaning steps and/or additional portions of the lead hazard control activity needed to prepare for clearance examination are repeated, after which the clearance examination process is to be begun anew.

12. Decision Making for Soil Samples

12.1 Upon receipt of the analysis report from the laboratory, transfer the soil sample analysis results to the Clearance

Summary Form (Annex A3). Compare the sample analysis results to applicable clearance level(s).

12.1.1 *Samples Analysis Less than Clearance Level*—If the result of a sample analysis is less than the clearance level, or if more stringent, by other agreements, the surface represented by that sample is determined to have passed clearance.

12.1.2 *Samples Analysis Equal to or Greater than Clearance Level*—If the result of a sample analysis is equal to or greater than the clearance level, or if more stringent, by other agreements, the surface or surfaces represented by that sample are determined to have failed clearance.

12.1.2.1 *Bare Soil Areas*—For soil samples failing clearance, the result made for a single dripline soil sample applies to all bare soil along the drip line. The result made for a single soil sample taken from replacement soil applies to all bare replacement soil. The result made for a single soil sample taken from bare soil beneath the work area applies to all bare soil on the work-area side of the building. The result made for a single soil sample taken from bare soil on one of the adjoining sides of the building to the work area applies to all bare soil on the adjoining sides of the building.

13. Record Keeping

13.1 Records shall be maintained in accordance with Practice E 2239, and shall include a copy of the clearance summary report, the clearance report, and the laboratory(s) reports.

14. Report

14.1 *Clearance Summary*—Provide a clearance summary report to the client. An example of a suitable Clearance Summary Report Form is shown in Annex A3.

14.2 *Clearance Report*—Prepare a clearance report only when the clearance area passes clearance. See Note 9. Ensure that the clearance report meets the requirements of the authorities having jurisdiction. At a minimum, include in the report:

14.2.1 *Client Information:*

14.2.1.1 Name, address, and telephone number of the person and of the organization that ordered the clearance examination.

14.2.1.2 Relationship(s) of the person and of the organization that ordered the clearance examination to the property involved (owner, buyer, tenant, lender, insurer, and so forth).

14.2.2 *Information on the Property for Which the Clearance Examination Was Conducted:*

14.2.2.1 Address of the property, including as applicable other unique identifiers of buildings,

14.2.2.2 Name, address, and telephone number of the property owner (if known),

14.2.2.3 Name, address, and telephone number(s) of the property manager(s) (if applicable),

14.2.2.4 The type of building (for example, single family residence, child-care facility) and the year of construction, if known, and

14.2.2.5 Starting and ending times and date(s) that the clearance examination was performed.

14.2.3 *Examiner and Laboratory Information:*

14.2.3.1 Name, address, telephone number, and certification or license number, or both, with expiration date, of the firm or individual, or both, that participated in the clearance examination.

14.2.3.2 Each laboratory's name, address, telephone number, and recognition for conducting lead analysis by regulatory authorities having jurisdiction, along with the documentation acknowledging its accreditation or licensing, or both, for analysis for lead in the matrix analyzed, at the time samples were processed.

14.2.4 *Regulatory Lead Clearance Levels:*

14.2.4.1 Levels used for dust wipes and soil, if applicable.

14.2.5 *Glossary*—A glossary of defined technical terms used to report the clearance examination results. At a minimum, the glossary shall contain definitions for building component names and codes (such as wall orientation and sampling identification codes) used.

14.2.6 *Deviations from Standard*—Any deviations from methods described in this practice.

14.2.7 *Clearance Examination Information and Laboratory Results:*

14.2.7.1 All forms, including chain-of-custody forms and laboratory reports of sample analysis.

14.2.7.2 For each sample collected:

- (a) The unique sample identifier,
- (b) The description of the location(s) sampled, and
- (c) The analysis results.

NOTE 9—For example, for abatement activities in the United States of America, the clearance report must be in accordance with 40 CFR 745.227(e)(10) or other regulations promulgated by authorities having jurisdiction. For non-abatement activities in the United States of America, the clearance report is described in 24 CFR 35.1340.

15. Keywords

15.1 clearance; clearance examination; lead; lead-based paint; lead hazard; sampling; soil; surface dust; testing