



Designation: E1718 – 95 (Reapproved 2004)

Standard Guide for Administrative and Engineering Controls for Silicon Carbide Whisker Work Areas¹

This standard is issued under the fixed designation E1718; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This guide applies to workplaces where unbound silicon carbide whiskers are manufactured, processed into products, or otherwise used.

1.2 This guide offers guidance for controlling workplace exposures to airborne silicon carbide whiskers.

1.3 All applicable federal, state, county, and local regulations must be complied with when this guide is used.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*²

E1437 Practice for Handling Silicon Carbide Whiskers³

E1451 Guide for Disposal of Wastes Containing Respirable Silicon Carbide Whiskers³

E1716 Guide for Selection and Use of Personal Protective Equipment for Humans Working With Respirable Silicon Carbide Whiskers³

E1717 Guide for Personnel Training for Health and Safety Aspects of Working in Environments Containing Respirable Silicon Carbide Whiskers³

3. Terminology

3.1 *Definitions of Terms Specific to This Standard:*

¹ This guide is under the jurisdiction of ASTM Committee E34 on Occupational Health and Safety and is the direct responsibility of Subcommittee E34.70 on Single Crystal Ceramic Whiskers.

Current edition approved February 1, 2004. Published March 2004. Originally approved in 1995. Last previous edition approved in 1995 as E1718 - 95. DOI: 10.1520/E1718-95R04.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Withdrawn. The last approved version of this historical standard is referenced on www.astm.org.

3.1.1 *respirable silicon carbide*—a crystalline silicon carbide material, approximately cylindrical in shape, whiskers and fibers with an aspect ratio equal to or greater than 5, and a diameter less than 3.0 μm with the potential to become airborne.

3.1.2 *silicon carbide whisker work area*—a hood, laboratory, room, building, facility, or other defined area where unbound silicon carbide whiskers are handled, and to which potential airborne silicon carbide whiskers can be reasonably restricted.

3.1.3 *unbound silicon carbide whiskers and fibers*—whiskers and fibers with the potential to become airborne.

4. Controls for Unbound Silicon Carbide Whisker Work Areas

4.1 *Application*—The following controls should be followed for areas where unbound silicon carbide whiskers are handled outside of closed containers, or where silicon carbide whisker airborne concentrations are known or expected to be present in any quantity, regardless of duration.

4.2 *Administrative Controls:*

4.2.1 All employees associated with a silicon carbide whisker workplace should be trained in accordance with Guide E1717 and Practice E1437.

4.2.2 Eating, drinking, or smoking are not permitted in silicon carbide whisker work areas.

4.2.3 Shoe cleaners, tacky mats, or other type of control for materials tracked by shoes, should be provided at appropriate locations to prevent introduction of unbound silicon carbide whiskers to non-work areas.

4.2.4 Rotation of workers to reduce 8-h time weighted average exposures to silicon carbide whiskers is not recommended.

4.3 *Personal Protective Equipment*—Consult Guide E1716.

4.4 *Engineering Controls:*

4.4.1 Local exhaust controls engineered for a process are preferred. General exhaust controls are acceptable, but generally less effective than local exhaust. Exhaust air from central collection points should be externally exhausted, filtered as appropriate to meet applicable standards. Small self-contained