



SLOVENSKI STANDARD

SIST EN 12977-2:2012

01-julij-2012

Nadomešča:

SIST-TS CEN/TS 12977-2:2010

Toplotni sončni sistemi in sestavni deli - Neserijsko izdelani sistemi - 2. del: Preskusne metode za sončne grelnike vode in kombinirane sisteme

Thermal solar systems and components - Custom built systems - Part 2: Test methods for solar water heaters and combisystems

Thermische Solaranlagen und ihre Bauteile - Kundenspezifisch gefertigte Anlagen - Teil 2: Prüfverfahren für solar betriebene Warmwasserbereiter und Kombinationssysteme

Installations solaires thermiques et leurs composants - Installations assemblées à façon - Partie 2: Méthodes d'essai pour chauffe-eau solaires et installations solaires combinées

Ta slovenski standard je istoveten z: EN 12977-2:2012

ICS:

27.160	Sončna energija	Solar energy engineering
91.140.10	Sistemi centralnega ogrevanja	Central heating systems
91.140.65	Oprema za ogrevanje vode	Water heating equipment

SIST EN 12977-2:2012

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 12977-2:2012

<https://standards.iteh.ai/catalog/standards/sist/840b32e5-8616-46d7-8bd0-ae70abf73a49/sist-en-12977-2-2012>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 12977-2

April 2012

ICS 27.160

Supersedes CEN/TS 12977-2:2010

English Version

**Thermal solar systems and components - Custom built systems
- Part 2: Test methods for solar water heaters and
combisystems**

Installations solaires thermiques et leurs composants -
Installations assemblées à façon - Partie 2: Méthodes
d'essai pour chauffe-eau solaires et installations solaires
combinées

Thermische Solaranlagen und ihre Bauteile -
Kundenspezifisch gefertigte Anlagen - Teil 2: Prüfverfahren
für solar betriebene Warmwasserbereiter und
Kombinationssysteme

This European Standard was approved by CEN on 19 February 2012.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

	Page
Foreword.....	4
Introduction	5
1 Scope	8
2 Normative references	8
3 Terms and definitions	9
4 Symbols and abbreviations	10
5 System classification	12
6 Test methods.....	12
6.1 Introduction	12
6.2 General.....	12
6.3 Materials	13
6.4 Components and pipework.....	13
6.5 Safety equipment and indicators	15
6.6 Installation	16
6.7 Initial operation, inspection and commissioning.....	16
6.8 Documentation.....	17
6.9 System performance (for small systems only).....	17
6.10 Water wastage (for small systems only)	17
7 Optional performance test of small custom built solar heating systems.....	17
7.1 General.....	17
7.2 Test of the solar collector	18
7.3 Test of the water store(s)	18
7.4 Test of the control equipment	18
7.5 Determination of the hot water comfort	18
7.6 System simulation model	19
7.7 Long-term performance prediction.....	19
7.8 Presentation of performance indicators	25
8 Performance test report	26
Annex A (normative) Reference conditions for performance prediction	28
A.1 General.....	28
A.2 Pipe diameter and insulation thickness	30
A.3 Calculation of mains water temperature at reference location.....	30
A.4 Space heating load	31
Annex B (normative) Additional information regarding the calculation of the fractional energy savings.....	37
B.1 Definition of a conventional reference water heating system	37
B.2 Calculation of fractional energy savings for other conditions	37
Annex C (informative) Short-term system testing	39
C.1 General.....	39
C.2 Instrumentation, data acquisition and processing	39
C.3 Check of short-term system performance	41
C.4 Short-term test for long-term system performance prediction.....	44
Annex D (informative) Long-term monitoring	51
D.1 General.....	51
D.2 Evaluation chart	52

D.3	Monitoring equipment.....	52
D.4	Data analysis.....	52
Annex E (informative) Determination of water wastage.....		53
Bibliography.....		54

Figures

Figure 1	— Energy balance for one-store and two-store solar-plus-supplementary systems	21
Figure 2	— Comparison of the gross auxiliary energy demand of the solar heating system, Q_{aux} , to the gross energy demand of the conventional heating system, Q_{conv}	22
Figure 3	— Energy balance for solar only systems	24
Figure 4	— Energy balance for solar preheat systems	25
Figure C.1	— Principle of the short term system performance check: Check and intercomparison of useful energy gain	41
Figure C.2	— Principle of the short-term test and of the subsequent long term system performance prediction	45
Figure C.3	— Example of the predicted performance dependence on load level and irradiation for a solar domestic hot water heating system (see [8]).....	50

Tables

Table 1	— Division for factory made and custom built solar heating systems	6
Table 2	— Symbols, definition and unit (1 of 2)	10
Table 2	— Symbols, definition and unit (2 of 2)	11
Table 3	— Presentation of system performance indicators for solar-plus-supplementary systems	26
Table 4	— Presentation of system performance indicators for solar-only and solar preheat systems	26
Table A.1	— Reference conditions for performance presentation (1 of 2).....	28
Table A.1	— Reference conditions for performance presentation (2 of 2).....	29
Table A.2	— External pipe diameter and insulation thickness for forced-circulation systems	30
Table A.3	— Data for calculation of the mains water temperature at the reference locations	31
Table A.4	— Space heating load file for Stockholm.....	32
Table A.5	— Space heating load file for Davos	33
Table A.6	— Space heating load file for Würzburg (1 of 2)	34
Table A.6	— Space heating load file for Würzburg (2 of 2)	35
Table A.7	— Space heating load file for Athens – Example to be updated	36
Table C.1	— Variables to be measured and corresponding maximum sampling intervals.....	43
Table C.2	— Variables to be measured during system test, and corresponding maximum sampling intervals.....	46
Table C.3	— Range of variations of the driving variables to be scanned during a test outdoors	47
Table C.4	— Permissible standard deviation for secondary collector parameters	49

EN 12977-2:2012 (E)**Foreword**

This document (EN 12977-2:2012) has been prepared by Technical Committee CEN/TC 312 “Thermal solar systems and components”, the secretariat of which is held by ELOT.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2012, and conflicting national standards shall be withdrawn at the latest by October 2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes CEN/TS 12977-2:2010.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 12977-2:2012

<https://standards.iteh.ai/catalog/standards/sist/840b32e5-8616-46d7-8bd0-ae70abf73a49/sist-en-12977-2-2012>

Introduction

a) Drinking water quality

In respect of potential adverse effects on the quality of drinking water intended for human consumption caused by the product covered by this document, it should be noted that

- 1) this document provides no information as to whether the product may be used without restriction in any of the Member States of the EU or EFTA,
- 2) while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or the characteristics of this product remain in force.

b) Factory made and custom built solar heating systems

EN 12976-1, EN 12976-2, EN 12977-1, EN 12977-2, EN 12977-3, EN 12977-4 and EN 12977-5 distinguish two categories of solar heating systems:

- 1) factory made solar heating systems; and
- 2) custom built solar heating systems.

The classification of a system as factory made or custom built is a choice of the final supplier, in accordance to the following definitions.

- 1) Factory made solar heating systems are batch products with one trade name, sold as complete and ready to install kits, with fixed configurations. Systems of this category are considered as a single product and assessed as a whole.

If a factory made solar heating system is modified by changing its configuration or by changing one or more of its components, the modified system is considered as a new system. Requirements and test methods for factory made solar heating systems are given in EN 12976-1 and EN 12976-2.

- 2) Custom built solar heating systems are either uniquely built or assembled by choosing from an assortment of components. Systems of this category are regarded as a set of components. The components are separately tested and test results are integrated to an assessment of the whole system. Requirements for custom built solar heating systems are given in EN 12977-1, test methods are specified in EN 12977-2, EN 12977-3, EN 12977-4 and EN 12977-5. Custom built solar heating systems are subdivided into two categories:
 - i) large custom built systems are uniquely designed for a specific situation. In general, they are designed by HVAC engineers, manufacturers or other experts;
 - ii) small custom built systems offered by a company are described in a so-called assortment file, in which all components and possible system configurations, marketed by the company, are specified. Each possible combination of a system configuration with components from the assortment is considered as one custom built system.

Table 1 shows the division for different system types.

EN 12977-2:2012 (E)

Table 1 — Division for factory made and custom built solar heating systems

Factory made solar heating systems (EN 12976-1 and EN 12976-2)	Custom built solar heating systems (EN 12977-1, EN 12977-2, EN 12977-3, EN 12977-4 and EN 12977-5)
Integral collector-storage systems for domestic hot water preparation	Forced circulation systems for hot water preparation and/or space heating/cooling, assembled using components and configurations described in a documentation file (mostly small systems)
Thermosiphon systems for domestic hot water preparation	
Forced circulation systems as batch product with fixed configuration for domestic hot water preparation	Uniquely designed and assembled systems for hot water preparation and/or space heating/cooling (mostly large systems)

NOTE 1 Forced circulation systems can be classified either as factory made or as custom built, depending on the market approach chosen by the final supplier.

NOTE 2 Both factory made and custom built systems are performance tested under the same set of basic reference conditions as specified in EN 12976-2:2006, Annex B and in EN 12977-2:2012, Annex A. In practice, the installation conditions may differ from these reference conditions.

c) Test methods and procedures for the analysis of large custom built solar heating systems

Quality assurance is of primary importance for large custom built systems. The total investment cost for such systems is higher than for smaller ones, although the specific investment cost (i.e., per m² collector area) is lower. In several European countries, the potential of large custom built systems from the point of view of conventional energy savings is much larger than for smaller ones. Moreover, the return on investment is in many cases more favourable for large systems than for small ones. Hence, both the purchasers of large custom built systems and the governments are interested in efficient, reliable and durable systems, the thermal performance of which may be accurately predicted, checked and supervised.

The test methods in this document provide a means of verifying the compliance of large custom built systems with the requirements in EN 12977-1.

NOTE 3 Within the framework of the EU ALTENER Programme the project "Guaranteed Solar Results" (GSR) was addressing similar objectives in respect of quality assurance (see [7], [8]). Similar procedures and monitoring equipment were used as described in Annexes C and D. It might be necessary to update Annexes C and D at a later stage during a revision of this document when more expertise is available.

As large custom built systems are by definition unique systems, only general procedures on how to check and supervise them may be given. An additional difficulty in the formulation of procedures is the fact that they have to be adapted to the dimension of the large custom built system considered, which may vary from typically 30 m² to 30 000 m² of collector area. Therefore, several possible levels of analysis are included (Annexes C and D).

The objective of the two short-term system tests presented in Annex C is the characterization of system performance and/or the estimation of the ability of the system to deliver the energy claimed by the designer. In principle, two approaches for short-term system testing are referred to in this European Standard:

- 1) a simplified check of short-term system performance, carried out by intercomparison of the measured thermal solar system heat gain with the one predicted by simulation, using the actual weather and operating conditions as measured during the short-term test;

- 2) a short-term test for long-term system performance prediction. The performance of the most relevant components of the solar heating system is measured for a certain time period while the system is in normal operation. More detailed measurements encompass
 - i) energy gain of collector array(s) and
 - ii) energy balance over storage vessel(s).

Inter-comparison of the observed and simulated energy quantities provides the indirect validation of collector and storage design parameters. The measured data within the collector array are also used for direct identification of the collector array parameters. As far the component parameters are verified, the long-term prediction of the system gain as well as the detection of possible sources of system malfunctioning are possible.

Annex D describes a procedure for long-term monitoring as a part of the supervision of a large custom built solar heating system. The objectives of supervision may be:

- 3) the early recognition of possible failures of system components, in order to get the maximum benefit from the initial solar investment as well as to minimize the consumption of non-solar energy and the resulting environmental impact,
- 4) the measurement of system performance (solar gains or other system indicators), if requested by a contractual clause, e.g. guaranteed results.

The long-term monitoring in Annex D is limited to the solar energy specific aspects, especially to the determination of the solar contribution to the total heat load. Instrumentation used in the long-term monitoring should be an integrating part of the system, a part included from the very beginning of the design process. If adequately foreseen, it may also be used for system adjustment at start time.

SIST EN 12977-2:2012

<https://standards.iteh.ai/catalog/standards/sist/840b32e5-8616-46d7-8bd0-ae70abf73a49/sist-en-12977-2-2012>

EN 12977-2:2012 (E)**1 Scope**

This European Standard applies to small and large custom built solar heating systems with liquid heat transfer medium for residential buildings and similar applications, and gives test methods for verification of the requirements specified in EN 12977-1.

This document also includes a method for thermal performance characterization and system performance prediction of small custom built systems by means of component testing and system simulation.

Furthermore, this document contains methods for thermal performance characterization and system performance prediction of large custom built systems.

This document applies to the following types of small custom built solar heating systems:

- systems for domestic hot water preparation only;
- systems for space heating only;
- systems for domestic hot water preparation and space heating;
- others (e.g. including cooling).

This document applies to large custom built solar heating systems, primarily to solar preheat systems, with one or more storage vessels, heat exchangers, piping and automatic controls and with collector array(s) with forced circulation of fluid in the collector loop.

This document does not apply to

- systems with a store medium other than water (e.g. phase-change materials),
<https://standards.iteh.ai/catalog/standards/sist/840b32e5-8616-46d7-8bd0-ae70abf73a49/sist-en-12977-2-2012>
- thermosiphon systems,
- integral collector-storage (ICS) systems.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 307, *Heat exchangers — Guidelines to prepare installation, operating and maintenance instructions required to maintain the performance of each type of heat exchangers*

EN 806-1, *Specifications for installations inside buildings conveying water for human consumption — Part 1: General*

EN 809, *Pumps and pump units for liquids — Common safety requirements*

EN 1151-1, *Pumps — Rotodynamic pumps — Circulation pumps having a rated power input not exceeding 200 W for heating installations and domestic hot water installations — Part 1: Non-automatic circulation pumps, requirements, testing, marking*

EN 1991-1-3, *Eurocode 1 — Actions on structures — Part 1-3: General actions — Snow loads*

EN 1991-1-4, *Eurocode 1: Actions on structures — Part 1-4: General actions — Wind actions*

EN 12975-1:2006, *Thermal solar systems and components — Solar collectors — Part 1: General requirements*

EN 12975-2:2006, *Thermal solar systems and components — Solar collectors — Part 2: Test methods*

EN 12976-1:2006, *Thermal solar systems and components — Factory made systems — Part 1: General requirements*

EN 12976-2:2006, *Thermal solar systems and components — Factory made systems — Part 2: Test methods*

EN 12977-1:2012, *Thermal solar systems and components — Custom built systems — Part 1: General requirements for solar water heaters and combisystems*

EN 12977-3:2012, *Thermal solar systems and components — Custom built systems — Part 3: Performance test methods for solar water heater stores*

EN 12977-4:2012, *Thermal solar systems and components — Custom built systems — Part 4: Performance test methods for solar combistores*

EN 12977-5:2012, *Thermal solar systems and components — Custom built systems — Part 5: Performance test methods for control equipment*

EN 60335-1, *Household and similar electrical appliances — Safety — Part 1: General requirements (IEC 60335-1)*

EN ISO 9488:1999, *Solar energy — Vocabulary (ISO 9488:1999)*

ISO 9459-5:2007, *Solar heating — Domestic water heating systems — Part 5: System performance characterization by means of whole-system tests and computer simulation*

ISO/TR 10217, *Solar energy — Water heating systems — Guide to material selection with regard to internal corrosion*

STANDARD PREVIEW
(standardit.ch)
SIST EN 12977-2:2012
<https://standards.iteh.ai/catalog/standards/sist/840652e5-8616-46d7-8bd0-ac70abf73a49/sist-en-12977-2-2012>

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 12975-1:2006, EN 12976-1:2006, EN 12977-1:2012, EN 12977-3:2012, EN 12977-5:2012, ISO 9459-5:2007 and EN ISO 9488:1999 apply.

4 Symbols and abbreviations

Table 2 — Symbols, definition and unit (1 of 2)

Symbol	Definition	Unit
a_1	heat loss coefficient at $(\vartheta_m - \vartheta_a) = 0$	W/(m ² × K)
A_c	reference area of collector	m ²
C_c	effective thermal capacity of collector or collector array	J/K
Day	day number of the year	
D_s	shift term for the calculation of mains water temperature at reference location	
f_{sav}	fractional energy savings	%
f_{sol}	solar fraction	%
G_d	diffuse solar irradiance on tilted plane	W/m ²
G_g	global solar irradiance (on horizontal plane)	W/m ²
G_h	hemispherical solar irradiance on tilted plane	W/m ²
H_c	hemispherical solar irradiation on collector plane	MJ/m ²
$K_{\alpha\tau}$	incidence angle modifier	
Q_{aux}	gross auxiliary energy demand of the solar heating system	MJ
$Q_{aux,net}$	net auxiliary energy demand of the solar heating system delivered by the auxiliary heater to the store or directly to the heat distribution system	MJ
Q_{conv}	gross energy demand of the conventional heating system	MJ
$Q_{conv,net}$	net energy demand of the conventional heating system	MJ
Q_d	heat demand	MJ
Q_L	energy delivered at the outlet of the solar heating system	MJ
Q_l	store heat losses of the solar heating system	MJ
$Q_{l,a}$	store heat losses of the store heated by auxiliary energy (in case of a two-store-solar-plus-supplementary system)	MJ
$Q_{l,s}$	store heat losses of the store heated by solar energy (in case of a two-store-solar-plus-supplementary system)	MJ
$Q_{l,conv}$	store heat losses of the conventional heating system	MJ
Q_{ohp}	heat diverted from the store as active overheating protection, if any	MJ
Q_{par}	parasitic energy (electricity) for the collector loop pump(s) and control unit	MJ
Q_{sav}	energy savings due to the solar heating system	MJ
Q_{sol}	energy delivered by the collector loop to the store	MJ
T^*	reduced temperature difference; $T^* = (\vartheta_m - \vartheta_a)/G_h$	m ² × K/W
$(UA)_{hx}$	heat transfer capacity rate of a heat exchanger	W/K
$(UA)_S$	heat loss capacity rate of the store of the solar heating system	W/K

Table 2 — Symbols, definition and unit (2 of 2)

$(UA)_{S,conv}$	heat loss capacity rate of the store of the conventional heating system	W/K
U_L	overall heat loss coefficient of a collector or collector array	W/(m ² × K)
\dot{V}_c	volume flow rate in collector loop	l/h
V_d	demanded (daily) load volume	l/d
\dot{V}_{rc}	volume flow rate in circulation loop	l/h
\dot{V}_s	volume draw-off flow rate from storage	l/h
$V_{S,conv}$	store volume of the conventional heating system	l
v	surrounding air speed	m/s
$\Delta \vartheta$	average temperature difference induced by a heat exchanger	K
$\Delta \vartheta_{amplit}$	average amplitude of seasonal mains water temperature variations on reference location	K
$\Delta \eta$	drop in system efficiency induced by a heat exchanger	%
ϑ_a	collector ambient or surrounding air temperature	°C
$\vartheta_{average}$	yearly average mains water temperature on reference location	°C
$\vartheta_{ci/co}$	collector or collector array inlet/outlet fluid temperature	°C
ϑ_{cw}	mains water temperature	°C
ϑ_d	desired hot water temperature	°C
ϑ_m	mean collector fluid temperature; $\vartheta_m = (\vartheta_{ci} + \vartheta_{co})/2$	°C
ϑ_{rce}	fluid temperature at circulation loop outlet	°C
ϑ_{rci}	fluid temperature at circulation loop inlet	°C
ϑ_S	storage draw-off temperature	°C
$\vartheta_{S,amb}$	store ambient air temperature	°C
$\vartheta_{start/stop}$	temperature for which controller operation starts/stops	°C
ϑ_{tank}	temperature of the storage tank	°C
η_0	zero-loss collector efficiency (efficiency at $T^* = 0$)	
η_{aux}	overall generation efficiency of the auxiliary heater of the solar heating system	
η_{conv}	overall generation efficiency of the heater of the conventional heating system	
θ_{req}	required temperature for sensor high-temperature resistance	°C
θ_{sens}	sensor temperature	°C

EN 12977-2:2012 (E)**5 System classification**

See EN 12977-1:2012, Clause 5.

6 Test methods**6.1 Introduction**

Subsequent test methods refer to the requirements given in EN 12977-1.

6.2 General**6.2.1 Suitability for drinking water**

See EN 806-1.

6.2.2 Water contamination

Check the design of all circuits to avoid water contamination for backflow from all circuits to drinking main supplies.

6.2.3 Freeze resistance

See EN 12976-2:2006, 5.1.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

6.2.4 High-temperature protection

SIST EN 12977-2:2012

[https://standards.iteh.ai/catalog/standards/sist/840b32e5-8616-46d7-](https://standards.iteh.ai/catalog/standards/sist/840b32e5-8616-46d7-8bd0-ae70abf73a49/sist-en-12977-2-2012)

6.2.4.1 Scald protection

[8bd0-ae70abf73a49/sist-en-12977-2-2012](https://standards.iteh.ai/catalog/standards/sist/840b32e5-8616-46d7-8bd0-ae70abf73a49/sist-en-12977-2-2012)

If the temperature of the domestic hot water in the system can exceed 60 °C, check the design plan or the system documentation to see whether the system is provided with an automatic cold water mixing device or any other device to limit the maximum tapping temperature to 60 °C.

6.2.4.2 High-temperature protection of materials

Ensure by checking the hydraulic scheme and/or by calculation and taking into account the most adverse conditions for the materials of all parts of the system, that the maximum temperatures which may occur do not exceed the maximum permissible temperatures for the respective materials, taking into account also pressure conditions and/or mechanical stress if relevant.

NOTE Both transients (high temperature peaks of short duration) and stagnation of longer duration may create adverse conditions for the respective material.

6.2.5 Reverse circulation prevention

Check the hydraulic scheme included in the documentation (see 6.8) to ensure that no unintentional reverse circulation will occur in any hydraulic loop of the system.

6.2.6 Pressure resistance

In case that it is not documented that the store(s) and the heat exchanger(s) withstand at least 1,5 times the manufacturer's stated maximum individual working pressures, the procedures specified in EN 12976-2:2006, 5.3 should be applied on the store(s) and the heat exchanger(s).

NOTE EN 12976-2:2006, 5.3 specifies a pressure resistance test method for a complete solar thermal system. For the purpose of this subclause, this method should be principally applied on the store(s) and heat exchanger(s).

Check if the system documentation for the installer describes a pressure resistance test procedure for the collector loop of the system.

6.2.7 Electrical safety

See EN 60335-1.

6.3 Materials

Check if the documentation for the installer includes information about the durability of the materials exposed to weathering with regard to UV radiation and other weather conditions.

Check if the materials used in the collector loop comply with ISO/TR 10217 concerning internal corrosion.

6.4 Components and pipework

6.4.1 Collector and collector array

The collector should be tested according to EN 12975-2.

The design of the collector array should be checked with regard to flow distribution.

6.4.2 Supporting frame

Check the calculation proving the resistance of the frame to snow and wind loads in accordance with EN 1991-1-3 and EN 1991-1-4 where applicable.

6.4.3 Collector and other loops

With regard to the collector loop, check if the requirements listed in EN 12977-5:2012, Table 10, are fulfilled.

6.4.4 Circulation pump

See EN 809, EN 1151-1 and EN 12977-5.

6.4.5 Expansion vessels

6.4.5.1 General

For systems without a separate expansion vessel (e.g. drain-back systems) check both by calculation and the hydraulic scheme to see whether the integrated expansion facility is able to fulfil its task.