

SLOVENSKI STANDARD SIST-TS CEN/TS 16650:2014

01-julij-2014

Specifikacija za spojke na ceveh za bencin, olja in maziva - Visokotlačna spojka

Specification for hose couplings for petrol, oil and lubricants - High pressure couplings

Spezifikation für Schlauchkupplungen für Benzin, Öl und Schmierstoffe -Hochdruckkupplungen

Spécifications pour les raccords de tuyaux pour essence, huile et lubrifiants - Raccords haute pression (standards.iteh.ai)

Ta slovenski standard je istoveten z CEN/TS 16650:2014

a2174eeeeead/sist-ts-cen-ts-16650-2014

ICS:

23.100.40 Cevna napeljava in sklopke Piping and couplings
75.180.01 Oprema za industrijo nafte in Equipment for petroleum and zemeljskega plina na splošno natural gas industries in general

SIST-TS CEN/TS 16650:2014 en,fr,de

SIST-TS CEN/TS 16650:2014

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST-TS CEN/TS 16650:2014 https://standards.iteh.ai/catalog/standards/sist/dbbc8f6e-9783-4a0e-b444a2174eeeeead/sist-ts-cen-ts-16650-2014

TECHNICAL SPECIFICATION SPÉCIFICATION TECHNIQUE TECHNISCHE SPEZIFIKATION

CEN/TS 16650

June 2014

ICS 23.040.70; 49.050

English Version

Specification for hose couplings for petrol, oil and lubricants - High pressure couplings

Spécifications pour les raccords de tuyaux pour essence, huile et lubrifiants - Raccords haute pression

Spezifikation für Schlauchkupplungen für Benzin, Öl und Schmierstoffe - Hochdruckkupplungen

This Technical Specification (CEN/TS) was approved by CEN on 16 December 2013 for provisional application.

The period of validity of this CEN/TS is limited initially to three years. After two years the members of CEN will be requested to submit their comments, particularly on the question whether the CEN/TS can be converted into a European Standard.

CEN members are required to announce the existence of this CEN/TS in the same way as for an EN and to make the CEN/TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force (in parallel to the CEN/TS) until the final decision about the possible conversion of the CEN/TS into an EN is reached.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

SIST-TS CEN/TS 16650:2014

https://standards.iteh.ai/catalog/standards/sist/dbbc8f6e-9783-4a0e-b444-a2174eeeeead/sist-ts-cen-ts-16650-2014



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

COI	intents	Page
Fore	eword	3
1	Scope	4
2	Normative references	4
3	Information to be supplied by the purchaser	4
4	Designation of sizes of couplings	4
5	Materials	4
6	Dimensions	4
7	Coupling finish	5
8	Screw threads	5
9	Washers	
10	Bonding	5
11	Hydrostatic test	
12	Identification marking Ten STANDARD PREVIEW	5
	(standards.iteh.ai)	

SIST-TS CEN/TS 16650:2014 https://standards.iteh.ai/catalog/standards/sist/dbbc8f6e-9783-4a0e-b444a2174eeeeead/sist-ts-cen-ts-16650-2014

Foreword

This document (CEN/TS 16650:2014) has been prepared by Technical Committee CEN/TC 218 "Rubber and plastics hoses and hose assemblies", the secretariat of which is held by BSI.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to announce this Technical Specification: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST-TS CEN/TS 16650:2014 https://standards.iteh.ai/catalog/standards/sist/dbbc8f6e-9783-4a0e-b444-a2174eeeeead/sist-ts-cen-ts-16650-2014

1 Scope

This Technical Specification specifies requirements for couplings of 2 in (50.8 mm), $2\frac{1}{2}$ in (63.5 mm), 3 in (76.2 mm) and 4 in (101.6 mm) nominal sizes with ribbed tails and hexagons for use at pressures not exceeding 1.550 kN/m^2 (225 lbf/in²). For assembly of coupling, see Figure 1.

This document is applicable to couplings which have been designed primarily for aircraft refuelling purposes, but they may also be used for other general purposes.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1982:1998, Copper and copper alloys — Ingots and castings

EN ISO 228-1, Pipe threads where pressure-tight joints are not made on the threads - Part 1: Dimensions, tolerances and designation (ISO 228-1)

EN ISO 228-2, Pipe threads where pressure-tight joints are not made on the threads - Part 2: Verification by means of limit gauges (ISO 228-2)

BS 1936-1, Undercuts and runouts for screw threads. Inch screw threads

BS 1936-2, Undercuts and runouts for screw threads. Metric screw threads (Standards.iteh.ai)

BS 2751, General purpose acrylonitrile-butadiene rubber compounds. Specification

SIST-TS CEN/TS 16650:2014

BS 3643-2:2007, ISO metric screw threads - Specification for selected limits of size 444

a2174eeeeead/sist-ts-cen-ts-16650-2014

3 Information to be supplied by the purchaser

It is essential that the purchaser states in the enquiry and order, the form of screw thread required (see Clause 8).

4 Designation of sizes of couplings

The size by which the coupling is designated shall be the nominal bore of the hose with which it is to be used.

5 Materials

The material used in the manufacture of the couplings shall be as follows:

- a) Gunmetal castings conforming to Specification CC 491 K of EN 1982:1998
- b) Brass castings conforming to Specification CC 750 S of EN 1982:1998

6 Dimensions

The dimensions of couplings and union nuts shall conform to those shown on Figure 2, Figure 3 and Figure 4 and in Table 1, Table 2 and Table 3.

NOTE The illustrations in this Technical Specification are diagrammatic only, and are solely for the purpose of indicating where the specified dimensions apply.

7 Coupling finish

The couplings shall be machined all over including the bores. All burrs and sharp edges shall be removed.

8 Screw threads

The coupling assembly is given in Figure 1.

The couplings shall be screwed with either:

- a) Whitworth BSP threads. The threads on the liner of the union nut (Figure 4 and Table 3) parallel threads as specified in EN ISO 228-1 and EN ISO 228-2. Thread undercuts shall conform to BS 1936-1.
- b) Metric threads. The threads on the liner of the union nut (Figure 5 and Table 4) shall conform to BS 3643-2:2007, Table 4, Tolerance class 6H (medium fit) and BS 3643-2:2007, Table 5, Tolerance class 6g (medium fit). Thread undercuts shall conform to BS 1936-2

It is essential that the purchaser states in the enquiry and order which threads are required.

9 Washers

Washers shall be made of specially selected leather or synthetic rubber in accordance with BS 2751.

10 Bonding iTeh STANDARD PREVIEW

The couplings shall be fitted to the hose so that the electrical bonding, as specified in the relevant standard, is maintained for the hose assembly.

11 Hydrostatic test SIST-TS CEN/TS 16650:2014 https://standards.iteh.ai/catalog/standards/sist/dbbc8f6e-9783-4a0e-b444-

All couplings, when assembled without hose, shall be subjected to a hydrostatic test of 3 100 kN/m² (450 lbf/in²). The test shall be applied after all machining operations have been completed. This test is for the purpose of locating flaws in the material after machining, and also to test the merits of the joint.

When couplings are being assembled for the hydrostatic test, only the appropriate standard wrench or spanner shall be used in tightening them. Use shall not be made of an extension on the handle of the wrench or spanner, or of other means to produce excessive tightness.


Couplings conforming to this Technical Specification shall not show signs of leakage during this test by reason either of a defective joint or of other defects.

12 Identification marking

Each set of couplings shall be legibly and permanently marked with:

- a) the manufacturer's identification;
- b) the number and date of this Technical Specification;
- c) the following letters to indicate the type of screw thread on the couplings;
 - 1) BSP for threads conforming to EN ISO 228-1 or EN ISO 228-2;
 - 2) METRIC for threads conforming to BS 3643-2;
- d) the reference of the material type;


e) the nominal size.



Key

- 1 tail end: Male (see Figure 2)
- 2 union nut (see Figure 4)
- 3 screwed liner (see Figure 5)
- 4 tail end: Female (see Figure 3)eh STANDARD PREVIEW

(standards.iteh.ai) Figure 1 — Assembly of coupling



Key

1 Whitworth (BSP) thread (see EN ISO 228-1 and EN ISO 228-2)

Figure 2 — Tail end: male (Machine all over)

Nominal	Screw thread A_X	<i>B</i> dia.	C dia.	<i>D</i> dia.	G	G ₁	Н	S	W Hexagon
size of coupling i.e. hose	BSP thread	+0,25	0 -0,25	+0,25 0	±0,25	±0,75	±0,75	Min.	0 -0,25
bore in	Nominal size in	mm	mm	mm	mm	mm	mm	mm	mm
2	2	54	44,5	49,0	69,75	13	22	22	75
2½	2½	66,5	57	62	76	13	25	25	90
3	3	79,25	69,75	74,5	89	13	32	29	105
4	4	106,25	92	98	101,5	13	38	29	130

Table 1 — Tail-end: male - hexagon (see Figure 2)




Figure 3 — Tail-end: Female (Machine all over)

Table 2 — Tail-end: female (see Figure 3)

	B dia.	C dia.	D dia.	F	Н	L ₂ dia.	V
Nominal size of coupling i.e. hose bore	0 -0,25	0 -0,25	+0,25 0	Min.	±0,75	0 -0,25	
in	mm	mm	mm	mm	mm	mm	mm
2	54	44,5	49	90	22	62	19
21/2	66,5	57	62	97	25	78	21
3	79,25	69,75	74,5	111	32	90	22
4	106,25	92	98	125	38	117	24