



**INTERNATIONAL STANDARD ISO 14520-2:2000**  
**TECHNICAL CORRIGENDUM 1**

Published 2001-10-15

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

**Gaseous fire-extinguishing systems — Physical properties and system design —**

**Part 2:**  
**CF<sub>3</sub>I extinguishant**

**TECHNICAL CORRIGENDUM 1**

*Systèmes d'extinction d'incendie utilisant des agents gazeux — Propriétés physiques et conception des systèmes —*

*Partie 2: Agent extincteur CF<sub>3</sub>I*

*RECTIFICATIF TECHNIQUE 1*

**iteh STANDARD PREVIEW**  
**(standards.iteh.ai)**  
<https://standards.iteh.ai/catalog/standards/sist/74592e1b-6ca3-4dee-95dd-5df9b80a281d/iso-14520-2-2000-cor-1-2001>

Technical Corrigendum 1 to International Standard ISO 14520-2:2000 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 8, *Gaseous media fire extinguishing systems*.

*Page 4, Table 5*

For the fuel entitled “Propane”, in the third column under the minimum design concentration replace “4,3” with “3,9”.