



# SLOVENSKI STANDARD

## SIST ISO 9972:2012

01-februar-2012

---

### Toplotne značilnosti stavb - Ugotavljanje tesnosti obodnih konstrukcij - Metoda tlačne razlike z uporabo ventilatorja

Thermal performance of buildings - Determination of air permeability of buildings - Fan pressurization method

### iTeh STANDARD PREVIEW

Performance thermique des bâtiments - Détermination de la perméabilité à l'air des bâtiments - Méthode de pressurisation par ventilateur

[SIST ISO 9972:2012](https://standards.iteh.ai/catalog/standards/sist/3afad2e3-a420-4578-85ff-224cb591c734/sist-iso-9972-2012)

Ta slovenski standard je istoveten z: **ISO 9972:2006**

---

#### **ICS:**

91.120.10      Toplotna izolacija stavb      Thermal insulation

**SIST ISO 9972:2012**

**en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST ISO 9972:2012

<https://standards.iteh.ai/catalog/standards/sist/3afad2e3-a420-4578-85ff-224cb591c734/sist-iso-9972-2012>

---

---

**Thermal performance of buildings —  
Determination of air permeability of  
buildings — Fan pressurization method**

*Performance thermique des bâtiments — Détermination de la  
perméabilité à l'air des bâtiments — Méthode de pressurisation par  
ventilateur*

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST ISO 9972:2012](https://standards.iteh.ai/catalog/standards/sist/3afad2e3-a420-4578-85ff-224cb591c734/sist-iso-9972-2012)

[https://standards.iteh.ai/catalog/standards/sist/3afad2e3-a420-4578-85ff-  
224cb591c734/sist-iso-9972-2012](https://standards.iteh.ai/catalog/standards/sist/3afad2e3-a420-4578-85ff-224cb591c734/sist-iso-9972-2012)



## ISO 9972:2006(E)

**PDF disclaimer**

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST ISO 9972:2012](https://standards.iteh.ai/catalog/standards/sist/3afad2e3-a420-4578-85ff-224cb591c734/sist-iso-9972-2012)

<https://standards.iteh.ai/catalog/standards/sist/3afad2e3-a420-4578-85ff-224cb591c734/sist-iso-9972-2012>

© ISO 2006

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

## Contents

Page

|  |    |
|--|----|
| Foreword.....  | iv |
| Introduction .....   | v  |
| 1 Scope .....  | 1  |
| 2 Normative references .....   | 1  |
| 3 Terms, definitions and symbols .....   | 1  |
| 4 Apparatus .....  | 3  |
| 5 Measurement procedure .....  | 4  |
| 6 Expression of results .....  | 8  |
| 7 Test report .....  | 12 |
| 8 Uncertainty .....  | 13 |
| Annex A (informative) Description of equipment used to pressurize buildings.....                       | 14 |
| Annex B (informative) Dependence of air density on temperature, dew point and barometric pressure..... | 16 |
| Annex C (informative) Recommended procedure for estimating uncertainty in derived quantities .....     | 17 |
| Annex D (informative) Beaufort scale for wind force (extract) .....                                    | 20 |

SIST ISO 9972:2012

<https://standards.iteh.ai/catalog/standards/sist/3afad2e3-a420-4578-85ff-224cb591c734/sist-iso-9972-2012>

## ISO 9972:2006(E)

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 9972 was prepared by Technical Committee ISO/TC 163, *Thermal performance and energy use in the built environment*, Subcommittee SC 1, *Test and measurement methods*.

This second edition cancels and replaces the first edition (ISO 9972:1996), which has been technically revised.

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST ISO 9972:2012  
<https://standards.iteh.ai/catalog/standards/sist/3afad2e3-a420-4578-85ff-224cb591c734/sist-iso-9972-2012>

## Introduction

The fan-pressurization method is intended to characterize the air permeability of the building envelope or parts thereof. It can be used

- a) to measure the air permeability of a building or part thereof for compliance with a design air-tightness specification;
- b) to compare the relative air permeability of several similar buildings or parts of buildings;
- c) to identify the leakage sources;
- d) to determine the air-leakage reduction resulting from individual retrofit measures applied incrementally to an existing building or part of building.

The fan-pressurization method is suitable for the respective diagnostic purposes. Although the air infiltration and exfiltration cannot be measured directly, the results of this method can also be used to estimate with adequate precision by means of calculation both the mean infiltration through unintended leakages and the mean air flow through intended air flow devices from outside, in relation to the pressure conditions to be expected within the building.

This method does not measure the air-infiltration rate of a building. The results of the fan-pressurization test can be used to estimate the air infiltration by means of calculation. Other methods are applicable when it is desired to obtain a direct measurement of the air infiltration rate. It is better to use the fan-pressurization method for diagnostic purposes and measure the actual infiltration rate with tracer gas methods. A single tracer gas measurement gives limited information on the performance of ventilation and infiltration of buildings.

This method applies to measurements of air flow through the construction from outside to inside or vice versa. It does not apply to air flow measurements from outside through the construction and from other places within the construction back to outside.

The proper use of this International Standard requires a knowledge of the principles of air flow and pressure measurements. Ideal conditions for the test described in this standard are small temperature differences and low wind speeds. For tests conducted in the field, it needs to be recognized that field conditions can be less than ideal. Nevertheless, strong winds and large indoor-outdoor temperature differences should be avoided.

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST ISO 9972:2012

<https://standards.iteh.ai/catalog/standards/sist/3afad2e3-a420-4578-85ff-224cb591c734/sist-iso-9972-2012>



# Thermal performance of buildings — Determination of air permeability of buildings — Fan pressurization method

## 1 Scope

This International Standard is intended for the measurement of the air permeability of buildings or parts of buildings in the field. It specifies the use of mechanical pressurization or depressurization of a building or part of a building. It describes the measurement of the resulting air flow rates over a range of indoor-outdoor static pressure differences.

This International Standard is intended for the measurement of the air leakage of building envelopes of single-zone buildings. For the purpose of this International Standard, many multi-zone buildings can be treated as single-zone buildings by opening interior doors or by inducing equal pressures in adjacent zones.

It does not address evaluation of air permeability through individual components.

## 2 Normative references

iTeh STANDARD PREVIEW  
(standards.iteh.ai)

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 6781, *Thermal Insulation — Qualitative detection of thermal irregularities in building envelopes — Infrared method*

ISO 7345, *Thermal Insulation — Physical quantities and definitions*

ISO 13790:2004, *Thermal performance of buildings — Calculation of energy use for space heating and cooling*

## 3 Terms, definitions and symbols

### 3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 7345 and the following apply.

#### 3.1.1

##### **air leakage rate**

air flow rate across the building envelope

NOTE This movement includes flow through joints, cracks and porous surfaces, or a combination thereof, induced by the air-moving equipment used in this standard (see Clause 4).

#### 3.1.2

##### **internal volume**

deliberately heated, cooled or mechanically ventilated space within a building or part of a building subject to the measurement, generally not including the attic space, basement space and attached structures

## ISO 9972:2006(E)

## 3.1.3

**building envelope**

boundary or barrier separating the internal volume subject to the test from the outside environment or another part of the building

## 3.1.4

**air change rate at reference pressure**

air leakage rate per internal volume at the reference pressure difference across the building envelope

NOTE The reference pressure is usually 50 Pa.

## 3.1.5

**air permeability**

air leakage rate per envelope area at the reference pressure difference across the building envelope

NOTE The reference pressure is usually 50 Pa.

## 3.1.6

**specific leakage rate**

air leakage rate per net floor area at the reference pressure difference across the building envelope

NOTE A pressure difference of 50 Pa is the most common.

## 3.1.7

**leakage area**

area corresponding to air leakage rate at the reference pressure difference across the building envelope

NOTE A pressure difference of 10 Pa is the most common.

## 3.1.8

**specific leakage area**

leakage area per net floor area or envelope area at the test reference pressure difference across the building envelope

## 3.2 Symbols

| Symbol           | Quantity                            | Unit                                    |
|------------------|-------------------------------------|---|
| $a_{10}$         | specific leakage area at 10 Pa      | $\text{m}^2/\text{m}^2$                 |
| $A_E$            | envelope area                       | $\text{m}^2$                            |
| $A_F$            | floor area                          | $\text{m}^2$                            |
| $A_L$            | leakage area                        | $\text{m}^2$                            |
| $C_{\text{env}}$ | air flow coefficient                | $\text{m}^3/(\text{h}\cdot\text{Pa}^n)$ |
| $C_L$            | air leakage coefficient             | $\text{m}^3/(\text{h}\cdot\text{Pa}^n)$ |
| $n_{50}$         | air change rate at 50 Pa            | $\text{h}^{-1}$                         |
| $p$              | pressure                            | Pa                                      |
| $p_{\text{bar}}$ | uncorrected barometric pressure     | Pa                                      |
| $p_v$            | partial vapour pressure of water    | Pa                                      |
| $p_{\text{vs}}$  | saturation vapour pressure of water | Pa                                      |
| $Q$              | tracer gas injection rate           | $\text{m}^3/\text{h}$                   |
| $q_{50}$         | air permeability at 50 Pa           | $\text{m}^3/\text{h}$                   |
| $q_{a50}$        | air permeability                    |   |

| Symbol                           | Quantity  | Unit                                |
|----------------------------------|---|-------------------------------------|
| $q_{env}$                        | air flow rate through the building envelope   | m <sup>3</sup> /h                   |
| $q_{env,s}$                      | air flow rate through the building envelope   | m <sup>3</sup> /s                   |
| $q_{L50}$                        | air leakage rate at 50 Pa   | m <sup>3</sup> /h                   |
| $q_m$                            | measured air flow rate  | m <sup>3</sup> /h                   |
| $q_{p50}$                        | air permeability at 50 Pa   | m <sup>3</sup> /(h·m <sup>2</sup> ) |
| $q_{pr}$                         | air leakage rate at a specified reference pressure difference                         | m <sup>3</sup> /h                   |
| $q_r$                            | readings of air flow rate   | m <sup>3</sup> /h                   |
| $V$                              | internal volume   | m <sup>3</sup>                      |
| $w_{50}$                         | specific leakage rate at 50 Pa  | m <sup>3</sup> /(h·m <sup>2</sup> ) |
| $\Delta p$                       | induced pressure difference   | Pa                                  |
| $\Delta p_0$                     | zero flow pressure difference (average)   | Pa                                  |
| $\Delta p_{0,1}; \Delta p_{0,2}$ | zero-flow pressure difference before and after the test (air moving equipment closed) | Pa                                  |
| $\Delta p_m$                     | measured pressure difference  | Pa                                  |
| $\Delta p_r$                     | reference pressure  | Pa                                  |
| $\Phi$                           | relative humidity   | –                                   |
| $T$                              | absolute temperature  | K                                   |
| $T_e$                            | external air absolute temperature   | K                                   |
| $T_{int}$                        | internal air absolute temperature   | K                                   |
| $\rho$                           | air density   | kg/m <sup>3</sup>                   |
| $\rho_e$                         | external air density  | kg/m <sup>3</sup>                   |
| $\rho_{int}$                     | internal air density  | kg/m <sup>3</sup>                   |

## 4 Apparatus

### 4.1 General

The following description of apparatus is general in nature. Any arrangement of equipment using the same principles and capable of performing the test procedure within the allowable tolerances is permitted. Examples of equipment configurations commonly used are indicated in Annex A.

Periodic calibration of the measurement system, used in this test method, according to manufacturer specifications or to standardized quality insurance systems is required.

### 4.2 Equipment

#### 4.2.1 Air-moving equipment

This includes any device that is capable of inducing a specific range of positive and negative pressure differences across the building envelope or part thereof. The system shall provide a constant air flow at each pressure difference for the period required to obtain readings of air flow rate.