



SLOVENSKI STANDARD
SIST IEC 60364-5-55:2006

01-september-2006

9`Y_f] bY]býHJUMY`n[fUXV'!) !)) "XY.'`nV]fU]b`bUa Ygh]Hj `YY_f] bY`cdfYa Y!
8 fi [UcdfYa U

Electrical installations of buildings - Part 5-55: Selection and erection of electrical equipment - Other equipment

iTeh STANDARD PREVIEW

Installations électriques des bâtiments - Partie 5-55: Choix et mise en oeuvre des matériels électriques - Autres matériels

[SIST IEC 60364-5-55:2006](https://standards.iteh.ai/catalog/standards/sist/5c6a2aea-b49d-4ce0-aaf2-65adda0259f1/sist-iec-60364-5-55-2006)

Ta slovenski standard je istoveten z: **IEC 60364-5-55**

ICS:

91.140.50 Sistemi za oskrbo z elektriko Electricity supply systems

SIST IEC 60364-5-55:2006

en

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

SIST IEC 60364-5-55:2006

<https://standards.iteh.ai/catalog/standards/sist/5c6a2aea-b49d-4ce0-aa2-65adda0259f1/sist-iec-60364-5-55-2006>

NORME
INTERNATIONALE

CEI
IEC

INTERNATIONAL
STANDARD

60364-5-55

Première édition
First edition
2001-08

Installations électriques des bâtiments –

Partie 5-55:

Choix et mise en œuvre des matériels électriques –
Autres matériels

iTeh STANDARD PREVIEW

Electrical installations of buildings –
(standards.iteh.ai)

Part 5-55:

<http://standards.iteh.ai/catalog/standards/sist/iec-60364-5-55-2006>
Selection and erection of electrical equipment –
Other equipment

© IEC 2001 Droits de reproduction réservés — Copyright - all rights reserved

Aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'éditeur.

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission
Telefax: +41 22 919 0300

3, rue de Varembe Geneva, Switzerland
e-mail: inmail@iec.ch IEC web site <http://www.iec.ch>



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE

Q

Pour prix, voir catalogue en vigueur
For price, see current catalogue

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

SIST IEC 60364-5-55:2006

<https://standards.iteh.ai/catalog/standards/sist/5c6a2aea-b49d-4ce0-aaf2-65adda0259f1/sist-iec-60364-5-55-2006>

CONTENTS

FOREWORD	5
550 Introduction	7
550.1 Scope	7
550.2 Normative references	7
551 Low-voltage generating set	9
551.1 Scope	9
551.2 General requirements	11
551.3 Protection against both direct and indirect contact	11
551.4 Protection against indirect contact	13
551.5 Protection against overcurrent	15
551.6 Additional requirements for installations where the generating set provides a supply as a switched alternative to the public supply (stand-by systems)	15
551.7 Additional requirements for installations where the generating set may operate in parallel with the public supply system	17
556 Safety services	17
559 Luminaires and lighting installations	23
Annex A (informative) IEC 60364 – (Parts 1 to 6: Restructuring)	27
Bibliography	35
Table A.1 – Relationship between restructured and original parts	27
Table A.2 – Relationship between new and old clause numbering	31

ITIEH STANDARD PREVIEW

(standards.itech.ai)

SIST IEC 60364-5-55:2006

[https://standards.itech.ai/catalog/standards/sist/5c6a2aea-b49d-4ce0-aaf2-](https://standards.itech.ai/catalog/standards/sist/5c6a2aea-b49d-4ce0-aaf2-65adda0259f1/sist-iec-60364-5-55-2006)

[65adda0259f1/sist-iec-60364-5-55-2006](https://standards.itech.ai/catalog/standards/sist/5c6a2aea-b49d-4ce0-aaf2-65adda0259f1/sist-iec-60364-5-55-2006)

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL INSTALLATIONS OF BUILDINGS – Part 5-55: Selection and erection of electrical equipment – Other equipment

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60364-5-55 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

The IEC 60364 series (parts 1 to 6), is currently being restructured, without any technical changes, into a more simple form (see annex A).

According to a unanimous decision by the Committee of Action (CA/1720/RV (2000-03-21)), the restructured parts of IEC 60364 have not been submitted to National Committees for approval.

The text of this first edition of IEC 60364-5-55 is compiled from and replaces

- part 5-551, first edition (1994),
- part 5-559, first edition (1999),
- part 5-56, first edition (1980) and its amendment 1 (1998), and
- part 3, second edition (1993), its amendment 1 (1994) and its amendment 2 (1995).

This publication has been drafted, as close as possible, in accordance with the ISO/IEC Directives, Part 3.

Annex A is for information only.

The committee has decided that the contents of this publication will remain unchanged until 2001. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

ELECTRICAL INSTALLATIONS OF BUILDINGS –

Part 5-55: Selection and erection of electrical equipment – Other equipment

550 Introduction

550.1 Scope

This part of IEC 60364 covers requirements for low-voltage generating sets. Particular requirements for supplies for safety services are given in clause 556 while clause 559 applies to the selection and erection of luminaires and lighting installations intended to be part of the fixed installation.

NOTE Requirements of the public supply undertaking should be ascertained before a generating set is installed in an installation which is connected to the public supply.

550.2 (551.1.2)(559.2) Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of IEC 60364. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this part of IEC 60364 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of IEC and ISO maintain registers of currently valid International Standards.

IEC 60050(195):1998, *International Electrotechnical Vocabulary – Part 195: Earthing and protection against electric shock*

IEC 60050(826):1982, *International Electrotechnical Vocabulary – Part 826: Electrical installations of buildings*

IEC 60079 (all parts), *Electrical apparatus for explosive gas atmospheres*

IEC 60245-3:1994, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 3: Heat resistant silicone insulated cables*

IEC 60364-4-41:2001, *Electrical installations of buildings – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-4-42:2001, *Electrical installations of buildings – Part 4-42: Protection for safety – Protection against thermal effects*

IEC 60364-4-43:2001, *Electrical installations of buildings – Part 4-43: Protection for safety – Protection against overcurrent*

IEC 60364-5-52:2001, *Electrical installations of buildings – Part 5-52: Selection and erection of electrical equipment – Wiring systems*

IEC 60364-5-53:2001, *Electrical installations of buildings – Part 5-53: Selection and erection of electrical equipment – Isolation, switching and control*

IEC 60364-5-54:1980, *Electrical installations of buildings – Part 5: Selection and erection of electrical equipment – Chapter 54: Earthing arrangements and protective conductors*¹⁾

IEC 60364-7-713:1996, *Electrical installations of buildings – Part 7-713: Requirements for special installations and locations – Furniture*

IEC 60364-7-714:1996, *Electrical installations of buildings – Part 7-714: Requirements for special installations and locations – External lighting installations*

IEC 60364-7-715:1999, *Electrical installations of buildings – Part 7-715: Requirements for special installations and locations – Extra-low voltage lighting installations*

IEC 60417 (all parts), *Graphical symbols for use on equipment*

IEC 60598 (all parts), *Luminaires*

551 Low-voltage generating set

551.1 (551.1.1.1) Scope

This part 5-55 of IEC 60364 applies to low-voltage and extra-low voltage installations which incorporate generating sets intended to supply, either continuously or occasionally, all or part of the installation. Requirements are included for installation with the following supply arrangements:

- supply to an installation which is not connected to the public supply;
- supply to an installation as an alternative to the public supply;
- supply to an installation in parallel with the public supply;
- appropriate combinations of the above.

This part does not apply to self-contained items of extra-low voltage electrical equipment which incorporate both the source of energy and the energy-using load and for which a specific product standard exists that includes the requirements for electrical safety.

551.1.1 (551.1.1.2) Generating sets with the following power sources are considered:

- combustion engines;
- turbines;
- electric motors;
- photovoltaic cells;
- electrochemical accumulators;
- other suitable sources.

551.1.2 (551.1.1.3) Generating sets with the following electrical characteristics are considered:

- mains-excited and separately excited synchronous generators;
- mains-excited and self-excited asynchronous generators;
- mains-commutated and self-commutated static inverters with or without by-pass facilities.

¹⁾ Currently being revised under the modified title "*Electrical installations of buildings – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements and protective conductors and equipotential bonding*"

551.1.3 (551.1.1.4) The use of generating sets for the following purposes is considered:

- supply to permanent installations;
- supply to temporary installations;
- supply to portable equipment which is not connected to a permanent fixed installation.

551.2 General requirements

551.2.1 The means of excitation and commutation shall be appropriate for the intended use of the generating set and the safety and proper functioning of other sources of supply shall not be impaired by the generating set.

NOTE See 551.7 for particular requirements where the generating set may operate in parallel with a public supply.

551.2.2 The prospective short-circuit current and prospective earth fault current shall be assessed for each source of supply or combination of sources which can operate independently of other sources or combinations. The short-circuit rating of protective devices within the installation and, where appropriate, connected to the public supply network, shall not be exceeded for any of the intended methods of operation of the sources.

551.2.3 Where the generating set is intended to provide a supply to an installation which is not connected to the public supply or to provide a supply as a switched alternative to the public supply, the capacity and operating characteristics of the generating set shall be such that danger or damage to equipment does not arise after the connection or disconnection of any intended load as a result of the deviation of the voltage or frequency from the intended operating range. Means shall be provided to automatically disconnect such parts of the installation as may be necessary if the capacity of the generating set is exceeded.

NOTE 1 Attention should be given to the size of individual loads as a proportion of the capacity of the generating set and to motor starting currents.

NOTE 2 Attention should be given to the power factor specified for protective devices in the installation.

NOTE 3 The installation of a generating set within an existing building or installation may change the conditions of external influence for the installation (see IEC 60364-1), for example by the introduction of moving parts, parts at high temperature or by the presence of noxious gases, etc.

551.3 Protection against both direct and indirect contact

Additional requirements for extra-low voltage (ELV) systems which provide protection against both direct and indirect contact and where the installation is supplied from more than one source.

551.3.1 Where a SELV or PELV system may be supplied by more than one source, the requirements of 411.1.2 of IEC 60364-4-41 shall apply to each source. Where one or more of the sources is earthed, the requirements of 411.1.3 and 411.1.5 of IEC 60364-4-41 for PELV systems shall apply.

If one or more of the sources does not meet the requirements of 411.1.2, the system shall be treated as a FELV system and the requirements of 411.3 shall apply.

551.3.2 Where it is necessary to maintain the supply to an extra-low voltage system following the loss of one or more sources of supply, each source of supply or combination of sources of supply which can operate independently of other sources or combinations shall be capable of supplying the intended load of the extra-low voltage system. Provisions shall be made so that the loss of low-voltage supply to an extra-low voltage source does not lead to danger or damage for other extra-low voltage equipment.

NOTE Such precautions may be necessary in supplies for safety services (see clause 35 of IEC 60364-1).

551.4 Protection against indirect contact

Protection against indirect contact shall be provided for the installation in respect of each source of supply or combination of sources of supply which can operate independently of other sources or combinations of sources.

551.4.1 Protection by automatic disconnection of supply

Protection by automatic disconnection of supply shall be provided in accordance with 413.1 of IEC 60364-4-41, except as modified for particular cases by 551.4.2, 551.4.3 or 551.4.4.

551.4.2 Additional requirements for installations where the generating set provides a switched alternative to the public supply (stand-by systems)

Protection by automatic disconnection of supply shall not rely upon the connection to the earthed point of the public supply system when the generator is operating as a switched alternative to a TN system. A suitable earth electrode shall be provided.

551.4.3 Additional requirements for installations incorporating static inverters

551.4.3.1 Where protection against indirect contact for parts of the installation supplied by the static inverter relies upon the automatic closure of the by-pass switch and the operation of protective devices on the supply side of the by-pass switch is not within the time required by 413.1 of IEC 60364-4-41, supplementary equipotential bonding shall be provided between simultaneous accessible exposed conductive parts and extraneous conductive parts on the load side of the static inverter in accordance with 413.1.6 of IEC 60364-4-41.

The resistance of supplementary equipotential bonding conductors required between simultaneously accessible conductive parts shall fulfil the following condition:

$$R \leq \frac{50}{I_a}$$

where

I_a is the maximum earth fault current which can be supplied by the static inverter alone for a period of up to 5 s.

NOTE Where such equipment is intended to operate in parallel with a public supply system, the requirements of 551.7 also apply.

551.4.3.2 Precautions shall be taken or equipment shall be selected so that the correct operation of protective devices is not impaired by d.c. currents generated by a static inverter or by the presence of filters.

551.4.4 Additional requirements for protection by automatic disconnection where the installation and generating set are not permanently fixed

This subclause applies to portable generating sets and to generating sets which are intended to be moved to unspecified locations for temporary or short-term use. Such generating sets may be part of an installation which is subject to similar use. This subclause does not apply to permanent fixed installations.

NOTE For suitable connection arrangements see IEC 60309.

551.4.4.1 Between separate items of equipment protective conductors shall be provided which are part of a suitable cord or cable and which comply with table 54F of IEC 60364-5-54. All protective conductors shall comply with IEC 60364-5-54.

551.4.4.2 In TN, TT and IT systems a residual current protective device with a rated residual operating current of not more than 30 mA shall be installed in accordance with 413.1 of IEC 60364-4-41 to provide automatic disconnection.

NOTE In IT systems, a residual current device may not operate unless one of the earth faults is on a part of the system on the supply side of the device.

551.5 Protection against overcurrent

551.5.1 Where means of detecting overcurrent of the generating set is provided, this shall be located as near as practicable to the generator terminals.

NOTE The contribution to the prospective short-circuit current by a generating set may be time-dependent and may be much less than the contribution made by a public supply.

551.5.2 Where a generating set is intended to operate in parallel with a public supply, or where two or more generating sets may operate in parallel, circulating harmonic currents shall be limited so that the thermal rating of conductors is not exceeded.

The effects of circulating harmonic currents may be limited as follows:

- the selection of generating sets with compensated windings;
- the provision of a suitable impedance in the connection to generator star points;
- the provision of switches which interrupt the circulatory circuit but which are interlocked so that at all times protection against indirect contact is not impaired;
- the provision of filtering equipment;
- other suitable means.

NOTE Consideration should be given to the maximum voltage which may be produced across an impedance connected to limit circulating harmonics.

551.6 Additional requirements for installations where the generating set provides a supply as a switched alternative to the public supply (stand-by systems)

551.6.1 Precautions complying with the relevant requirements of IEC 60364-5-53 for isolation shall be taken, so that the generator cannot operate in parallel with the public supply system. Suitable precautions may include:

- an electrical, mechanical or electro-mechanical interlock between the operating mechanisms or control circuits of the change-over switching devices;
- a system of locks with a single transferable key;
- a three-position break-before-make change-over switch;
- an automatic change-over switching device with a suitable interlock;
- other means providing equivalent security of operation.