

SLOVENSKI STANDARD SIST EN 13053:2007+A1:2011

01-oktober-2011

Prezračevanje stavb - Klimati - Ocenitev in lastnosti klimatov, sestavnih delov in sekcij

Ventilation for buildings - Air handling units - Rating and performance for units, components and sections

Lüftung von Gebäuden - Zentrale raumlufttechnische Geräte - Leistungskenndaten für Geräte, Komponenten und Baueinheiten ARD PREVIEW

Ventilation des bâtiments - Caissons de traitement d'air - Classification et performance des unités, composants et sections_{IST EN 13053 2007+A1 2011}

https://standards.iteh.ai/catalog/standards/sist/95e97440-d250-44b7-

7844-3b225e3b89a9/sist-en-13053-2007a1-2011 Ta slovenski standard je istoveten z: EN 13053:2006+A1:2011

ICS:

91.140.30 Prezračevalni in klimatski Ventilation and air-

sistemi conditioning

SIST EN 13053:2007+A1:2011 en,fr,de

SIST EN 13053:2007+A1:2011

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 13053:2007+A1:2011

https://standards.iteh.ai/catalog/standards/sist/95e97440-d250-44b7-9844-3b225e3b89a9/sist-en-13053-2007a1-2011

EUROPEAN STANDARD

EN 13053:2006+A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

July 2011

ICS 91.140.30

Supersedes EN 13053:2006

English Version

Ventilation for buildings - Air handling units - Rating and performance for units, components and sections

Ventilation des bâtiments - Caissons de traitement d'air -Classification et performance des unités, composants et sections Lüftung von Gebäuden - Zentrale raumlufttechnische Geräte - Leistungskenndaten für Geräte, Komponenten und Baueinheiten

This European Standard was approved by CEN on 26 June 2006 and includes Amendment 1 approved by CEN on 19 May 2011.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

SIST EN 13053:2007+A1:2011 https://standards.iteh.ai/catalog/standards/sist/95e97440-d250-44b7-

9844-3b225e3b89a9/sist-en-13053-2007a1-2011



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

COII	iterits	Page
Forew	vord	4
1	Scope	
2	Normative references	
3	Terms and definitions	8
4	Symbols and abbreviations	
-	Ratings and performance of the entire air handling unit	
5 5.1	GeneralGeneral	13
5.2	Testing of aerodynamic performance	13
5.2.1	Characteristics and quantities	
5.2.2	Test method	
5.2.3	Measurement procedure	
5.2.4 5.3	Evaluation of results Testing of acoustic performance	
5.3.1	General	
5.3.2	Specific requirements concerning the set-up of acoustic tests	18
5.4	Tolerances	22
5.5	Tolerances Test report Test re	23
6	Ratings and performance of the entire air handling unit	26
6.1	General	20
6.2	Casing	20
6.3	Fan section	28
6.3.1	General https://standards.iten.avcatalog/standards/sist/95e9/440-d250-446/-	28
6.3.2	Power input of fans (4) 02236306989/881-61F13033-200/81-2011	29
6.4 6.4.1	Coils	
6.4.1 6.4.2	General Testing	
6.4.2 6.4.3	Construction	
6.4.4	Cooler/Droplet Eliminator	
6.5	Heat recovery sections	3
6.5.1	General	
6.5.2	Classifications and requirements	
6.5.3	Testing	
6.6 6.6.1	Damper sections	
6.6.2	Requirements and testing	
6.7	Mixing sections	
6.7.1	General	
6.7.2	Categories and characteristics	
6.7.3	Requirements	
6.7.4	Measurements	
6.7.5 6.8	Field testing of mixing efficiency	
6.8.1	General	
6.8.2	Categories	
6.8.3	Requirements	
6.9	Filter sections	
6.9.1	General requirements	
6.9.2	Filters installed in air handling units	
6.10	Passive sound attenuation sections	
7	Extended hygiene requirements for special applications	11

7.1	General	4J
7.2	Accessibility	43
7.3	Smoothness	
7.4	Inspection windows and lights	
7.5	Drainage/prevention of condensation, humidifiers	44
7.6	Air leakage	44
_	•	
8	Instructions for installation, operation and maintenance	
8.1	Installation	
8.2	Operation and maintenance	
8.3	Documentation and labelling	45
Annex	A (informative) Air handling units - Heat recovery – Defrosting - Requirements and	
,	testing	46
A.1	General	
A.2	Defrosting	
A.2.1	Defrosting heat factor	
A.2.2	Non-cyclic defrosting	
A.2.3	Cyclic defrosting	
A.3	Testing	
A.3.1	Test rig	
A.3.2	Duty points	
A.3.3	Test procedures	
A.3.4	Testing of defrosting heat factor	
A.3.5	Total measuring time	
A.4	Test report	
A.4.1		
A.4.2	The heat recovery device The defrosting heat factor ANDARD PREVIEW	7 3
Annex	B (informative) Air handling units - Heat recovery - Characteristics 4	50
B.1	Efficiency of the heat recovery	50
B.2	Evaluation	52
B.3	Evaluation of auxiliary energies	52
B.4	Evaluation	52
B.5	Efficiency	53
B.6	View of yearly energy	53
Biblio	graphy	E 4
שוטווטום	/I apily	54

Foreword

This document (EN 13053:2006+A1:2011) has been prepared by Technical Committee CEN/TC 156 "Ventilation for buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2012, and conflicting national standards shall be withdrawn at the latest by January 2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.


This document supersedes A EN 13053:2006 A.

This document includes Amendment 1, approved by CEN on 2011-05-19.

The start and finish of text introduced or altered by amendment is indicated in the text by tags [A].

This European Standard is a part of a series of standards for air handling units used for ventilation and air conditioning of buildings for human occupancy. It considers the ratings and the performance of air handling units as a whole, the requirements and performance of specific components and sections of air handling units including hygiene requirements. The position of this standard in the field of mechanical building services is shown in Figure 1.

According to the CEN/CENELEC Internal Regulations, the hational standards organizations of the following countries are bound to implement this European Standard Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark Estonia, Finland France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 13053:2007+A1:2011

https://standards.iteh.ai/catalog/standards/sist/95e97440-d250-44b7-

Figure 1 — Position of this standard in the field of mechanical building services

1 Scope

This European Standard specifies requirements and testing for ratings and performance of air handling units as a whole. It also specifies requirements, recommendations, classification, and testing of specific components and sections of air handling units. For many components and sections it refers to component standards, but it also specifies restrictions or applications of standards developed for stand alone components.

This standard is applicable both to standardised designs, which may be in a range of sizes having common construction concepts, and also to custom-design units. It also applies both to air handling units, which are completely prefabricated, and to units which are built up on site. Generally the units within the scope of this standard include at least a fan, a heat exchanger and an air filter.

This standard is not applicable to the following:

- a) air conditioning units serving a limited area in a building, such as fan coil units;
- b) units for residential buildings;
- c) units producing ventilation air mainly for a manufacturing process.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 308, Heat exchangers — Test procedures for establishing performance of air to air and flue gases heat recovery devices https://standards.iteh.ai/catalog/standards/sist/95e97440-d250-44b7-9844-3b225e3b89a9/sist-en-13053-2007a1-2011

EN 779, Particulate air filters for general ventilation — Determination of the filtration performance

EN 1216, Heat exchangers — Forced circulation air-cooling and air-heating coils — Test procedures for establishing the performance

EN 1751, Ventilation for buildings — Air terminal devices — Aerodynamic testing of dampers and valves

EN 1886:1998, Ventilation for buildings — Air handling units — Mechanical performance

EN 12792:2003, Ventilation for buildings — Symbols, terminology and graphical symbols

EN 13779, Ventilation for non-residential buildings — Performance requirements for ventilation and room-conditioning systems

EN ISO 3741, Acoustics — Determination of sound power levels of noise sources using sound pressure — Precision methods for reverberation rooms (ISO 3741:1999)

EN ISO 3744, Acoustics — Determination of sound power levels of noise sources using sound pressure — Engineering method in an essentially free field over a reflecting plane (ISO 3744:1994)

EN ISO 3746, Acoustics — Determination of sound power levels of noise sources using sound pressure — Survey method using an enveloping measurement surface over a reflecting plane (ISO 3746:1995)

EN ISO 5136, Acoustics — Determination of sound power radiated into a duct by fans and other airmoving devices — In-duct method (ISO 5136:2003)

SIST EN 13053:2007+A1:2011

EN 13053:2006+A1:2011 (E)

EN ISO 5167-1, Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements (ISO 5167-1:2003)

EN ISO 7235, Acoustics — Laboratory measurement procedures for ducted silencers and air-terminal units — Insertion loss, flow noise and total pressure loss (ISO 7235:2003)

ISO 5221, Air distribution and air diffusion — Rules to methods of measuring air flow rate in an air-handling duct

ISO 5801:1997, Industrial fans — Performance testing using standardized airways

 \fbox{M} ISO 13348 \fbox{M} , Industrial Fans — tolerances, methods of conversion and technical data presentation

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 13053:2007+A1:2011 https://standards.iteh.ai/catalog/standards/sist/95e97440-d250-44b7-9844-3b225e3b89a9/sist-en-13053-2007a1-2011

3 Terms and definitions

For the purposes of this European Standard, the terms and definitions given in EN 12792:2003 and the following apply.

3.1

air handling unit

factory made encased assembly consisting of sections containing a fan or fans and other necessary equipment to perform one or more of the following functions: circulating, filtrating, heating, cooling, heat recovery, humidifying, dehumidifying and mixing air

3.2

section of air handling unit

functional element of an air handling unit consisting of one or more components in a single casing

3.3

component of air handling unit

smallest functional element of an air handling unit

3.4

blow-through unit

air handling unit with a section or sections downstream of the supply air fan

3.5

casing of an air-handling unit STANDARD PREVIEW

enclosure of the unit, within which the components are mounted (standards.iteh.ai)

3.6

openings for outdoor air, supply air, extract air, recirculation air and exhaust air

aperture through which air is taken in or discharged from the air handling unit, such as openings for outdoor air, supply air, recirculation air and exhaust air 13053-2007a1-2011

3.7

damper section

section of air handling unit including a damper or valve

3.8

mixing section

section where e.g. outdoor air flow and the recirculation air flow are mixed in a controlled way. The section generally consists of one damper per air flow and a mixing chamber

3.9

filter section

section including a filter or filters and an associated filterframe

3.10

heat recovery section

section in which heat (and possibly also moisture) is transferred from one airstream into another, either directly or using an intermediary heat transfer medium

3.11

air heating and cooling coils

heat exchangers by means of which heat is transferred from a heat transfer medium to air (heating coil) or the other way round (cooling coil)

3.12

sound attenuation section

section in which sound transfer into a ductwork or into ambient air is reduced

3.13

humidifier section

section in which moisture is added to the air

3.14

fan section

section in which one or more fans are installed for moving air

3 15

combined section

section within which two or more functions are combined

3.16

functions

3.16.1

air treatment

process by which the state of the air is modified with respect to one or more of its characteristics such as temperature, moisture content, dust content, bacterial count, gas and vapour content

3.16.2

air type

designation of air moving through a ventilation, air conditioning or air treatment installation as a function of its location relative to the installation, e.g. outdoor air, exhaust air, extract air etc

3.16.3 iTeh STANDARD PREVIEW

cooling

removal of latent and/or sensible heat and ards.iteh.ai)

3.16.4

SIST EN 13053:2007+A1:2011

dehumidification https://standards.iteh.ai/catalog/standards/sist/95e97440-d250-44b7-controlled reduction of water vapour from the air/sist-en-13053-2007a1-2011

3.16.5

filtration

removal of particulate material from the airstream

3.16.6

heating

transfer of heat from one body or medium to another medium

3.16.7

humidification

controlled addition of water vapour to an air stream or space

3.16.8

sound reduction

controlled reduction of sound energy

3.17

characteristics

3.17.1

air flow

movement of air within set boundaries (such as ducts)

3.17.2

air flow rate

mass or volume flow of air passing a given plane divided by time

3.17.3

bypass factor

ratio of the diverted air flow to the sum of the main air flow and the diverted air flow

3.17.4

bypass leakage

unwanted and uncontrolled passing of untreated air into the treated air between the components within a casing, such as filters and coils

3.17.5

deflection of a casing

deformation in mm of the external surfaces of the enclosure when subjected to a positive (bulging) or negative (caving) pressure. It is given as the measured difference in distance between a reference plane and the maximum point of deflection when subjected to air pressure

3.17.6

defrosting heat factor

ratio between the energy transferred into the air supply and the maximum recoverable energy in exhaust air, excluding the energy input for defrosting

3.17.7

air leakage factor f

air tightness expressed as the air leakage per unit envelope area and pressure difference (external air leakage)

iTeh STANDARD PREVIEW

3.17.8

air leakage rate qvi

air leakage of the air handling unit, subject to air pressure (external air leakage)

3.17.9

external total pressure difference SIST EN 13053:2007+A1:2011

difference between the total pressure at the outlet of the air handling unit and the total pressure at the inlet 9844-3b225e3b89a9/sist-en-13053-2007a1-2011

3.17.10

humidification efficiency

ratio between the mass of water evaporated by the humidifier and the theoretical mass needed to achieve saturation at a given temperature

3.17.11

internal air leakage rate

air leakage in between the two air streams within a section

3.17.12

thermal bridging factor $k_{\rm b}$

ratio between the lowest temperature difference between any point on the external surface and the mean internal air temperature and the mean air to air temperature difference

3.17.13

thermal transmittance U

heat flow per unit of area and temperature difference

4 Symbols and abbreviations

For the purposes of this standard, symbols and units given in EN 12792:2003 and in Table 1 apply together with those defined by the formulae, text and annexes of this standard.

Table 1 — Symbols, terms, units and subscripts

Symbol	Term	Unit
Α	Surface area	m^2
A _c	Cross sectional area of a duct	m^2
С	Sound velocity in the air	$m \times s^{-1}$
d	Effective duct diameter	m
D_{p}	Sound insertion loss	dB
E	Duct end correction value	dB
f	Air leakage factor	$I \times (s \times m^2)^{-1}$
k	Number of measurements within the total measuring time	-
k	Filter bypass leakage factor	%
<i>k</i> _b	Thermal bridging factor of the casing	-
Lp	Sound pressure level TANDARD PREVIEW	dB
L _W	Sound power level (standards.iteh.ai)	dB
L_{WA}	A-weighted sound power 13053:2007+A1:2011 https://gtandards.itch.ni/cetalog/standards/sixt/95e97440.d250.44b7	dB(A)
n _F	Rotational speed of the fan b89a9/sist-en-13053-2007a1-2011	s ⁻¹
P _E	Electrical motor input power	W
p _a	Atmospheric pressure	Pa
$oldsymbol{ ho}_{ extsf{d}}$	Dynamic pressure	Pa
ps	Static pressure	Pa
p_t	Total fan pressure	Pa
p_{tu}	External total pressure difference of the unit	Pa
Q _{defr}	Total energy input for defrosting during one complete frosting/defrosting cycle	J
$p_{\scriptscriptstyle V}$	Partial pressure of water vapour	Pa
q _{mn}	Nominal air mass flow rate of the recovery device	kg × s ⁻¹
q_{m}	Air mass flow rate	kg × s ⁻¹
$q_{\scriptscriptstyle ee}$	Air volume flow rate	$m^3 \times s^{-1}$

Table 1 (continued)

Symbol	Term	Unit
$oldsymbol{q}_{\sf vm}$	Measured and converted air volume flow rate	$\text{m}^3 \times \text{s}^{-1}$
$q_{ m vs}$	Specified air volume flow rate	$\text{m}^3 \times \text{s}^{-1}$
t _a	Dry-bulb temperature	°C
$t_{m,i}$	Local temperature at measurement point	°C
t _i	Mean internal air temperature	°C
t	Tolerance range	%
и	Uncertainty range of measured data	%
U	Range of uniformity of flow after the mixing section	-
U	Thermal transmittance of the casing RD PREVIEW	$W \times (m^2 \times K)^{-1}$
v	Velocity of air at a point and ards.iteh.ai)	$m \times s^{-1}$
х	Absolute humidity SIST EN 13053:2007+A1:2011	g x kg ⁻¹
Δau	Sampling interval time S225e3b89a9/sist-en-13053-2007a1-2011	s
Δp_1	Pressure drop on exhaust-air side	Pa
\mathcal{E}_{D}	Defrosting heat ratio	-
η_{h}	Humidifier efficiency	-
η_{mix}	Mixing efficiency	%
φ	Relative humidity	%
ρ	Density	kg × m ⁻³

Table 1 (concluded)

Subscripts		
1	Inlet	
2	Outlet	
11	Exhaust air in	
12	Exhaust air out	
21	Supply air in	
22	Supply air out	
i	Internal	
Н	Air flow with higher temperature	
L	Air flow with lower temperature	
М	Mixed air flow [mean temperature]	
tot	Air flow downstream of the mixing section PREVIEW	
Abbreviations (standards.iteh.ai)		
HVAC	Heating, ventilation and air conditioning 07+A1:2011 https://standards.iteh.ai/catalog/standards/sist/95e97440-d250-44b7-	

9844-3b225e3b89a9/sist-en-13053-2007a1-2011

5 Ratings and performance of the entire air handling unit

5.1 General

The performance of the entire air handling unit cannot be defined as the sum of the individual components and sections. Hence, the procedures that follow shall be applied to a complete air handling unit. In particular, and under agreed circumstances these procedures can be applied to a part of an air handling unit.

The methods described in 5.2 cover measuring air volume flow together with the external total pressure of the unit and power consumption. By selecting an appropriate test system, these procedures can be extended to include measuring the sound level transmitted from the air handling unit into the ductwork at a known volume flow, as described in 5.3.

5.2 Testing of aerodynamic performance

5.2.1 Characteristics and quantities

5.2.1.1 Characteristics

a) External total pressure difference of the unit/Air volume flow - characteristic. The difference in total pressure between outlet and inlet of the air handling unit related to the air volume flow at the measurement plane.