



SLOVENSKI STANDARD
SIST ISO 7507-1:2006

01-februar-2006

BUZU]b`HY_c]bUZb]dfc]nj cX]ÈI a YfUbYbUj d] b] j U'Ugh] fYnYfj cUfYj `È%'
XY. `ÄGfUdd]b[Ä'a YrcXU

Petroleum and liquid petroleum products -- Calibration of vertical cylindrical tanks -- Part
1: Strapping method

Pétrole et produits pétroliers liquides -- Jaugeage des réservoirs cylindriques verticaux --
Partie 1: Méthode par ceinturage

Ta slovenski standard je istoveten z: ISO 7507-1:2003

ICS:

| | | |
|-----------|-----------------------------------------------|------------------------------------------|
| 75.180.30 | Oprema za merjenje prostornine in merjenje | Volumetric equipment and measurements |
|-----------|-----------------------------------------------|------------------------------------------|

SIST ISO 7507-1:2006

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/53551346-b9a2-4373-8199-ded666d9556/sist-iso-7507-1-2006>

INTERNATIONAL STANDARD

ISO 7507-1

Second edition
2003-12-15

Petroleum and liquid petroleum products — Calibration of vertical cylindrical tanks —

Part 1: Strapping method

*Pétrole et produits pétroliers liquides — Jaugeage des réservoirs
cylindriques verticaux —*

Partie 1: Méthode par ceinturage



Reference number
ISO 7507-1:2003(E)

© ISO 2003

ISO 7507-1:2003(E)

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

ITEH STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/53551346-b9a2-4373-8199-4ef46e6d9556/sist-iso-7507-1-2006>

© ISO 2003

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

| | |
|------------------------------------------------------------------------------------------------------------------------------------|-----------|
| Foreword..... | iv |
| Introduction | v |
| 1 Scope..... | 1 |
| 2 Normative references | 1 |
| 3 Terms and definitions..... | 2 |
| 4 Precautions..... | 5 |
| 5 Equipment..... | 6 |
| 6 General requirements | 7 |
| 7 Circumference measurements..... | 7 |
| 8 Other measurements on tank shell plates..... | 10 |
| 9 Deadwood | 10 |
| 10 Tank bottoms..... | 11 |
| 11 Measurement of tilt | 11 |
| 12 Floating-roof tanks..... | 11 |
| 13 Recalibration | 12 |
| 14 Computation of tank capacity tables — General rules | 12 |
| 15 Form of tank capacity tables | 13 |
| 16 Computation of open capacity | 13 |
| 17 Construction of final tables..... | 17 |
| Annex A (normative) Specification for equipment used in strapping | 23 |
| Annex B (informative) Recommendations for monitoring, checking and verification of tank calibration and capacity table..... | 26 |
| Annex C (informative) Tank calibration data and calculation sheet..... | 32 |
| Annex D (informative) Tank calibration uncertainties | 36 |
| Annex E (informative) Tank shell temperature determination | 47 |
| Annex F (normative) Gauge tape temperature correction | 48 |
| Annex G (informative) Expansion due to liquid head | 50 |
| Annex H (normative) Expansion due to temperature | 58 |
| Annex I (normative) Certificate of calibration..... | 61 |
| Bibliography | 62 |

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

International Standard ISO 7507-1 was prepared by Technical Committee ISO/TC 28, *Petroleum products and lubricants*, Subcommittee SC 3, *Static petroleum measurement*.

This second edition cancels and replaces the first edition (ISO 7507-1:1993). It also cancels and replaces ISO 7507-6:1997, the subject of which is now included in this part of ISO 7507.

ISO 7507 consists of the following parts, under the general title *Petroleum and liquid petroleum products — Calibration of vertical cylindrical tanks*:

- *Part 1: Strapping method*
- *Part 2: Optical-reference-line method*
- *Part 3: Optical-triangulation method*
- *Part 4: Internal electro-optical distance-ranging method*
- *Part 5: External electro-optical distance-ranging method*
- *Part 6: Recommendations for monitoring, checking and verification of tank calibration and capacity table*

Introduction

This part of ISO 7507 forms part of a series on tank calibration including the following:

ISO 7507-2:1993, *Petroleum and liquid petroleum products — Calibration of vertical cylindrical tanks — Part 2: Optical-reference-line method*

ISO 7507-3:1993, *Petroleum and liquid petroleum products — Calibration of vertical cylindrical tanks — Part 3: Optical-triangulation method*

ISO 7507-4:1995, *Petroleum and liquid petroleum products — Calibration of vertical cylindrical tanks — Part 4: Internal electro-optical distance-ranging method*

ISO 7507-5:2000, *Petroleum and liquid petroleum products — Calibration of vertical cylindrical tanks — Part 5: External electro-optical distance-ranging method*

ISO 7507-6:1997, *Recommendations for monitoring, checking and verification of tank calibration and capacity table*

ISO 8311:1989, *Refrigerated light hydrocarbon fluids — Calibration of membrane tanks and independent prismatic tanks in ships — Physical measurement*

ISO 9091-1:1991, *Refrigerated light hydrocarbon fluids — Calibration of spherical tanks in ships — Part 1: Stereo-photogrammetry*

ISO 9091-2:1992, *Refrigerated light hydrocarbon fluids — Calibration of spherical tanks in ships — Part 2: Triangulation measurement*

The strapping method for the calibration of vertical cylindrical tanks has been used for many years and is a recognized method of determining the capacity of storage tanks from measurements of the circumference of a tank at various heights. The strapping method is also often used to establish a reference circumference at a selected height to use as a datum in other methods of tank calibration.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/53551346-b9a2-4373-8199-4e1f6e6d9556/sist-iso-7507-1-2006>

Petroleum and liquid petroleum products — Calibration of vertical cylindrical tanks —

Part 1: Strapping method

1 Scope

1.1 This part of ISO 7507 specifies a method for the calibration of substantially vertical cylindrical tanks by measuring the tank using a strapping tape.

1.2 This method is known as the “strapping method” and is suitable for use as a working method, a reference method or a referee method.

NOTE For the reference method, the number of strappings required will be specified in the standard which refers to this part of ISO 7507.

1.3 The operation of strapping, the corrections to be made and the calculations leading to the compilation of the tank capacity table are described.

1.4 This method does not apply to abnormally deformed, e.g. dented or non-circular, tanks.

1.5 This method is suitable for tilted tanks with a deviation of up to 3 % from the vertical, provided that a correction for the measured tilt is applied in the calculations.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 91-1:1992, *Petroleum measurement tables — Part 1: Tables based on reference temperatures of 15 °C and 60 °F*

ISO 3675:1998, *Crude petroleum and liquid petroleum products — Laboratory determination of density — Hydrometer method*

ISO 4269:2001, *Petroleum and liquid petroleum products — Tank calibration by liquid measurement — Incremental method using volumetric meters*

ISO 7507-1:2003(E)

3 Terms and definitions

For the purposes of this document and subsequent parts of ISO 7507, the following terms and definitions apply.

- 3.1 argument**
independent variable of a function
- NOTE A table is entered with value(s) of the independent variable(s), the value(s) extracted from the table being known as the dependent value(s).
- 3.2 bottom calibration**
procedure to determine the quantity of liquid contained in a tank below the calibration datum-point
- 3.3 calibration**
process of determining the capacity of a tank, or the partial capacities corresponding to different levels
- 3.4 capacity**
total volume of a tank
- 3.5 capacity table**
tank table
tank capacity table
table showing the capacities of, or volumes in, a tank corresponding to various liquid levels measured from a stable reference point
- 3.6 course**
one circumferential ring of plates in a tank
- 3.7 calibration datum-point**
point used as the datum in the preparation of a calibration table
- NOTE Course heights and the effective levels of deadwood are measured from this point, to which the bottom calibration is also related.
- 3.8 deadwood**
any tank fitting that affects the capacity of the tank
- NOTE Deadwood is referred to as "positive deadwood" when the capacity of the fitting increases the effective capacity of the tank, or "negative deadwood" when the volume of the fitting displaces liquid and reduces the effective capacity.
- 3.9 dip**
innage
depth of a liquid in a tank above the dipping datum-point
- 3.10 dip-hatch**
gauge-hatch
opening in the top of a tank through which dipping and sampling operations are carried out

3.11**dip-point**

point on the dip-plate which the dip-weight touches during gauging and from which the measurements of the oil and water depths are taken

NOTE The dip-point usually corresponds to the datum-point, but when this is not so, the difference in level between the datum-point and the dip-point has to be allowed for in the calibration table.

3.12**dip-plate**

striking-plate positioned below the dip-hatch

NOTE The position of the dip-plate should not be affected by bottom or wall movements.

3.13**dip-tape**

graduated steel tape used for measuring the depth of the oil or water in a tank, either directly by dipping or indirectly by ullage

3.14**dip-weight**

weight attached to a steel dip-tape, of sufficient mass to keep the tape taut and of such shape as to facilitate the penetration of any sludge that might be present on the dip-point or the dip-plate

3.15**floating cover**

screen

lightweight cover of either metal or plastics material designed to float on the surface of a liquid in a tank

NOTE The cover rests upon the liquid surface and is used to retard evaporation of volatile products in a tank.

3.16**floating-roof tank**

tank in which the roof floats freely on the surface of the liquid contents, except at low levels when the weight of the roof is taken through its supports by the tank bottom

3.17**function**

when two variable quantities are interrelated, one quantity is said to be a function of the other

NOTE In the context of tank calibration, the volume of liquid contained in a tank is said to be a function of the dip or of the ullage.

3.18**gauging**

process of taking all the necessary measurements in a tank in order to determine the quantity of liquid that it contains

3.19**interpolation**

process of obtaining the value of a function corresponding to a value of the argument intermediate between those given

3.20**Littlejohn grip**

quick-release clamp that may be fitted around a strapping tape at any convenient position throughout its length

NOTE A handle is attached to the Littlejohn grip so that the strapping tape can be pulled to the correct tension.

ISO 7507-1:2003(E)**3.21****open capacity**

calculated capacity of a tank or part of a tank before any allowance has been made for deadwood

3.22**reference height**

vertical distance between the dip-point and the upper reference point

3.23**overall height**

total external height from the top of the shell to the base of the tank (plate)

3.24**referee method**

application of the strapping method of tank calibration to give a calibration of a tank for custody transfer purposes or to provide a basis for assessing the accuracy of other methods of tank calibration

3.25**reference method**

application of the strapping method of tank calibration to the measurement of a reference circumference for use in other methods of tank calibration

NOTE An example of such a method is the optical-reference-line method (see ISO 7507-2).

3.26**reference point**

a point to which measurements in either calibration or gauging are related

3.27**step-over**

device used in strapping for measuring the distance apart, along the arc, of two points on a tank shell where it is not possible to use a strapping tape directly because of an intervening obstruction, e.g. a protruding fitting

3.28**step-over constant**

distance between the measuring points of a step-over as measured along the arc of the particular course of the tank concerned

3.29**step-over correction**

difference between the apparent distance between two points on a tank shell as measured by a strapping tape passing over an obstruction and the true arc distance as measured by a step-over, i.e. the step-over constant

3.30**strapping tape**

specially designed and calibrated steel measuring tape graduated in units of length and used for taking circumferential measurements in tank calibration

3.31**strapping method**

method of tank calibration in which the capacities are calculated from the measurement of the external circumferences, due allowance being made for the thickness of the shell of the tank

3.32**tape positioner**

guide sliding freely on the strapping tape, used to pull and hold it in the correct position for taking measurements

3.33**tensioning handles**

handles fastened to the strapping tape, used for pulling it into the correct position and applying tension

3.34**ullage**

outage

capacity of a tank not occupied by the liquid

3.35**upper reference point**

point clearly defined on the dip-hatch directly above the dip-point to indicate the position at which dipping or ullaging shall be carried out

3.36**working method**

application of the strapping method of tank calibration by a simplified procedure that may result in some loss of accuracy and is unsuitable for assessing other methods

4 Precautions**4.1 Introduction**

This clause outlines the precautions that are applicable when tanks are being calibrated. The precautions necessary to ensure the safety of the operator are dealt with separately from those precautions which have to be taken to ensure the necessary precision required in the calibration of tanks.

4.2 General precautions

4.2.1 The utmost care and attention to detail shall be exercised when calibrating storage tanks.

4.2.2 All measurements shall be carefully observed and recorded as read, and any corrections which are required shall be recorded separately. If any unusual occurrences are noted during the operations, these occurrences shall be documented and the calibration shall be repeated, if necessary.

4.2.3 If the tank is only slightly distorted, sufficient additional measurements shall be taken to allow satisfactory calculation of its capacity table. If such additional measurements are required, the calibrator's notes shall include the reasons for the extra measurements.

It is also recommended that dimensioned sketches should be provided by the calibrator to show any abnormality of the tank or the fittings that affect calibration.

NOTE Seriously distorted tanks are best calibrated using liquid calibration methods similar to the method described in ISO 4269.

4.2.4 To ensure accuracy and repeatability of readings, lumps of paint, scale, etc., likely to interfere with measurement, shall be removed or the position of the measuring equipment adjusted accordingly.

4.2.5 If drawings for the tank are available, all relevant measurements shall be compared with the corresponding dimensions shown on the drawings. Any measurement which shows a significant discrepancy as a result of this comparison shall be reported and, if necessary, repeated.

4.2.6 If the calibration of a tank is interrupted, it may be resumed at a later date provided that:

- a) if there is a change of equipment or personnel, sufficient check measurements shall be made to ensure that the results obtained prior to the change correspond within the tolerances given in this method;
- b) all records of work done are complete and legible;