



# SLOVENSKI STANDARD

## SIST EN 1363-1:2012

01-november-2012

Nadomešča:  
SIST EN 1363-1:1999

---

### Preskusi požarne odpornosti - 1. del: Splošne zahteve

Fire resistance tests - Part 1: General Requirements

Feuerwiderstandsprüfungen - Teil 1: Allgemeine Anforderungen

Essais de résistance au feu - Partie 1: Exigences générales

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

**Ta slovenski standard je istoveten z: EN 1363-1:2012**

<https://standards.iteh.ai/catalog/standards/sist/05b1b071-a8a9-42fb-b2e3-c65ec6e5e92a/sist-en-1363-1-2012>

#### **ICS:**

13.220.50	Požarna odpornost gradbenih materialov in elementov	Fire-resistance of building materials and elements
-----------	---	--

**SIST EN 1363-1:2012**

**en,fr,de**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 1363-1:2012](#)

<https://standards.iteh.ai/catalog/standards/sist/05b1b071-a8a9-42fb-b2e3-c65ce6e5c92a/sist-en-1363-1-2012>

EUROPEAN STANDARD

**EN 1363-1**

NORME EUROPÉENNE

EUROPÄISCHE NORM

July 2012

ICS 13.220.50

Supersedes EN 1363-1:1999

English Version

**Fire resistance tests - Part 1: General Requirements**

Essais de résistance au feu - Partie 1: Exigences générales

Feuerwiderstandsprüfungen - Teil 1: Allgemeine Anforderungen

This European Standard was approved by CEN on 9 June 2012.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

[SIST EN 1363-1:2012](https://standards.iteh.ai/catalog/standards/sist/05b1b071-a8a9-42fb-b2e3-c65ce6e5c92a/sist-en-1363-1-2012)<https://standards.iteh.ai/catalog/standards/sist/05b1b071-a8a9-42fb-b2e3-c65ce6e5c92a/sist-en-1363-1-2012>

EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**Management Centre: Avenue Marnix 17, B-1000 Brussels**

## Contents

Page

Foreword.....	5
Introduction .....	6
1 Scope .....	7
2 Normative references .....	7
3 Terms, definitions, symbols and designations .....	8
3.1 Terms and definitions .....	8
3.2 Symbols and designations .....	10
4 Test equipment .....	10
4.1 General.....	10
4.2 Furnace .....	11
4.3 Loading equipment.....	11
4.4 Test frames.....	11
4.5 Instrumentation.....	12
4.5.1 Temperature .....	12
4.5.2 Pressure.....	13
4.5.3 Load .....	13
4.5.4 Deflection.....	13
4.5.5 Integrity.....	13
4.6 Precision of measuring equipment.....	14
5 Test conditions .....	14
5.1 Furnace temperature .....	14
5.1.1 Heating curve .....	14
5.1.2 Tolerances .....	14
5.2 Furnace pressure.....	15
5.2.1 General.....	15
5.2.2 Establishing the neutral pressure plane .....	16
5.3 Furnace atmosphere .....	16
5.4 Loading .....	16
5.5 Restraint/boundary conditions.....	16
5.6 Ambient temperature conditions .....	17
5.7 Deviation from required test conditions .....	17
6 Test specimen(s).....	17
6.1 Size .....	17
6.2 Number .....	17
6.2.1 Separating elements.....	17
6.2.2 Non-separating elements .....	17
6.3 Design .....	17
6.4 Construction.....	18
6.5 Verification .....	18
7 Installation of test specimen .....	18
7.1 General.....	18
7.2 Supporting constructions .....	18
7.2.1 General.....	18
7.2.2 Standard supporting constructions.....	19
7.2.3 Non-standard supporting constructions.....	21
8 Conditioning.....	21
8.1 Test specimen .....	21

iTech STANDARD PREVIEW  
(standards.itech.ai)

SIST EN 1363-1:2012

<https://standards.itech.ai/catalog/standards/sist/05b1b071-aba9-421b-b2e3-c65ce6e5e92a/sist-en-1363-1-2012>

8.2	Supporting constructions .....	21
9	Application of instrumentation .....	21
9.1	Thermocouples .....	21
9.1.1	Furnace thermocouples (plate thermometers).....	21
9.1.2	Unexposed surface thermocouples .....	22
9.1.3	Internal thermocouples.....	23
9.2	Pressure .....	23
9.2.1	General .....	23
9.2.2	Furnaces for vertical elements .....	23
9.2.3	Furnaces for horizontal elements.....	23
9.3	Deflection .....	23
10	Test procedure.....	24
10.1	Restraint application.....	24
10.2	Load application .....	24
10.3	Commencement of test.....	24
10.4	Measurements and observations .....	24
10.4.1	General .....	24
10.4.2	Temperatures .....	24
10.4.3	Furnace pressure .....	25
10.4.4	Deflection .....	25
10.4.5	Integrity .....	25
10.4.6	Load and restraints .....	26
10.4.7	General behaviour.....	26
10.5	Termination of test .....	26
11	Performance criteria.....	27
11.1	Loadbearing capacity.....	27
11.2	Integrity .....	27
11.3	Insulation.....	28
11.4	Consequential effects of failing certain performance criteria .....	28
11.4.1	Insulation and integrity versus loadbearing capacity .....	28
11.4.2	Insulation versus integrity .....	28
12	Test report.....	28
12.1	Test report.....	28
12.2	Expression of test results in the test report.....	30
Annex A	(informative) Field of application of test results .....	39
A.1	General .....	39
A.2	Field of direct application .....	39
A.3	Extended application .....	39
Annex B	(informative) The role of supporting constructions.....	40
B.1	General .....	40
B.2	Standard supporting constructions .....	40
B.3	Non-standard supporting constructions .....	40
Annex C	(informative) General information on thermocouples .....	42
C.1	Furnace thermocouples (plate thermometers).....	42
C.1.1	Maintenance .....	42
C.1.2	Positioning .....	42
C.2	Internal thermocouples.....	42
C.2.1	General .....	42
C.2.2	Specification .....	42
C.2.3	Fixing methods and positioning .....	42
C.3	Unexposed face thermocouples .....	43
C.3.1	General .....	43
C.3.2	Positioning .....	43
C.3.3	Fixing to specific materials .....	44
Annex D	(informative) Guidance on the basis for selection of the test load .....	46

## EN 1363-1:2012 (E)

D.1	General.....	46
D.2	Options for selecting the test load.....	46
Annex E (informative) Boundary and support conditions .....		47
Annex F (informative) Guidance on conditioning .....		48
F.1	General.....	48
F.2	Guidance on procedures for conditioning .....	48
F.3	Guidance on measurement techniques .....	49
F.3.1	Direct reading moisture meter.....	49
F.3.2	Oven drying techniques.....	49
Annex G (informative) Guidance on deflection measurements of vertical separating elements using a fixed datum .....		50
G.1	General.....	50
G.2	Apparatus .....	50
G.3	Procedure .....	50
G.4	Reporting .....	51
Bibliography .....		52

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 1363-1:2012](https://standards.iteh.ai/catalog/standards/sist/05b1b071-a8a9-42fb-b2e3-c65ce6e5c92a/sist-en-1363-1-2012)

<https://standards.iteh.ai/catalog/standards/sist/05b1b071-a8a9-42fb-b2e3-c65ce6e5c92a/sist-en-1363-1-2012>

## Foreword

This document (EN 1363-1:2012) has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2013, and conflicting national standards shall be withdrawn at the latest by January 2013.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1363-1:1999.

The main changes compared to EN 1363-1:1999 are:

- a) a tolerance is specified for the thickness of the thermocouple wire in the furnace thermocouple;
- b) a small variation to the layout of the unexposed surface thermocouples;
- c) a tolerance to the maximum pressure is specified;
- d) a redefinition of standard supporting constructions;
- e) a change to the required distance of thermocouples to a discontinuity from 15 mm into 20 mm;
- f) a redefinition of the commencement of the fire test;
- g) a redefinition for the load bearing capacity criterion;
- h) specifications for the short form test report are removed.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

This European Standard is technically related to ISO 834-1 prepared by ISO/TC92/SC2 "Fire resistance tests".

EN 1363, *Fire resistance tests*, consists of the following parts:

- *Part 1: General requirements* (this European Standard);
- *Part 2: Alternative and additional procedures*;
- *Part 3: Verification of furnace performance* (published as an ENV).

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**EN 1363-1:2012 (E)****Introduction**

The objective of determining fire resistance is to assess the behaviour of a specimen of an element of building construction when subjected to defined heating and pressure conditions. The method provides a means of quantifying the ability of an element to withstand exposure to high temperatures. It does so by setting criteria against which the loadbearing capacity, the fire containment (integrity) and the thermal transmittance (insulation) functions amongst other characteristics can be evaluated.

A representative sample of the element is exposed to a specified regime of heating and the performance of the test specimen is monitored on the basis of criteria described in the standard. Fire resistance of the test element is expressed as the time for which the appropriate criteria have been satisfied. The times so obtained are a measure of the adequacy of the construction in a fire; but they have no direct relationship with the duration time of a real fire.

**Caution**

The attention of all persons concerned with managing and carrying out fire resistance testing is drawn to the fact that fire testing might be hazardous and that there is a possibility that toxic and/or harmful smoke and gases will be emitted during the test. Mechanical and operational hazards might also arise during the construction of the test elements or structures, their testing and disposal of test residues.

An assessment of all potential hazards and risks to health needs to be made and safety precautions need to be identified and provided. Written safety instructions will be issued. Appropriate training will be given to relevant personnel. Laboratory personnel will ensure that they follow written safety instructions at all times.

**Uncertainty of measurement of fire resistance**

<https://standards.iteh.ai/catalog/standards/sist/05b1b071-a8a9-42fb-b2e3->

There are many factors which can affect the result of a fire resistance test. Those concerned with the variability of the specimen including its materials, manufacture and installation are not related to the uncertainty of measurement. Of the remainder, some, such as the different thermal dose provided by different furnaces, are much more significant than others such as the accuracy of calibration of the data logging system.

Because of the very labour intensive nature of the test, many of the factors that have a bearing on the result are operator-dependent. The training, experience and attitude of the operator is thus crucial to eliminate such variables which can significantly affect the degree of uncertainty of measurement. Unfortunately, it is not possible to numerically quantify these factors and therefore any attempt to determine uncertainty of measurement that does not take into account operator-dependent variables is of limited value.



## 1 Scope

This European Standard establishes the general principles for determining the fire resistance of various elements of construction when subjected to standard fire exposure conditions. Alternative and additional procedures to meet special requirements are given in EN 1363-2.

The principle that has been embodied within all European Standards relating to fire resistance testing is that where aspects and procedures of testing are common to all specific test methods e.g. the temperature/time curve, then they are specified in this test method. Where a general principle is common to many specific test methods but the details vary according to the element being tested (e.g. the measurement of unexposed face temperature), then the principle is given in this document, but the details are given in the specific test method. Where certain aspects of testing are unique to a particular specific test method (e.g. the air leakage test for fire dampers), then no details are included in this document.

The test results obtained might be directly applicable to other similar elements, or variations of the element tested. The extent to which this application is permitted depends upon the field of direct application of the test result. This is restricted by the provision of rules which limit the variation from the tested specimen without further evaluation. The rules for determining the permitted variations are given in each specific test method.

Variations outside those permitted by direct application are covered under extended application of test results. This results from an in-depth review of the design and performance of a particular product in test(s) by a recognised authority. Further consideration on direct and extended application is given in Annex A.

The duration for which the tested element, as modified by its direct or extended field of application, satisfies specific criteria will permit subsequent classification.

All values given in this Standard are nominal unless otherwise specified.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 520, *Gypsum plasterboards — Definitions, requirements and test methods*

EN 1363-2, *Fire resistance tests — Part 2: Alternative and additional procedures*

EN 13501-1, *Fire classification of construction products and building elements — Part 1: Classification using data from reaction to fire tests*

EN ISO 13943:2010, *Fire safety — Vocabulary (ISO 13943:2008)*

EN 60584-1, *Thermocouples — Part 1: Reference tables (IEC 60584-1)*

EN 60584-2, *Thermocouples — Part 2: Tolerances (IEC 60584-2)*

## EN 1363-1:2012 (E)

**3 Terms, definitions, symbols and designations****3.1 Terms and definitions**

For the purposes of document, the terms and definitions given in EN ISO 13943:2010 and the following apply.

**3.1.1****actual material properties**

properties of a material determined from representative samples taken from the test specimen for the fire test according to the requirements of the specific product standard

**3.1.2****characteristic material properties**

properties of a material which are specified for a grade of material which may be used for design purposes

**3.1.3****associated construction**

form of construction required to test some types of test specimen

EXAMPLE The aerated concrete slabs on top of a beam.

**3.1.4****deflection**

movement associated with structural and or thermal actions

**3.1.5****discontinuity**

interruption in the construction associated with a change in material or a joint

[SIST EN 1363-1:2012](http://standards.iteh.ai/SIST/EN/1363-1/2012)

Note 1 to entry: Examples of discontinuities are the joint between two adjacent boards in a partition, or the joint between one type of construction and another, such as the joint between a partition and a doorset or the joint between a partition and a glazed area within it.

**3.1.6****element of building construction**

defined construction component, such as a wall, partition, doorset, floor, roof, beam or column

**3.1.7****exposed face**

side of the test construction that is exposed to the heating conditions of the test

**3.1.8****glowing**

emittance of light without flaming associated with combustion of a material

**3.1.9****insulation**

ability of a test specimen of a separating element of building construction, when exposed to fire on one side, to restrict the temperature rise of the unexposed face to below specified levels

**3.1.10****integrity**

ability of a test specimen of a separating element of building construction, when exposed to fire on one side, to prevent the passage of flames and hot gases through and to prevent the occurrence of flames on the unexposed side

**3.1.11****loadbearing capacity**

ability of a test specimen of a loadbearing element to support its test load, where appropriate, without exceeding specified criteria with respect to both the extent of, and rate of, deflection

**3.1.12****loadbearing element**

element that is intended for use in supporting an external load in a building and maintaining this support in the event of a fire

**3.1.13****neutral pressure plane**

elevation at which the pressure is equal inside and outside of the furnace

**3.1.14****notional floor level**

assumed floor level relative to the position of the building element in service

**3.1.15****restraint**

constraint to expansion or rotation (induced by thermal and/or mechanical actions) afforded by the conditions at the ends, edges or supports of a test specimen

EXAMPLE      Examples of different types of restraint are: longitudinal, rotational and lateral.

**3.1.16****separating element**

element that is intended for use in maintaining separation between two adjacent areas of a building in the event of a fire

**3.1.17****supporting construction**

construction that may be required for the testing of some building elements into which the test specimen is assembled

Note 1 to entry:      For example, the wall into which a doorset is fitted, See Annex B

**3.1.18****sustained flaming**

continuous flaming for a period of time greater than 10 s

**3.1.19****test construction**

complete assembly of the test specimen together with its supporting construction

**3.1.20****test frame**

frame containing the test construction for the purpose of mounting onto the furnace

**3.1.21****test load**

load applied to the test specimen

**3.1.22****test specimen**

element (or part) of building construction provided for the purpose of determining either its fire resistance or its contribution to the fire resistance of another building element

**EN 1363-1:2012 (E)****3.1.23****discrete area(s)**

portion(s) of the total surface of the test specimen, which may be expected to have different fire insulation performance

**3.2 Symbols and designations**

The symbols and designations listed below define those used in this document.

<b>Symbol</b>	<b>Unit</b>	<b>Description</b>
<i>A</i>	°C min	the area under the average furnace temperature/time curve
<i>A<sub>s</sub></i>	°C min	the area under the standard temperature/time curve
<i>C</i>	mm	axial contraction measured from the start of heating
<i>d</i>	mm	the distance from the extreme fibre of the design compression zone to the extreme fibre of the design tensile zone of the structural section of a flexural test specimen
<i>D</i>	mm	the deflection measured from the commencement of heating
<i>h</i>	mm	the initial height of the loaded vertical test specimen
<i>L</i>	mm	the length of the span of the test specimen
<i>t</i>	min	the time from the commencement of heating
<i>T</i>	°C	the temperature within the test furnace
$\Delta T$	K	the temperature difference or the temperature rise

iteh STANDARD PREVIEW  
(standards.iteh.ai)

**4 Test equipment****4.1 General**

[SIST EN 1363-1:2012  
https://standards.iteh.ai/catalog/standards/sist/05b1b071-a8a9-42fb-b2e3-c65ce6e5c92a/sist-en-1363-1-2012](https://standards.iteh.ai/catalog/standards/sist/05b1b071-a8a9-42fb-b2e3-c65ce6e5c92a/sist-en-1363-1-2012)

Equipment used to carry out the test consists essentially of the following:

- a) a specially designed furnace to subject the test specimen to the test conditions;
- b) control equipment to enable the temperature of the furnace to be controlled as required in 5.1;
- c) equipment to control and monitor the pressure of the hot gases within the furnace as required in 5.2;
- d) a frame in which the test construction can be erected and which can be positioned in conjunction with the furnace so that appropriate heating, pressure and support conditions can be developed;
- e) arrangement for loading and restraint of the test specimen as appropriate, including control and monitoring of load;
- f) equipment for measuring temperature in the furnace and on the unexposed face of the test specimen, and where needed within the test specimen;
- g) equipment for measuring the deflection of the test specimen;
- h) equipment for evaluating integrity and for establishing compliance with the performance criteria described in Clause 11;
- i) equipment for establishing the elapsed time;
- j) equipment for measuring the oxygen concentration of furnace gases.

## 4.2 Furnace

The test furnace shall be designed to employ liquid or gaseous fuels and shall be capable of:

- a) heating of vertical or horizontal separating elements on one face, or
- b) heating of columns on all sides, or
- c) heating of walls on more than one side, or
- d) heating of beams on three or four sides, as appropriate.

Other special furnaces may be required for specific elements.

The furnace linings shall consist of materials with densities less than 1 000 kg/m<sup>3</sup>. Such lining materials shall have a minimum thickness of 50 mm and shall constitute at least 70 % of the internally exposed surface of the furnace.

The furnace shall be capable of providing the standard fire exposure conditions with respect to thermal exposure and pressure.

Furnaces may be designed so that assemblies of more than one element can be tested simultaneously, provided that all the requirements for each individual element can be complied with.

## 4.3 Loading equipment

The loading equipment shall be capable of subjecting test specimens to the level of loading determined in accordance with 5.4. The load may be applied hydraulically, mechanically or by the use of weights.

The loading equipment shall be able to simulate conditions of uniform loading, point loading, concentric loading, axial loading or eccentric loading as appropriate for the test construction. The loading equipment shall be capable of maintaining the test load at a constant value ( $\pm 5\%$  of the required value) without changing its distribution and following the maximum deflection and the rate of deflection of the test specimen until failure of loadbearing capacity occurs as defined in 11.3 or for the duration of the test, whichever occurs sooner.

The loading equipment shall not significantly influence the heat transfer through the specimen nor impede the use of the thermocouple insulating pads. It shall not interfere with the measurement of surface temperature and/or deflection and shall permit general observation of the unexposed face. The total area of the contact points between the loading equipment and the test specimen surface shall not exceed 10 % of the total area of the surface of a horizontal test specimen.

## 4.4 Test frames

Special test frames or other means shall be employed to reproduce the boundary and support conditions appropriate for the test constructions as required by 5.5. Different types of test constructions will require test frames of differing stiffness. The performance of the test frames shall be evaluated by applying an expansion force within the frame at mid-width between two opposite members and measuring the increase in the internal dimension. The increase shall not exceed 5 mm with an applied force of 25 kN. This evaluation shall be conducted in both directions of the frame.

Where test frames are to meet different requirements, these other requirements are given in the specific test method.

**EN 1363-1:2012 (E)****4.5 Instrumentation****4.5.1 Temperature****4.5.1.1 Furnace thermocouples**

The furnace thermocouples shall be plate thermometers comprised of an assembly of a folded nickel alloy plate, a thermocouple fixed to it and insulation material.

The folded metal plate shall be constructed from a strip of austenitic nickel based superalloy for high temperature oxidation resistance,  $(150 \pm 1)$  mm long by  $(100 \pm 1)$  mm wide by  $(0,7 \pm 0,1)$  mm, folded to the design as shown in Figure 1.

The measuring junction shall consist of nickel chromium/nickel aluminium (type K) wire as defined in EN 60584-1, contained within mineral insulation in a heat resisting steel alloy sheath of nominal diameter range of 1 mm to 3 mm, the hot junctions being electrically insulated from the sheath. The thermocouple hot junction shall be fixed to the geometric centre of the plate in the position shown in Figure 1 by a small strip made from the same material as the plate. The strip can be welded to the plate or may be screwed to it to facilitate replacement of the thermocouple. The strip shall be approximately 18 mm by 6 mm if it is spot welded to the plate and nominally 25 mm by 6 mm if it is to be screwed to the plate. The screw shall be 2 mm in diameter.

The assembly of plate and thermocouple shall be fitted with a pad of inorganic insulation material nominally  $(97 \pm 1)$  mm by  $(97 \pm 1)$  mm by  $(10 \pm 1)$  mm thick and with a density of  $(280 \pm 30)$  kg/m<sup>3</sup>.

Before the plate thermometers are first used, the folded plate part shall be aged by immersing it in a pre-heated oven at 1 000 °C for 1 h, or exposing it in a fire resistance furnace for 90 min during a test carried out following the standard temperature/time curve given in 5.1.1.

Where a plate thermometer is used more than once, a log of its use shall be maintained, indicating for each use the checks made and duration of use. The thermocouple and the insulation pad shall be replaced after 50 h exposure in the furnace.

**4.5.1.2 Unexposed surface thermocouples**

The temperature of the unexposed surface of the test specimen shall be measured by means of disc thermocouples of the type shown in Figure 2. In order to provide a good thermal contact, type K thermocouple wires, as defined in EN 60584-1, 0,5 mm in diameter (with tolerances as defined in EN 60584-2) shall be soldered to a 0,2 mm thick by 12 mm diameter copper disc. It is also permitted to use thermocouples whose wires have been twisted together and then soldered to the copper disc.

Each thermocouple shall be covered with a  $(30 \pm 2)$  mm x  $(30 \pm 2)$  mm x  $(2 \pm 0,5)$  mm thick insulating pad, silicate-fibre based and classified as A1 or A2 according EN 13501-1. The pad material shall have a density of  $(900 \pm 100)$  kg/m<sup>3</sup>, unless specified otherwise in specific test standards. The insulation pads shall be cut to accommodate the thermocouple wires. If the thermocouple wires are soldered separately to the disc as shown in Figure 2, the slots may originate from opposite corners of the pad or from mid way along opposite edges. The measuring and recording equipment shall be capable of operating within the limits specified in 4.6.

In the case of non-planar surface of the test specimen, the disc and/or pad shall be deformed to follow the main surface profile. If there is difficulty in fixing the standard pad, the size of the pad may be reduced on two parallel sides subject to covering the disc.

**4.5.1.3 Roving thermocouples**

One or more roving thermocouples of the design shown in Figure 3 shall be available to measure the unexposed surface temperature during a test at positions where higher temperatures are suspected. The measuring junction of the thermocouple shall consist of type K thermocouple wires as defined in EN 60584-1, 1,0 mm in diameter soldered to a 12 mm diameter, 0,5 mm thick copper disc. The thermocouple assembly

shall be provided with a handle so that it can be applied over any point on the unexposed surface of the test specimen.

#### 4.5.1.4 Internal thermocouples

If information concerning the internal temperature of a test specimen or particular component is required, it shall be obtained by means of thermocouples having characteristics appropriate to the range of temperatures to be measured, as well as suitable to the type of materials in the test specimen. A specification for the thermocouples for measurement of internal temperature is given in Annex C.

#### 4.5.1.5 Ambient temperature thermocouple

A thermocouple shall be used to indicate the ambient temperature within the laboratory in the vicinity of the test specimen both prior to and during the test period. The thermocouple shall be nominally 3 mm diameter, mineral insulated, stainless steel sheathed type K thermocouple as defined in EN 60584-1 with tolerances in accordance with EN 60584-2. The measuring junction shall be protected from radiated heat and draughts with a device as shown in Figure 8.

#### 4.5.2 Pressure

The pressure in the furnace shall be measured by means of one of the designs of sensors described in Figure 4. The measuring and recording equipment shall be capable of operating within the limits specified in 4.6.

Data measured at each measuring interval shall be used in the analysis of the test specimen's performance. If the data is presented as fixed or floating average values, the methodology for processing the data presented shall be clearly explained in the test report.

#### 4.5.3 Load

When using weights, no further measurement of load in a test is needed. The loads applied by hydraulic loading systems shall be measured by means of a load cell or other relevant equipment having the same accuracy or by monitoring the hydraulic pressure at an appropriate point. The measuring and recording equipment shall be capable of operating within the limits specified in 4.6.

#### 4.5.4 Deflection

Deflection measurements can be made by using equipment employing mechanical, optical or electrical techniques. Where such equipment is used in relation to performance criteria, e.g. for measurements of deflection or contraction, it shall be capable of operating at a frequency of at least one reading per minute. All necessary precautions shall be taken to prevent any drift in the sensor readings due to heating. Details of precision of measuring equipment are given in 4.6.

#### 4.5.5 Integrity

##### 4.5.5.1 Cotton pad

Unless specified otherwise in the standards for specific elements, the cotton pad employed in the measurement of integrity shall consist of 100 % new, untreated, undyed and soft cotton fibres which shall weigh between 3 g – 4 g per 100 x 100 x 20 mm. It shall be conditioned prior to use by drying in an oven at  $(100 \pm 5)$  °C for at least 30 min. After drying it may be stored in a desiccator or in an airtight container for up to one week before oven drying again as described above. For use it shall be mounted in a wire frame with sizes of either  $(100 \pm 5) \times (100 \pm 5) \times (20 \pm 1)$  mm or  $(30 \pm 2) \times (30 \pm 2) \times (20 \pm 1)$  mm, as shown in Figure 5, provided with a handle of suitable length. The cotton pad with nominal sizes 30 x 30 x 20 mm shall only be used when required by the specific test method.