



# SLOVENSKI STANDARD SIST EN ISO 7396-1:2016

01-julij-2016

## Nadomešča:

SIST EN ISO 7396-1:2007

SIST EN ISO 7396-1:2007/A1:2010

SIST EN ISO 7396-1:2007/A2:2010

SIST EN ISO 7396-1:2007/A3:2013

---

## Sistemi napeljav za medicinske pline - 1. del: Sistemi napeljav za stisnjene medicinske pline in podtlak (ISO 7396-1:2016)

Medical gas pipeline systems - Part 1: Pipeline systems for compressed medical gases and vacuum (ISO 7396-1:2016)

Rohrleitungssysteme für medizinische Gase - Teil 1: Rohrleitungssysteme für medizinische Druckgase und Vakuum (ISO/DIS 7396-1:2013)

Systèmes de distribution de gaz médicaux - Partie 1: Systèmes de distribution de gaz médicaux comprimés et de vide (ISO 7396-1:2016)

**Ta slovenski standard je istoveten z: EN ISO 7396-1:2016**

---

### **ICS:**

11.040.10	Anestezijska, respiratorna in reanimacijska oprema	Anaesthetic, respiratory and reanimation equipment
-----------	--	--

**SIST EN ISO 7396-1:2016**

**en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN ISO 7396-1:2016](https://standards.iteh.ai/catalog/standards/sist/aee1d1e4-ee92-4f95-9f42-bf6657b2b172/sist-en-iso-7396-1-2016)

<https://standards.iteh.ai/catalog/standards/sist/aee1d1e4-ee92-4f95-9f42-bf6657b2b172/sist-en-iso-7396-1-2016>

EUROPEAN STANDARD

**EN ISO 7396-1**

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2016

ICS 11.040.10

Supersedes EN ISO 7396-1:2007

English Version

## Medical gas pipeline systems - Part 1: Pipeline systems for compressed medical gases and vacuum (ISO 7396-1:2016)

Systèmes de distribution de gaz médicaux - Partie 1:  
Systèmes de distribution de gaz médicaux comprimés  
et de vide (ISO 7396-1:2016)

Rohrleitungssysteme für medizinische Gase - Teil 1:  
Rohrleitungssysteme für medizinische Druckgase und  
Vakuum (ISO 7396-1:2016)

This European Standard was approved by CEN on 7 November 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

<b>Contents</b>	<b>Page</b>
<b>European foreword.....</b>	<b>3</b>
<b>Annex ZA (informative) Relationship between this European Standard and the Essential Requirements of EU Directive 93/42/EEC on Medical devices.....</b>	<b>4</b>

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN ISO 7396-1:2016](https://standards.iteh.ai/catalog/standards/sist/aee1d1e4-ee92-4f95-9f42-bf6657b2b172/sist-en-iso-7396-1-2016)  
<https://standards.iteh.ai/catalog/standards/sist/aee1d1e4-ee92-4f95-9f42-bf6657b2b172/sist-en-iso-7396-1-2016>

## European foreword

This document (EN ISO 7396-1:2016) has been prepared by Technical Committee ISO/TC 121 “Anaesthetic and respiratory equipment” in collaboration with Technical Committee CEN/TC 215 “Respiratory and anaesthetic equipment”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2016, and conflicting national standards shall be withdrawn at the latest by March 2019.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 7396-1:2007.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## Endorsement notice

The text of ISO 7396-1:2016 has been approved by CEN as EN ISO 7396-1:2016 without any modification.

## Annex ZA (informative)

### Relationship between this European Standard and the Essential Requirements of EU Directive 93/42/EEC on Medical devices

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association to provide one means of conforming to Essential Requirements of the New Approach Directive 93/42/EEC on Medical devices.

Once this standard is cited in the Official Journal of the European Union under that Directive and has been implemented as a national standard in at least one Member State, compliance with the clauses of this standard given in Table ZA.1 confers, within the limits of the scope of this standard, a presumption of conformity with the corresponding Essential Requirements of that Directive and associated EFTA regulations.

**Table ZA.1— Correspondence between this European Standard and Directive 93/42/EEC, Medical devices**

Clause(s)/Sub-clause(s) of this European Standard	Essential Requirements (ERs) of EU Directive 93/42/EEC	Qualifying remarks/Notes
4	1, 2, 7.1, 7.3	
4.3.2	9.3	
4.3.3	7.1	
4.3.4	9.2, 9.3, 12.7.1	
4.3.5	9.3	
4.3.6	7.1, 9.3, 12.7.1	
4.3.7	7.2, 7.6	
4.3.8	9.2	
4.4.1	2, 3	
4.4.2	1, 2, 3, 4	
5.1 to 5.2.9	1, 2, 3, 4, 7.6, 12.8.1, 12.8.2	
5.3.1 to 5.3.3	2, 3, 7.6	
5.3.4	7, 12.7.1	
5.3.5	7, 12.7.1	
5.3.6	7.1, 9.3	
5.3.7	2, 3	
5.4	3	
5.5.1	3, 12.8	
5.5.2.1 to 5.5.2.11	3, 7.2, 12.8	
5.5.2.12	7.6	
5.5.2.13	3, 9.2	
5.5.2.14	12.7.2	
5.5.2.15	3, 7.2	
5.5.3	3, 7.2, 7.6, 12.8	

5.6	2, 3, 7.2, 7.3, 7.6, 9.3, 12.8	
5.7.1 to 5.7.7	3, 8.1, 12.8.1	
5.7.8 to 5.7.9	7,6, 8.1	
5.7.10	12.7.2	
5.7.11	7.2	
5.7.12	3, 7.2, 7.6	
5.7.13	3, 9.3	
5.7.14	3, 9.3	
5.7.15	3, 12.8	
5.8 to 5.10	2, 3	
6	1, 2, 3, 4, 12.3, 12.8.1, 12.8.2, 12.9	
7	1, 2, 3	
7.1	9.3, 12.7.1	
7.2.1 to 7.2.4	2, 3	
7.2.5	9.2	
7.2.6	9.2	
7.3	2,3,4	
7.4	2, 3, 12.8	
8	1, 2	
9	9.1, 12.7.4, 13.6 c)	
9.3	9.2, 12.5, 12.6	
10	13.2	
11	1, 2, 3, 4, 9	
11.1.5	12.6	
12.1 to 12.4	1, 2, 3	
12.5.1	9.3, 12.7.1, 9.2	
12.5.2	7.5, 9.3, 12.7.1, 9.2	
12.6.1	7.5, 12.7.1	
12.6.2 to 12.6.9	2, 3, 7.5, 12.8	
12.6.10	7.2	
12.6.11	7.2	
12.6.12	7.2	
12.6.13	7.2	
12.6.14	7.2	
12.6.15 to 12.6.16	12.7.4, 12.8.1	
13	4, 13.1, 13.3, 13.6 c), 13.6 d), 13.6 e), 13.6 k), 13.6 l), 13.6 m), 13.6 n), 13.6 q)	

**WARNING:** Other requirements and other EU Directives may be applicable to the products falling within the scope of this standard.

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN ISO 7396-1:2016](https://standards.iteh.ai/catalog/standards/sist/aee1d1e4-ee92-4f95-9f42-bf6657b2b172/sist-en-iso-7396-1-2016)

<https://standards.iteh.ai/catalog/standards/sist/aee1d1e4-ee92-4f95-9f42-bf6657b2b172/sist-en-iso-7396-1-2016>



INTERNATIONAL  
STANDARD

ISO  
7396-1

Third edition  
2016-02-15

---

---

**Medical gas pipeline systems —**  
**Part 1:**  
**Pipeline systems for compressed**  
**medical gases and vacuum**

*Systèmes de distribution de gaz médicaux —*

*Partie 1: Systèmes de distribution de gaz médicaux comprimés et de vide*

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN ISO 7396-1:2016](https://standards.iteh.ai/catalog/standards/sist/aee1d1e4-ee92-4f95-9f42-bf6657b2b172/sist-en-iso-7396-1-2016)

<https://standards.iteh.ai/catalog/standards/sist/aee1d1e4-ee92-4f95-9f42-bf6657b2b172/sist-en-iso-7396-1-2016>



Reference number  
ISO 7396-1:2016(E)

© ISO 2016

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN ISO 7396-1:2016

<https://standards.iteh.ai/catalog/standards/sist/ae1d1e4-ee92-4f95-9f42-bf6657b2b172/sist-en-iso-7396-1-2016>



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Ch. de Blandonnet 8 • CP 401  
CH-1214 Vernier, Geneva, Switzerland  
Tel. +41 22 749 01 11  
Fax +41 22 749 09 47  
copyright@iso.org  
www.iso.org

# Contents

Page

<b>Foreword</b> .....	<b>vi</b>
<b>Introduction</b> .....	<b>vii</b>
<b>1 (*) Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>2</b>
<b>3 Terms and definitions</b> .....	<b>3</b>
<b>4 General requirements</b> .....	<b>9</b>
4.1 (*) Safety.....	9
4.2 (*) Alternative construction.....	10
4.3 Materials.....	10
4.4 System design.....	12
4.4.1 General.....	12
4.4.2 Extensions and modifications of existing pipeline systems.....	12
<b>5 Supply systems</b> .....	<b>13</b>
5.1 System components.....	13
5.2 General requirements.....	13
5.2.1 Capacity and storage.....	13
5.2.2 Continuity of supply.....	13
5.2.3 Primary source of supply.....	14
5.2.4 Secondary source of supply.....	14
5.2.5 Reserve source(s) of supply.....	14
5.2.6 Means of pressure relief.....	15
5.2.7 Maintenance supply assembly.....	15
5.2.8 Pressure regulators.....	16
5.2.9 (*)Ozone Sterilizers.....	16
5.3 Supply systems with cylinders, cylinder bundles or high-pressure reservoir(s).....	16
5.4 Supply systems with cryogenic or non-cryogenic vessels.....	16
5.5 Supply systems for air.....	17
5.5.1 General requirements.....	17
5.5.2 Supply systems with air compressor(s).....	18
5.5.3 Supply systems with proportioning unit(s).....	21
5.6 Supply systems with oxygen concentrator(s).....	23
5.6.1 General requirements.....	23
5.6.2 Primary source of supply.....	23
5.6.3 Secondary source of supply.....	23
5.6.4 Reserve source of supply.....	24
5.6.5 Specifications for oxygen 93.....	24
5.6.6 Oxygen concentrator unit.....	25
5.6.7 Oxygen 93 reservoirs.....	25
5.6.8 Oxygen analysers.....	25
5.6.9 Local filling of permanently attached high-pressure reservoir(s), acting as reserve source of supply.....	26
5.7 Supply systems for vacuum.....	27
5.8 Location of supply systems.....	28
5.9 Location of cylinder manifolds.....	28
5.10 Location of stationary cryogenic vessels.....	29
<b>6 Monitoring and alarm systems</b> .....	<b>29</b>
6.1 General.....	29
6.2 Installation requirements.....	29
6.3 Monitoring and alarm signals.....	30
6.3.1 General.....	30
6.3.2 Auditory signals.....	30
6.3.3 Visual signals.....	30

## ISO 7396-1:2016(E)

6.3.4	Emergency and operating alarm characteristics	30
6.3.5	Information signals	31
6.3.6	Remote alarm extensions	31
6.4	Provision of operating alarms	31
6.5	Provision of emergency clinical alarms	32
6.6	(*) Provision of emergency operating alarms	32
<b>7</b>	<b>Pipeline distribution systems</b>	<b>33</b>
7.1	Mechanical resistance	33
7.2	Distribution pressure	33
7.3	Low-pressure hose assemblies and low-pressure flexible connections	34
7.4	Double-stage pipeline distribution systems	35
<b>8</b>	<b>Shut-off valves</b>	<b>35</b>
8.1	General	35
8.2	Service shut-off valves	36
8.3	Area shut-off valves	36
<b>9</b>	<b>Terminal units, gas-specific connectors, medical supply units, pressure regulators and pressure gauges</b>	<b>38</b>
<b>10</b>	<b>Marking and colour coding</b>	<b>38</b>
10.1	Marking	38
10.2	Colour coding	38
<b>11</b>	<b>Pipeline installation</b>	<b>39</b>
11.1	General	39
11.2	Pipeline supports	40
11.3	Pipeline joints	40
11.4	Extensions and modifications of existing pipeline systems	41
<b>12</b>	<b>Testing and commissioning</b>	<b>41</b>
12.1	General	41
12.2	General requirements for tests	42
12.3	Inspections and checks before concealment	42
12.4	Tests, checks and procedures before use of the system	42
12.5	Requirements for inspections and checks before concealment	43
12.5.1	Inspection of marking and pipeline supports	43
12.5.2	Check for compliance with design specifications	43
12.6	Requirements for tests, checks and procedures before use of the system	43
12.6.1	General	43
12.6.2	(*) Tests of area shut-off valves for leakage and closure and checks for correct zoning and correct identification	45
12.6.3	Test for cross-connection	45
12.6.4	Test for obstruction and flow	46
12.6.5	Checks of terminal units and NIST, DISS or SIS connectors for mechanical function, gas specificity and identification	47
12.6.6	Tests or checks of system performance	47
12.6.7	(*) Tests of pressure-relief valves	47
12.6.8	Tests of all sources of supply	48
12.6.9	Tests of monitoring and alarm systems	48
12.6.10	Test for particulate contamination of pipeline distribution systems	48
12.6.11	Tests of the quality of medical air produced by supply systems with air compressor(s)	49
12.6.12	Tests of the quality of air for driving surgical tools produced by supply systems with air compressor(s)	49
12.6.13	Tests of the quality of medical air produced by supply systems with proportioning unit(s)	49
12.6.14	Tests of the quality of oxygen 93 produced by supply systems with oxygen concentrator(s)	49
12.6.15	Filling with specific gas	49

12.6.16	Tests of gas identity.....	49
12.6.17	Verification of restart after power supply failure.....	50
12.7	Statement of compliance to this part of ISO 7396.....	50
<b>13</b>	<b>Information to be supplied by the manufacturer.....</b>	<b>50</b>
13.1	General.....	50
13.2	Instructions for installation.....	50
13.3	Instructions for use.....	50
13.4	Operational management information.....	51
13.5	“As-installed” drawings.....	52
13.6	Electrical diagrams.....	52
<b>Annex A</b>	<b>(informative) Schematic representations of typical supply systems and area distribution systems.....</b>	<b>53</b>
<b>Annex B</b>	<b>(informative) Guidelines for location of cylinder manifolds, cylinder storage areas and stationary vessels for cryogenic or non-cryogenic liquids.....</b>	<b>84</b>
<b>Annex C</b>	<b>(informative) Example of procedure for testing and commissioning.....</b>	<b>85</b>
<b>Annex D</b>	<b>(informative) Typical forms for documenting compliance of the pipeline systems for compressed medical gas and vacuum.....</b>	<b>98</b>
<b>Annex E</b>	<b>(informative) Temperature and pressure relationships.....</b>	<b>128</b>
<b>Annex F</b>	<b>(informative) Risk management checklist.....</b>	<b>130</b>
<b>Annex G</b>	<b>(informative) Operational management.....</b>	<b>147</b>
<b>Annex H</b>	<b>(informative) Rationale.....</b>	<b>167</b>
<b>Annex I</b>	<b>(informative) Rationale (for compressor hazards).....</b>	<b>170</b>
<b>Annex J</b>	<b>(informative) Considerations for implementation and use of oxygen 93.....</b>	<b>171</b>
<b>Annex K</b>	<b>(informative) Manufacture of medical gases on site, Responsibility for medical gas quality.....</b>	<b>173</b>
<b>Bibliography</b>	.....	<b>176</b>

## ISO 7396-1:2016(E)

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 121, *Anaesthetic and respiratory equipment*, Subcommittee SC 6, *Medical gas systems*.

This third edition cancels and replaces the second edition (ISO 7396-1:2007) and ISO 10083:2006, which have been technically revised. It also incorporates the Amendments ISO 7396-1:2007/Amd1:2010, ISO 7396-1:2007/Amd2:2010, and ISO 7396-1:2007/Amd3:2013.

ISO 7396 consists of the following parts, under the general title *Medical gas pipeline systems*:

- *Part 1: Pipeline systems for compressed medical gases and vacuum*
- *Part 2: Anaesthetic gas scavenging disposal systems*

## Introduction

Many healthcare facilities use pipeline systems to deliver medical gases and to provide vacuum to areas where they are used in patient care or to power equipment such as ventilators and surgical tools.

This part of ISO 7396 specifies requirements for pipeline systems for gases for medicinal use, medical device gases, gases for driving surgical tools and vacuum. It is intended for use by those persons involved in the design, construction, inspection and operation of healthcare facilities treating human beings. Those persons involved in the design, manufacture and testing of equipment intended to be connected to these pipeline systems should also be aware of the contents of this part of ISO 7396.

This part of ISO 7396 seeks to ensure that medical gas pipelines contain only the specific gas (or vacuum) intended to be supplied. For this reason, gas-specific components are used for terminal units and for other connectors which are intended to be used by the operator. In addition, each system is tested and certified to contain only the specific gas (or vacuum).

The objectives of this part of ISO 7396 are to ensure the following:

- a) non-interchangeability between different pipeline systems by design, installation and testing;
- b) continuous supply of gases and vacuum at specified quality, pressures and specified flows by providing appropriate sources;
- c) use of suitable materials;
- d) cleanliness of components;
- e) correct installation;
- f) provision of monitoring and alarm systems;
- g) correct marking of the pipeline system;
- h) testing and commissioning;
- i) quality of the gases delivered by the pipeline system;
- j) correct operational management;
- k) safety features of the sources to ensure the quality of the gases according to specification.

The responsibility for the quality of the medical gas supplied via the medical gas pipeline system should be assigned to a nominated person within the healthcare facility. This role would usually be assigned to the Head Pharmacist, who may in turn nominate other responsible person(s) on site to manage the day-to-day requirements.

Where the medical gas is supplied by a third party (in some jurisdictions under licence from the national, regional or local regulatory body), the supplier is responsible for ensuring that the medical gas as delivered meets the relevant specification requirements. In this case, the healthcare facility is responsible under local regulations for ensuring that the product meets the specifications as ordered, that the product administered to patients is not adulterated and complies with specifications and regulations, and that the product manufacturer is informed immediately of any undesirable effects or defects in the quality of the product.

Where the healthcare facility manufactures the gas on site, e.g. for medical air produced by air compressor systems, medical air produced by proportioning systems or oxygen 93 produced by oxygen concentrator systems, the healthcare facility is responsible for all aspects of the medical gas quality.

**NOTE** Vacuum is also the responsibility of the healthcare facility.

[Annex G](#) provides guidance for the assignment of responsibility for production and quality control of the gases and vacuum.