



SLOVENSKI STANDARD
SIST EN 12201-3:2011/kFprA1:2012
01-julij-2012

**Cevni sistemi iz polimernih materialov za oskrbo z vodo in za odvodnjavanje in
kanalizacijo pod tlakom - Polietilen (PE) - 3. del: Fitingi**

Plastics piping systems for water supply, and for drainage and sewerage under pressure
- Polyethylene (PE) - Part 3: Fittings

Kunststoff-Rohrleitungssysteme für die Wasserversorgung und für Entwässerungs- und
Abwasserdruckleitungen - Polyethylen (PE) - Teil 3: Formstücke

Systèmes de canalisations en plastique pour l'alimentation en eau et pour les
branchements et les collecteurs d'assainissement avec pression - Polyéthylène (PE) -
Partie 3 : Raccords

Ta slovenski standard je istoveten z: EN 12201-3:2011/FprA1

ICS:

23.040.45	Fitingi iz polimernih materialov	Plastics fittings
91.140.60	Sistemi za oskrbo z vodo	Water supply systems
93.030	Zunanji sistemi za odpadno vodo	External sewage systems

SIST EN 12201-3:2011/kFprA1:2012 **en,fr,de**

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

FINAL DRAFT
EN 12201-3:2011

FprA1

May 2012

ICS 23.040.45

English Version

Plastics piping systems for water supply, and for drainage and sewerage under pressure - Polyethylene (PE) - Part 3: Fittings

Systèmes de canalisations en plastique pour l'alimentation en eau et pour les branchements et les collecteurs d'assainissement avec pression - Polyéthylène (PE) - Partie 3 : Raccords

Kunststoff-Rohrleitungssysteme für die Wasserversorgung und für Entwässerungs- und Abwasserdruckleitungen - Polyethylen (PE) - Teil 3: Formstücke

This draft amendment is submitted to CEN members for unique acceptance procedure. It has been drawn up by the Technical Committee CEN/TC 155.

This draft amendment A1, if approved, will modify the European Standard EN 12201-3:2011. If this draft becomes an amendment, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for inclusion of this amendment into the relevant national standard without any alteration.

This draft amendment was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	3
1 Modification to the Foreword	4
2 Modification to 7.3, Requirements	4

Foreword

This document (EN 12201-3:2011/FprA1:2012) has been prepared by Technical Committee CEN/TC 155 "Plastics piping systems and ducting systems", the secretariat of which is held by NEN.

This document is currently submitted to the Unique Acceptance Procedure.

EN 12201-3:2011/FprA1:2012 (E)**1 Modification to the Foreword**

Just before the paragraph beginning with "System Standards are based", add the following paragraph:

"Due to Amendment 1 to EN 12201-3:2011, this document comprises technical changes to:

- Subclause 7.3, Requirements."

2 Modification to 7.3, Requirements

In Footnote c in Table 4 — Mechanical characteristics, replace the sentence "The stress shall be calculated using the nominal dimensions of the pipe used in the test assembly." with "The test pressure shall be calculated using the design SDR of the fitting."